



STANDARD

ANSI/ASHRAE Standard 62.1-2016

(Supersedes ANSI/ASHRAE Standard 62.1-2013)

Includes ANSI/ASHRAE addenda listed in Appendix K

Ventilation for Acceptable Indoor Air Quality

See Appendix K for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, and the American National Standards Institute.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the Standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website (www.ashrae.org) or in paper form from the Senior Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 62.1
Cognizant TC: 4.3, Ventilation Requirements and Infiltration
SPLS Liaison 2011–2013: Steven J. Emmerich
SPLS Liaison 2013–2016: John F. Dunlap
ASHRAE Staff Liaison: Mark Weber

Hoy R. Bohanon, Jr., *Chair* (2015–2016)
Co-Vice Chair (2014–2015)
Roger L. Hedrick, *Chair* (2013–2015)
Hamid Habibi, *Vice-Chair* (2015–2016)
Wayne R. Thomann, *Co-Vice Chair* (2013–2015)
Hugo O. Aguilar
Gary L. Berlin
Gregory Brunner
Mark P. Buttner
Gustavo G. Chaves
Eric Chen
James K. Chisholm
Waller S. Clements
Leonard A. Damiano
Abdel K. Darwich
Helen D. Davis
Paul L. Doppel
Francis J. Fisher, Jr.

Kevin B. Gallen
Gregg Gress
Brian J. Hafendorfer
Donald C. Herrmann
Nathan L. Ho
Tianzhen Hong
Elliott Horner
Gregg Gress
Eli P. Howard, III
Bashar Madani
John K. McFarland
Molly E. McGuire
Stephany I. Mason
Wayne E. Morris
Adam S. Muliawan
Kashif Nawaz
John Nelson, Jr.

Jianlei Niu
Jonathan W. W. Olsen
Laura G. Petrillo-Groh
Lisa J. Rogers
Duane P. Rothstein
Chandra Sekhar
Charles J. Seyffer
Harris M. Sheinman
Jeffrey K. Smith
Kirk J. Stache
Dennis A. Stanke
W. Brad M. Stanley
Erica Stewart
Pawel Wargocki
Josiah Wiley
Scott D. Williams
Marwa Zaatari

ASHRAE STANDARDS COMMITTEE 2015–2016

Douglass T. Reindl, *Chair*
Rita M. Harrold, *Vice-Chair*
James D. Aswegan
Niels Bidstrup
Donald M. Brundage
John A. Clark
Waller S. Clements
John F. Dunlap
James W. Earley, Jr.
Keith I. Emerson

Steven J. Emmerich
Julie M. Ferguson
Walter T. Grondzik
Roger L. Hedrick
Srinivas Katipamula
Rick A. Larson
Lawrence C. Markel
Arsen K. Melikov
Mark P. Modera
Cyrus H. Nasser

Heather L. Platt
David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Jack H. Zarour
Julia A. Keen, *BOD ExO*
James K. Vallort, *CO*

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS
ANSI/ASHRAE Standard 62.1-2016,
Ventilation for Acceptable Indoor Air Quality

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	3
3 Definitions	3
4 Outdoor Air Quality	5
5 Systems and Equipment	5
6 Procedures	11
7 Construction and System Start-Up	19
8 Operations and Maintenance	21
9 References	21
Normative Appendix A: Multiple-Zone Systems	24
Normative Appendix B: Separation of Exhaust Outlets and Outdoor Air Intakes	27
Informative Appendix C: Summary of Selected Air Quality Guidelines	29
Informative Appendix D: Rationale for Minimum Physiological Requirements for Respiration Air Based on CO ₂ Concentration	40
Informative Appendix E: Acceptable Mass Balance Equations for Use with the IAQ Procedure	42
Informative Appendix F: Information on Selected National Standards and Guidelines for PM ₁₀ , PM _{2.5} , and Ozone	44
Informative Appendix G: Application and Compliance	45
Informative Appendix H: Documentation	47
Informative Appendix I: National Ambient Air Quality Standards (NAAQS)	50
Informative Appendix J: Informative References	51
Informative Appendix K: Addenda Description Information	52

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2016 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

The 2016 edition of ANSI/ASHRAE Standard 62.1-2016 combines Standard 62.1-2013 and the fourteen approved and published addenda to the 2013 edition. Specific information on the contents of each addendum and approval dates for addenda are included in Informative Appendix K.

First published in 1973 as Standard 62, Standard 62.1 is updated on a regular basis using ASHRAE's continuous maintenance procedures. Addenda are publicly reviewed, approved by ASHRAE and ANSI, and published as a supplement at approximately 18 months. The complete collection of addenda to the standard are incorporated into the current edition and published as a new edition every three years.

Standard 62.1 has undergone key changes over the years, reflecting the ever-expanding body of knowledge, experience, and research related to ventilation and air quality. While the purpose of the standard remains unchanged—to specify minimum ventilation rates and other measures intended to provide indoor air quality (IAQ) that is acceptable to human occupants and that minimizes adverse health effects—the means of achieving this goal have evolved. In its first edition, the standard adopted a prescriptive approach to ventilation by specifying both minimum and recommended outdoor airflow rates to obtain acceptable indoor air quality for a variety of indoor spaces. In its 1981 edition, the standard reduced minimum outdoor airflow rates and introduced an alternative performance-based approach, the Indoor Air Quality Procedure, which allowed for the calculation of the amount of outdoor air necessary to maintain the levels of indoor air contaminants below recommended limits. Today, the standard includes three procedures for ventilation design, the IAQ Procedure, the Ventilation Rate Procedure, and the Natural Ventilation Procedure.

In its 1989 edition, in response to a growing number of buildings with apparent indoor air quality problems, the standard increased minimum outdoor airflow rates significantly and introduced a requirement for finding outdoor air intake flow requirements for multiple-zone recirculating systems.

The 1999 and 2001 editions made several minor changes and clarifications that did not impact the minimum required outdoor airflow rates. The 2004 edition—the last time the standard was revised in its entirety—modified the IAQ Procedure to improve enforceability, but more significantly it modified the Ventilation Rate Procedure, changing both the minimum outdoor airflow rates and the procedures for calculating both zone-level and system-level outdoor airflow rates. The 2007, 2010, and 2013 editions of the standard provided

some significant updates, but the changes primarily focused on usability and clarity.

The 2016 edition revises and improves the standard in several ways. Scope was changed to remove residential occupancies from 62.1 with a concurrent change in 62.2 to add all residential spaces. Significant changes include the following:

- Previously, Standard 62.1 had responsibility for multi-family residential buildings that are 4 stories or more. Now the dwelling units themselves are covered by Standard 62.2 regardless of building height, while common areas are covered by Standard 62.1.
- The definition of “environmental tobacco smoke” (ETS) was revised to include emissions from electronic smoking devices and from smoking of cannabis.
- Operations and maintenance requirements were revised to closer align with the requirements in ASHRAE/ACCA Standard 180-2012.
- Requirements were added to the Indoor Air Quality Procedure for determining minimum ventilation rates by including consideration of the combined effects of multiple contaminants of concern on individual organ systems.
- Laboratory exhaust continues to be assigned a default of Air Class 4, but the change explicitly allows a responsible EH&S professional to determine that a lower air class is appropriate for particular systems.
- Ventilation is allowed to be reduced to zero through the use of occupancy sensors (not through contaminant or CO₂ measurements) for spaces of selected occupancy types, provided that ventilation is restored to V_{bz} whenever occupancy is detected.
- Changes in language related to demand control ventilation remove the assumption that the standard is intended to be used only for calculations for code review and not physical operation.

For more specific information on these changes and on other revisions made to the standard by other addenda, refer to Informative Appendix K. Users of the standard are encouraged to use the continuous maintenance procedure to suggest changes for further improvements.

A form for submitting change proposals is included in the back of the standard. The project committee for Standard 62.1 will take formal action on all change proposals received.

1. PURPOSE

1.1 The purpose of this standard is to specify minimum ventilation rates and other measures intended to provide indoor air quality that is acceptable to human occupants and that minimizes adverse health effects.

1.2 This standard is intended for regulatory application to new buildings, additions to existing buildings, and those changes to existing buildings that are identified in the body of the standard.

1.3 This standard is intended to be used to guide the improvement of indoor air quality in existing buildings.

2. SCOPE

2.1 This standard applies to spaces intended for human occupancy within buildings except those within dwelling units in residential occupancies in which occupants are nontransient.

2.2 This standard defines requirements for ventilation and air-cleaning-system design, installation, commissioning, and operation and maintenance.

2.3 Additional requirements for laboratory, industrial, health care, and other spaces may be dictated by workplace and other standards, as well as by the processes occurring within the space.

2.4 Although the standard may be applied to both new and existing buildings, the provisions of this standard are not intended to be applied retroactively when the standard is used as a mandatory regulation or code.

2.5 This standard does not prescribe specific ventilation rate requirements for spaces that contain smoking or that do not meet the requirements in the standard for separation from spaces that contain smoking.

2.6 Ventilation requirements of this standard are based on chemical, physical, and biological contaminants that can affect air quality.

2.7 Consideration or control of thermal comfort is not included.

2.8 This standard contains requirements, in addition to ventilation, related to certain sources, including outdoor air, construction processes, moisture, and biological growth.

2.9 Acceptable indoor air quality may not be achieved in all buildings meeting the requirements of this standard for one or more of the following reasons:

- a. Because of the diversity of sources and contaminants in indoor air
- b. Because of the many other factors that may affect occupant perception and acceptance of indoor air quality, such as air temperature, humidity, noise, lighting, and psychological stress
- c. Because of the range of susceptibility in the population
- d. Because outdoor air brought into the building may be unacceptable or may not be adequately cleaned

3. DEFINITIONS (SEE FIGURE 3.1)

acceptable indoor air quality: air in which there are no known contaminants at harmful concentrations as determined by cognizant authorities and with which a substantial majority (80% or more) of the people exposed do not express dissatisfaction.

air-cleaning system: a device or combination of devices applied to reduce the concentration of airborne contaminants such as microorganisms, dusts, fumes, respirable particles, other particulate matter, gases, vapors, or any combination thereof.

air conditioning: the process of treating air to meet the requirements of a conditioned space by controlling its temperature, humidity, cleanliness, and distribution.

air, ambient: the air surrounding a building; the source of outdoor air brought into a building.

air, exhaust: air removed from a space and discharged to outside the building by means of mechanical or natural ventilation systems.

air, indoor: the air in an enclosed occupiable space.

air, makeup: any combination of outdoor and transfer air intended to replace exhaust air and exfiltration.

air, outdoor: ambient air and ambient air that enters a building through a ventilation system, through intentional openings for natural ventilation, or by infiltration.

air, primary: air supplied to the ventilation zone prior to mixing with any locally recirculated air.

air, recirculated: air removed from a space and reused as supply air.

air, return: air removed from a space to be recirculated or exhausted.

air, supply: air delivered by mechanical or natural ventilation to a space and composed of any combination of outdoor air, recirculated air, or transfer air.

air, transfer: air moved from one indoor space to another.

air, ventilation: that portion of supply air that is outdoor air plus any recirculated air that has been treated for the purpose of maintaining acceptable indoor air quality.

breathing zone: the region within an occupied space between planes 3 and 72 in. (75 and 1800 mm) above the floor and more than 2 ft (600 mm) from the walls or fixed air-conditioning equipment.

cognizant authority: an agency or organization that has the expertise and jurisdiction to establish and regulate concentration limits for airborne contaminants, or an agency or organization that is recognized as authoritative and has the scope and expertise to establish guidelines, limit values, or concentrations levels for airborne contaminants.

concentration: the quantity of one constituent dispersed in a defined amount of another.

conditioned space: that part of a building that is heated or cooled, or both, for the comfort of occupants.

contaminant: an unwanted airborne constituent with the potential to reduce acceptability of the air.

contaminant mixture: two or more contaminants that target the same organ system.

demand-controlled ventilation (DCV): any means by which the breathing zone outdoor airflow (V_{bz}) can be varied to the occupied space or spaces based on the actual or estimated number of occupants, ventilation requirements of the occupied zone, or both.

dwelling unit: a single unit providing complete, independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking, and sanitation.

energy recovery ventilation system: a device or combination of devices applied to provide the outdoor air for ventilation in which energy is transferred between the intake and exhaust airstreams.