

ANSI/ASHRAE Standard 87.2-2009
(Supersedes ANSI/ASHRAE Standard 87.2-2002)



ASHRAE STANDARD

In-Situ Method of Testing Propeller Fans for Reliability

Approved by the ASHRAE Standards Committee on January 24, 2009; by the ASHRAE Board of Directors on January 28, 2009; and by the American National Standards Institute on January 29, 2009.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the standard number is the year of ASHRAE Board of Directors approval. The latest copies may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**
1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

ASHRAE Standard Project Committee 87.2

Cognizant TC: TC 5.1, Fans

SPLS Liaison: K. William Dean

David M. Carroll, *Chair**
Terry D. Bickley*
Joseph Brooks*

Franco Cincotti*
John A. Murphy*

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2008–2009

Hugh F. Crowther, *Chair*
Steven T. Bushby, *Vice-Chair*
Robert G. Baker
Michael F. Beda
Donald L. Brandt
Paul W. Cabot
Kenneth W. Cooper
Samuel D. Cummings, Jr.
K. William Dean
Martin Dierycxk
Robert G. Doerr
Allan B. Fraser
Nadar R. Jayaraman
Byron W. Jones

Jay A. Kohler
Carol E. Marriott
Merle F. McBride
Frank Myers
H. Michael Newman
Janice C. Peterson
Douglas T. Reindl
Lawrence J. Schoen
Boggarm S. Setty
Bodh R. Subherwal
William F. Walter
Michael W. Woodford
David E. Knebel, *BOD ExO*
Andrew K. Persily, *CO*

Stephanie Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Assistant Director of Technology for Standards and Special Projects of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ANSI/ASHRAE Standard 87.2-2009 In-Situ Method of Testing Propeller Fans for Reliability

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Requirements	2
5 General Approach	2
6 Apparatus and Instrumentation	3
7 Test Setup	3
8 Test Procedure	4
9 Data Reduction.....	4
10 Life-Cycle Testing.....	4
11 References	5

NOTE

When addenda, interpretations, or errata to this standard have been approved, they can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org.

© Copyright 2009 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org
All rights reserved.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Standard 87.2 is classified as an ASHRAE Standard Method of Testing. It recommends procedures that will permit evaluation of the dynamic characteristics of propeller fan assemblies under conditions that are as close as possible to actual application conditions. First published in 2002, the standard has been revised in this edition to clarify its intent and update its references.

Experience has shown that there are many instances in which excessive vibration and/or failures occur in heating, ventilating, and air-conditioning (HVAC) equipment when the propeller fan assembly, consisting of a fan impeller, its drive motor, and support structure, is operated at or near a resonance frequency of the system. Excitation at these resonance frequencies can occur in a variety of ways, including unbalance, aerodynamic forces, motor torque pulsations, or blade flutter; and may be encountered during normal steady-state operation of the equipment. Transient excitation (e.g., start-up) forces must also be considered.

The methods described herein permit the evaluation of the dynamic characteristics of the propeller fan assembly early in the development process so that problems can be identified and corrective action taken. For the purposes of this standard, the fan specimens should reflect production or near-production designs. Guidance will be provided to assist the investigator in collection and interpretation of data necessary to estimate reliability; however, the identification of specific acceptance criteria is beyond the scope of this standard.

1. PURPOSE

The purpose of this standard is to establish a method of testing propeller fans to measure the dynamic characteristics that are essential in the proper selection and application of such fans to minimize the potential for fatigue failure.

2. SCOPE

2.1 This standard applies to propeller fans that are used in heating, ventilating, refrigerating, and air-conditioning equipment and that

- a. are constructed of built-up or of monolithic materials,
- b. may include a slinger ring or hub, or both, and
- c. are direct or belt driven.

2.2 This test method characterizes the fan in the application for which it is intended.

3. DEFINITIONS

The definitions of vibration terms used in this standard conform to those given in ANSI S1.1¹ and in ISO Standard 2041.² The most important definitions used in the standard are given below.

resonance frequency: the frequency at which operation of the equipment leads to a peak in the response spectrum. **Note:** For lightly damped structures, the resonance frequency can be taken to be the natural frequency.

natural frequency: a frequency at which a structure will vibrate when excited. **Note:** All practical structures possess many natural frequencies.

4. REQUIREMENTS

This standard requires that the specimen fan under investigation be tested in a manner that replicates both the support of the fan/motor subassembly and the flow conditions to which the fan will be subjected in the actual application. These conditions include the static pressure rise and volume flow rates that the fan will produce during the actual application as well as the presence of all upstream or downstream obstructions that may be present in the actual application.

The preferred test environment is the actual unit in which the fan will be operated. This would include units with multiple fans. The unit should be situated in a manner that replicates the normal recommended application for the unit and be capable of operating over the entire speed range for the product.

An acceptable alternative is a mock-up or master fan test environment, which replicates the actual unit in terms of airflow resistance, upstream and downstream obstructions, and the support structure for the fan or fan/motor subassembly. In addition, the stiffness associated with the structure that supports the propeller fan assembly must be replicated.

To meet the intent of this standard, the specimen fan must be manufactured in a manner similar to the manufacturing processes anticipated for this product.

5. GENERAL APPROACH

5.1 The inherent stiffness and mass of each of the components of the propeller fan assembly will give rise to resonance frequencies when the assembly is excited. A fan will be considered reliable when the induced mean and alternating stress levels in any part of the fan are sufficiently low as to not cause fatigue when the fan is run at any anticipated operating condition. It is recommended that the fan should not be operated within $\pm 5\%$ of any speed that causes the excitation of a resonance frequency.

5.2 A common method to determine stress levels in fans is to use strain gages placed at strategic locations on the fan. The fan is assembled into an actual unit or appropriate mock-up. Strain measurements are then recorded and analyzed over the full speed and static pressure ranges for the fan. From these mean and alternating strain measurements, stresses can be calculated.

5.3 Although not a requirement of this standard, some form of endurance and/or accelerated life testing is highly recommended when the proximity to resonance is at or close to allowable limits.