



ASHRAE® GUIDELINE

Measurement of Energy and Demand Savings

Approved by the ASHRAE Standards Committee June 22, 2002, and by the ASHRAE Board of Directors June 27, 2002.

ASHRAE Guidelines are updated on a five-year cycle; the date following the Guideline is the year of approval. The latest edition of an ASHRAE Guideline may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in U.S. and Canada).

©Copyright 2002 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1049-894X

**AMERICAN SOCIETY OF HEATING,
REFRIGERATING AND
AIR-CONDITIONING ENGINEERS, INC.**
1791 Tullie Circle, NE • Atlanta, GA 30329

ASHRAE Guideline Project Committee 14P
Cognizant TC: TC 9.6, Energy System Utilization
SPLS Liaison: Matt R. Hargan

George Reeves, *Chair**
Kenneth L. Gillespie, Jr., *Vice-Chair**
John D. Cowan*
Charles Wayne Frazell*
Jeff S. Haberl*
Kristin H. Heinemeier*
John S. Kromer*
James P. Kummer*

Richard P. Mazzucchi*
Agami T. Reddy*
Steven Schiller*
Ish Sud*
Jack S. Wolpert*
Thomas P. Wutka*
David E. Claridge
Charles H. Culp, III

**Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2001-2002

Nance C. Lovvorn, *Chair*
Thomas E. Watson, *Vice-Chair*
Charles G. Arnold
Van D. Baxter
Dean S. Borges
Paul W. Cabot
Waller S. Clements
Charles W. Coward, Jr.
Harold L. Crowder, Jr.
Brian P. Dougherty
Richard A. Evans
Arthur D. Hallstrom

Richard D. Hermans
John F. Hogan
Frederick H. Kohloss
William J. Landman
Rodney H. Lewis
Ross D. Montgomery
Davor Novosel
Dennis A. Stanke
Michael Tavares
Steven T. Taylor
J. Richard Wright
Lee W. Burgett, *CO*
Gordon V.R. Holness, *ExO*

Claire B. Ramspeck, *Manager of Standards*

SPECIAL NOTE

This Guideline was developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). ASHRAE Guidelines are developed under a review process, identifying a guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by project committees appointed specifically for the purpose of writing Guidelines. The project committee chair and vice-chair must be members of the ASHRAE; while other members of the project committee may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) guidelines are not appealable, and (d) guidelines are not submitted to ANSI for approval.

The Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Guideline,
- participation in the next review of the Guideline,
- offering constructive criticism for improving the Guideline,
- permission to reprint portions of the Guideline.

DISCLAIMER

ASHRAE publishes Guidelines in order to provide assistance to interested parties on issues that relate to the design, testing, application, and/or evaluation of products, concepts, and practices where there may be more than one acceptable approach. Guidelines are not mandatory and only provide one source of information that may be helpful in any given situation.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ASHRAE Guideline 14-2002, Measurement of Energy and Demand Savings

SECTION	PAGE
Foreword.....	4
1 Purpose	4
2 Scope.....	4
3 Utilization	4
3.1 Basic Methodology	4
3.2 Range of Approaches.....	5
3.3 Uncertainty and Cost.....	5
3.4 Planning and Objectives.....	6
3.5 Compliance	6
4 Definitions	7
5 Requirements and Common Elements.....	10
5.1 Approaches	10
5.2 Common Elements of all Approaches.....	10
5.3 Compliance Requirements.....	16
5.4 Design of a Savings Measurement Process	18
5.5 Implementation of the Savings Measurement Process	21
6 Specific Approaches	21
6.1 Whole Building Approach.....	21
6.2 Retrofit Isolation Approach.....	25
6.3 Whole Building Calibrated Simulation Approach (Calibrated Simulation)	32
7 Instrumentation and Data Management	45
7.1 Introduction.....	45
7.2 Measurement Procedure.....	45
7.3 Instrumentation	46
7.4 Measurement Techniques	46
7.5 Calibration of Instrumentation	47
7.6 Measurement System Verification and Data Validation.....	47

7.7 The Uncertainty of the Measurement.....	48
7.8 Measurement System Maintenance.....	48
7.9 References.....	49
7.10 Bibliography.....	49
ANNEX A: Physical Measurements.....	50
A.1 Sensors.....	50
A.2 Calibration Techniques.....	56
A.3 Laboratory Standards for Measurement of Physical Characteristics.....	59
A.4 Equipment Testing Standards.....	60
A.5 Cost and Error Considerations.....	68
ANNEX B: Determination of Savings Uncertainty.....	101
B.1 Scope and Objective.....	101
B.2 Brief Preamble of Uncertainty and Sources of Uncertainty.....	101
B.3 Background in Savings Uncertainty.....	106
B.4 Uncertainty Formulae.....	106
B.5 Discussion and Examples.....	108
B.6 Implication Towards Required Level of M&V.....	109
B.7 Calibrated Simulation.....	110
B.8 Nomenclature.....	110
B.9 References.....	111
ANNEX C: Examples.....	111
C.1 Examples for Clause 6.1 Whole Building Approach.....	111
C.2 Examples for Clause 6.2 Retrofit Isolation Approach.....	126
ANNEX D: Regression Techniques.....	139
D.1 Eliminating Net Bias Error Due to Data Length Variation.....	139
D.2 Multiple Independent Variables.....	140
D.3 Data Requirements.....	140
D.4 Energy Use Baseline Development with a Regression Model.....	140
D.5 Regression Model Selection.....	143
D.6 Models Based on Measured Indoor Temperature.....	143
D.7 References.....	143

ANNEX E: Retrofit Isolation Approach Techniques	144
E.1 Retrofit Isolation Approach for Pumps	144
E.2 Retrofit Isolation Approach for Fans.....	147
E.3 Retrofit Isolation Approach for Chillers	149
E.4 Retrofit Isolation Approach for Boilers and Furnaces	154
E.5 Retrofit Isolation Approach for Lighting.....	156
E.6 Retrofit Isolation Approach for Unitary and Split Condensing Equipment	159
E.7 Retrofit Isolation Generic Test Procedure	164

(This foreword is not part of this guideline but is included for information purposes only.)

FOREWORD

Guideline 14 was developed by ASHRAE to fill a need for a standardized set of energy (and demand) savings calculation procedures. The intent is to provide guidance on minimum acceptable levels of performance for determining energy and demand savings, using measurements, in commercial transactions. Note that it is entirely possible to have a sale/purchase, lease, or other arrangement for energy-efficient equipment that does not involve measurements. Indeed, the vast majority of transactions are of this type. However, if the savings determination is to be based on measurements, certain minimum requirements are necessary in order to avoid a process that appears to be based on actual savings but might be highly inaccurate, biased, or random.

It is expected that ASHRAE Guideline 14 will be used for transactions between energy service companies (ESCOs) and their customers and between ESCOs and utilities, where the utilities have elected to purchase energy savings. Use of ASHRAE Guideline 14 is expected to provide savings results sufficiently well specified and reasonably accurate so that the parties to the transaction can have adequate assurance for the payment basis. Other applications of ASHRAE Guideline 14 may include documenting energy savings for various credit programs, e.g., emission reduction credits associated with energy efficiency activities.

Determining savings with measurements in accordance with this guideline involves measuring post-retrofit energy use and comparing that to the measured pre-retrofit use, adjusted or normalized, to act as a proxy for the conditions that would have prevailed had the retrofit not been performed. Therefore, determining energy savings through the use of measurements involves more than just verifying that new equipment has been installed and can function as expected, although those tasks are usually a necessary part of determining savings. In addition, energy savings cannot be claimed to be "measured" if no pre-retrofit data are available.

Sampling is often used in projects involving end-use monitoring or what we call the "retrofit isolation approach." Annex B gives procedures to calculate the added uncertainty due to sampling. ASHRAE Guideline 14 may be used to measure the energy savings from a utility sponsored or contracted multiple-building energy conservation project. Applying ASHRAE Guideline 14 to such a project would allow the use of Annex B to calculate the measurement uncertainty directly. The net impacts of large-scale utility energy conservation programs, such as those that may involve market transformation or standard offers for purchase of conservation energy, are specifically excluded from the scope of ASHRAE Guideline 14, although individual and multiple-building projects within such programs are covered.

ASHRAE Guideline 14 primarily addresses measurements of energy and demand for determining savings. Other tasks are needed in any energy performance contract. These can include determining appropriate utility rates, inspecting and commissioning equipment, etc. Users of ASHRAE Guideline 14 who are interested in learning more about some of the

contractual issues and types of performance contracts will find relevant discussion in the DOE publication "International Performance Measurement and Verification Protocol" (IPMVP 2000) available at <www.ipmvp.org>.

1. PURPOSE

The purpose of this document is to provide guidelines for reliably measuring the energy and demand savings due to building energy management projects.

2. SCOPE

2.1 This guideline provides for using measured pre-retrofit and post-retrofit data to quantify the billing determinants (e.g., kWh, kW, MCF, etc.) used for calculation of energy and demand savings payments to energy service companies, utilities, or others.

2.2 ASHRAE Guideline 14 includes the determination of energy and demand savings from individual facilities or meters.

2.3 Procedures include all forms of energy, including electricity, gas, oil, district heating/cooling, etc.

2.4 The procedures encompass residential, commercial, and industrial buildings.

2.5 The procedures do not include

- a. sampling methodologies that may be used in large-scale demand-side management programs,
- b. metering standards, or
- c. major industrial process loads.

3. UTILIZATION

3.1 Basic Methodology

There is no direct way of measuring energy use or demand savings since instruments cannot measure the absence of energy use or demand. However, the absence of energy use or demand can be calculated by comparing measurements of energy use and/or demand from before and after implementation of an energy conservation measure (ECM). Simple comparison by subtraction of post-retrofit energy use from the pre-retrofit quantity does not differentiate between the energy impacts of the ECM and those of other factors such as weather or occupancy. In order to assess the effectiveness of the ECM alone, the influence of these other complicating factors, such as weather and usage factors, must be removed.

This guideline addresses determination of energy savings by comparing before and after energy use and making adjustments for non-ECM changes that affect energy use. The basic method of this guideline is shown in Figure 3-1. It involves projecting energy use or demand patterns of the pre-retrofit (baseline) period into the post-retrofit period. Such projection requires adjustment of baseline energy use or demand to different conditions of weather, occupancy, or other energy-governing variables. Savings are then determined as:

$$\text{Savings} = (\text{Baseline energy use or demand projected to Post-retrofit conditions}) - (\text{Post-retrofit energy use or demand})$$