



**GUIDELINE**

**ASHRAE Guideline 16-2014**  
(Supersedes ASHRAE Guideline 16-2010)

# Selecting Outdoor, Return, and Relief Dampers for Air-Side Economizer Systems

Approved by the ASHRAE Standards Committee on January 18, 2014, and by the ASHRAE Board of Directors on January 22, 2014.

ASHRAE Guidelines are scheduled to be updated on a five-year cycle; the date following the guideline number is the year of ASHRAE Board of Directors approval. The latest edition of an ASHRAE Guideline may be purchased on the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

**ASHRAE Guideline Project Committee 16**  
**Cognizant TC: TC 9.1, Large Building Air-Conditioning Systems**  
**SPLS Liaison: Dennis A. Stanke**

Steven T. Taylor, *Chair\**  
Safir M. Adeni  
Bryan H. Atkinson  
Gil Avery  
Herman F. Behls\*  
Michael R. Bilderbeck\*  
Kirk H. Drees\*  
Larry G. Felker  
John L. Kuempel, Jr.\*

Frank W. Mayhew  
Les Milewski  
Stanley A. Mumma\*  
Keith D. Robinson\*  
Harry J. Sauer, Jr.\*  
David A. Schaaf, Jr.\*  
Adrienne G. Thomle\*  
Robert M. Van Becelaere\*  
Michael L. Wolf

*\*Denotes members of voting status when the document was approved for publication*

---

**ASHRAE STANDARDS COMMITTEE 2013–2014**

William F. Walter, *Chair*  
Richard L. Hall, *Vice-Chair*  
Karim Amrane  
Joseph R. Anderson  
James Dale Aswegan  
Charles S. Barnaby  
Steven F. Bruning  
John A. Clark  
Waller S. Clements

David R. Conover  
John F. Dunlap  
James W. Earley, Jr.  
Steven J. Emmerich  
Julie M. Ferguson  
Krishnan Gowri  
Cecily M. Grzywacz  
Rita M. Harrold  
Adam W. Hinge  
Debra H. Kennoy

Malcolm D. Knight  
Rick A. Larson  
Mark P. Modera  
Cyrus H. Nasser  
Janice C. Peterson  
Heather L. Platt  
Douglas T. Reindl  
Julia A. Keen, *BOD ExO*  
Thomas E. Werkema, Jr., *CO*

Stephanie C. Reiniche, *Manager of Standards*

---

**SPECIAL NOTE**

This Guideline was developed under the auspices of ASHRAE. ASHRAE Guidelines are developed under a review process, identifying a guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by project committees appointed specifically for the purpose of writing Guidelines. The project committee chair and vice-chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) Guidelines are not appealable, and (d) Guidelines are not submitted to ANSI for approval.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Guideline,
- b. participation in the next review of the Guideline,
- c. offering constructive criticism for improving the Guideline, or
- d. permission to reprint portions of the Guideline.

---

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

---

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

## CONTENTS

### ASHRAE Guideline 16-2014, Selecting Outdoor, Return, and Relief Dampers for Air-Side Economizer Systems

SECTION.....	PAGE
Foreword .....	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions .....	2
4 System Arrangements.....	2
5 Damper Selection Rationale .....	8
6 References.....	9
Informative Annex A—Installation of Dampers.....	11
Informative Annex B—Sensing Building Pressures .....	11
Informative Annex C—Example Problem.....	12
Informative Annex D—Bibliography .....	14

#### NOTE

Approved addenda, errata, or interpretations for this guideline can be downloaded free of charge from the ASHRAE Web site at [www.ashrae.org/technology](http://www.ashrae.org/technology).

© 2014 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · [www.ashrae.org](http://www.ashrae.org) · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.  
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this guideline. It is merely informative and does not contain requirements necessary for conformance to the guideline.)

## FOREWORD

Control damper selection and sizing are a critical first step in the design of a control system. The system designer should take care to make the correct damper selections. Improper selection and sizing may cause hunting; improper temperature, flow, and pressure control; and other operational difficulties.

The objective of this guideline is to address the application and sizing of outdoor, return, and relief dampers used to control

- outdoor-air intake for economizer (free) cooling,
- minimum-ventilation outdoor airflow for indoor air quality, and
- building pressure.

This guideline focuses on the three most common damper configurations for systems employing an air-side economizer:

- a. Supply and return fan
- b. Supply and relief fan
- c. Supply fan with gravity (nonpowered) relief

These configurations have outdoor, return, and relief dampers. For other damper configurations, such as multiple return dampers within a system, the general information in this guideline is still beneficial.

The methods of control described in this guideline are not intended to indicate a control preference but to show how dampers typically operate in heating, ventilating, and air-conditioning systems that include an air-side economizer.

This is a revision of Guideline 16-2010. This guideline was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry. Changes made for the 2014 revision include

- updated references and
- minor editorial changes.

## 1. PURPOSE

This guideline provides the basis for selecting and sizing control dampers (outdoor, return, and relief) commonly found in constant-air-volume (CAV) and variable-air-volume (VAV) air-handling units (AHU) and systems with air-side economizers.

## 2. SCOPE

**2.1** This guideline covers the application of mixed-air control dampers in AHUs and systems that incorporate air-side economizer systems for cooling.

**2.2** This guideline addresses the selection of control dampers based on damper characteristics and damper pressure drop.

**2.3** This guideline is not intended to cover dampers used elsewhere in heating, ventilating, and air-conditioning (HVAC) systems.

**2.4** This guideline does not cover air mixing.

## 3. DEFINITIONS

**3.1** Definitions of most terms used in this guideline can be found in *ASHRAE Terminology of Heating, Ventilation, Air Conditioning, & Refrigeration* (ASHRAE 1991).

**3.2** Terms used in this guideline that are not found in *ASHRAE Terminology of Heating, Ventilation, Air Conditioning, & Refrigeration* or that are used differently are defined in this section.

**maximum outdoor-air damper:** a modulating damper or set of dampers used to control the outdoor airflow to the system in excess of minimum ventilation outdoor air for free cooling (air-side economizer). Also called economizer outdoor-air damper. May also serve to provide the minimum outside airflow control.

**minimum outdoor-air damper:** a two-position damper in parallel with the maximum outdoor-air damper to provide the minimum outdoor air required for ventilation.

**path pressure drop:** the pressure drop in the air path that is affected by the control damper.

**relief air:** building return air discharged by the AHU equipment to control building pressure when an HVAC system is operating in the economizer cycle.

**ventilation air:** the minimum amount of outdoor air required for the purpose of controlling air contaminant levels in buildings.

**$\alpha$ -value:** the ratio of path pressure drop, including fully open control damper pressure drop, to the pressure drop across the fully open damper at design flow.

## 4. SYSTEM ARRANGEMENTS

### 4.1 General

**4.1.1** This guideline covers air-handling systems that include an air-side economizer. The most common variations are:

- a. Arrangement 1 (Figure 1): HVAC system with a return fan
- b. Arrangement 2 (Figure 2): HVAC system with a relief fan
- c. Arrangement 3 (Figure 3): HVAC system with a gravity or motorized relief damper

**4.1.2** Figures 1–3 show features and controls that are optional. For example, supply/return/relief fan motors are shown with variable-speed drives as the method of controlling fan capacity. Other methods of fan capacity control may be used. The figures shown are VAV systems. This guideline also applies to CAV systems.

**4.1.3** The supply-air temperature sensor (T-1) normally controls dampers D-2 and D-3 so that one damper closes as the other opens (Figure 4). For Arrangements 2 and 3, sequencing the dampers (Figure 5) reduces energy costs in VAV systems by reducing pressure drop in the mixing mode. This has an impact on the way dampers are selected (see Section 4.3.3.4, second paragraph).