

ASHRAE Guideline 2-2010
(Supersedes ASHRAE Guideline 2-2005)



ASHRAE GUIDELINE

Engineering Analysis

Systems and Data

review of "ASHRAE Guideline 2-2...". Click here to purchase the full version from the ANSI store.

Approved by the ASHRAE Standards Committee on June 26, 2010, and by the ASHRAE Board of Directors on June 30, 2010.

ASHRAE Guidelines are updated on a five-year cycle; the date following the Guideline is the year of ASHRAE Board of Directors approval. The latest edition of an ASHRAE Guideline may be purchased on the ASHRAE Web site (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© Copyright 2010 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1049-894X

**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**

1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

ASHRAE Guideline Project Committee 2
Cognizant TC: TC 1.2, Instruments and Measurements
SPLS Liaison: Douglas T. Reindl

Rick M. Heiden, *Chair**
David P. Yuill, *Vice-Chair**
Peter R. Armstrong
Anthony G. Buschur*
Chad B. Dorgan
William M. Healy*
Sally A. Hooks

B. Ronald Moncrief*
John W. Mroszczyk
T.W. Petrie
Agami Reddy
Douglas T. Reindl
Lauren M. Ronsse*
Michael A. Wegenka
Claudia Wood

**Denotes members of voting status when the document was approved for publication*

review of "ASHRAE Guideline 2-2...". [Click here to purchase the full version from the ANSI store.](#)

Steven T. Bushby, *Chair*
H. Michael Newman, *Vice-Chair*
Douglass S. Abramson
Robert G. Baker
Michael F. Beda
Hoy R. Bohanon, Jr.
Kenneth W. Cooper
K. William Dean
Martin Dieryckx
Allan B. Fraser
Nadar R. Jayaraman
Byron W. Jones
Jay A. Kohler
Carol E. Marriott

Merle F. McBride
Frank Myers
Janice C. Peterson
Douglas T. Reindl
Lawrence J. Schoen
Boggarm S. Setty
Both R. Subherwal
James R. Tauby
James K. Vallort
William F. Walter
Michael W. Woodford
Craig P. Wray
Wayne R. Reedy, *BOD ExO*
Thomas E. Watson, *CO*

Stephanie Reiniche, *Manager of Standards*

SPECIAL NOTE

This Guideline was developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). ASHRAE Guidelines are developed under a review process, identifying a guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by project committees appointed specifically for the purpose of writing Guidelines. The project committee chair and vice-chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) Guidelines are not appealable, and (d) Guidelines are not submitted to ANSI for approval.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Guideline,
- b. participation in the next review of the Guideline,
- c. offering constructive criticism for improving the Guideline, or
- d. permission to reprint portions of the Guideline.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ASHRAE Guideline 2-2010 Engineering Analysis of Experimental Data

SECTION	PAGE
Foreword.....	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Types of Measurements	3
5 The Experimental Process	3
6 Uncertainty Analysis Methods and Techniques.....	6
7 Data Validation	6
8 Regression Analysis.....	9
9 References	14
Informative Annex A: Uncertainty Analysis/Propagation of Error.....	14
Informative Annex B: HVAC&R System Examples	20
Informative Annex C: Reporting of Results	24
Informative Annex D: Bibliography.....	26

NOTE

Approved addenda, errata, or interpretations for this guideline can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© Copyright 2010 American Society of Heating,
Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE
Atlanta, GA 30329
www.ashrae.org
All rights reserved.

(This foreword is not part of this guideline. It is merely informative and does not contain requirements necessary for conformance to the guideline.)

FOREWORD

Guideline 2 was originally created from the material contained in ASHRAE Standard 41.5-75, Standard Measurement Guide: Engineering Analysis of Experimental Data when it was published in 1986 and reaffirmed with minor editorial changes in 1990 and 1996. Because technology and use of computer programs has increased significantly since 1986, Guideline 2 was revised in 2005 to provide a greater focus not only on the analysis of the data but also on how to collect the data to ensure proper analysis. In addition, the scope of the guideline was expanded to include engineers and technicians who collect, analyze, and report information on systems covered in ASHRAE standards and other publications. In this revision of the guideline, dual units were used throughout, references were revised to reflect the latest editions, and some of the definitions were revised to make them more consistent with ASHRAE terminology and industry practice.

Although this guideline addresses many of the ways in which statistics are used in HVAC&R applications, it should not be considered a comprehensive statistical text. An attempt has been made to provide sufficient background and references for the statistics used in this guideline.

1. PURPOSE

The purpose of this document is to provide guidelines for planning, analyzing data, and reporting the uncertainty of experiments.

2. SCOPE

Appropriate terms are defined and statistically based procedures and formulae are recommended for evaluating experimental data related to HVAC&R. Numerous examples are provided to illustrate analysis of experimental data.

3. DEFINITIONS

accuracy: the degree of conformity of an indicated value to an accepted standard value, or true value. The degree of inaccuracy is known as total measurement error and is the sum of bias error and precision error.

bias, fixed, or systematic error: the difference between the true or actual value to be measured and the indicated value from the measuring system that persists and is usually due to the particular instrument or technique of measurement.

confidence level: the probability that a stated interval will include the true value. In analyzing experimental data, a level of 95% is usually used.

confidence limits (used for multisample data) and uncertainty interval (used for single-sample data): that range of values that can be expected, given a stated probability, to include the true value. For example, a statement that the 95% confidence limit is 5 to 8 means that there is a 95% probability (19 chances out of 20) that the interval between 5 and 8 will contain the true value.

data: information obtained by experimental means, assumed to be in numerical form; recorded values of the variables; readings.

deviation: the difference between a single result and the mean of many results.

error: the difference between the true value of the quantity measured and an observed value. Since the true value is often not known, it is estimated by the mean. The difference between the mean and an observed value is often called its deviation.

experiment: a systematic approach for collecting information on a physical apparatus or system to determine the nature of its operation.

mean: the sum of measurement values divided by the number of measurements. It is considered the best approximation of the true value.

parent population: synonymous with population but emphasizing the relation to a sample.

population: any finite or infinite aggregation of items or individuals (inanimate or animate).

precision: the closeness of agreement among repeated measurements of the same characteristic by the same method under the same conditions.

propagation of uncertainty: the degree to which the uncertainties in the values of the parameters affect the uncertainty in the result.

random error (or precision error): a statistical error that is caused by chance and is not recurring. There are two types of random errors:

- *additive* errors that are independent of the magnitude of the observations
- *multiplicative* errors that are dependent on the magnitude of the observations

repeatability: the closeness of agreement among repeated measurements of the same characteristic under the same conditions by the same instrument.

replication: repetitions of measurements at the same conditions that are taken to estimate the uncertainty in the results.

reproducibility: the closeness of agreement among repeated measurements of the same characteristic under the same conditions by different instruments.

sample: a portion, subset, or limited number of items of a population; a set of values, experimentally obtained, that is representative of the parent population.

standard deviation: the square root of the mean of the squares of the deviations.

uncertainty: a measure of the potential error in a measurement or experimental result that reflects the lack of confidence in the result to a specified level.

uncertainty range (or confidence interval): the band for the error in an estimate at a certain confidence level. The greater the acceptable confidence level (e.g., 95% rather than 50%), the wider the uncertainty range.

variance: the square of the standard deviation.