



GUIDELINE

ASHRAE Guideline 33-2013 (RA 2016)
(Reaffirmation of ASHRAE Guideline 33-2013)

Guideline for Documenting Indoor Airflow and Contaminant Transport Modeling

Approved by ASHRAE on November 30, 2016.

ASHRAE Guidelines are scheduled to be updated on a five-year cycle; the date following the Guideline number is the year of ASHRAE approval. The latest edition of an ASHRAE Guideline may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2016 ASHRAE

ISSN 1049-894X

ASHRAE Guideline Project Committee 33
Cognizant TC: 4.10, Indoor Environmental Modeling
SPLS Liaison: Steven J. Emmerich

William S. Dols, *Chair**
Amy B. Musser, *Vice Chair**
Julian Rimmer, *Secretary**

Jason W. DeGraw*
Josephine Lau*
Chao-Hsin Lin*

Liangzhu Wang*
Matthew Wolski*
Zhiqiang Zhai*

** Denotes members of voting status when the document was approved for publication*

ASHRAE STANDARDS COMMITTEE 2016–2017

Rita M. Harrold, *Chair*
Steven J. Emmerich, *Vice-Chair*
James D. Aswegan
Niels Bidstrup
Donald M. Brundage
Waller S. Clements
Drury B. Crawley
John F. Dunlap,
James W. Earley, Jr.
Keith I. Emerson

Julie M. Ferguson
Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson
Roger L. Hedrick
Rick M. Heiden
Srinivas Katipamula
Arsen K. Melikov
R. Lee Millies, Jr.

Cyrus H. Nasser
David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Jack H. Zarour
William F. Walter, *BOD ExO*
Patricia Graef, *CO*

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This Guideline was developed under the auspices of ASHRAE. ASHRAE Guidelines are developed under a review process, identifying a Guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a Guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by Project Committees appointed specifically for the purpose of writing Guidelines. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) Guidelines are not appealable, and (d) Guidelines are not submitted to ANSI for approval.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Guideline,
- b. participation in the next review of the Guideline,
- c. offering constructive criticism for improving the Guideline, or
- d. permission to reprint portions of the Guideline.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS

ASHRAE Guideline 33-2013 (RA 2016), Documenting Airflow and Contaminant Transport Modeling Studies

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions	2
4 Project Documentation	2
5 Building Description	2
6 Multizone Modeling Documentation	3
7 CFD Modeling Documentation	4
8 Results	5
9 References	6

NOTE

Approved addenda, errata, or interpretations for this guideline can be downloaded free of charge from the ASHRAE Web site at www.ashrae.org/technology.

© 2016 ASHRAE

1791 Tullie Circle NE • Atlanta, GA 30329 • www.ashrae.org • All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

(This foreword is not part of this guideline. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a guideline and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Airflow and contaminant transport modeling studies are performed for a number of reasons using a wide variety of analysis tools and techniques. This poses a challenge to the practitioners as well as those who might depend on the work of said practitioners to develop, execute, present, and interpret such studies. This guideline is meant to provide those who carry out and those who commission such studies with a common ground pertaining to the documentation of these types of studies. This guideline is not meant to provide an all-encompassing and restrictive set of rules but to establish a foundation upon which documentation of such studies can be formed.

This is a reaffirmation of Guideline 33-2013. This guideline was prepared under the auspices of ASHRAE. It may be used in whole or in part by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interest of obtaining uniform guidelines throughout the industry. This version of the reaffirmation has no changes.

1. PURPOSE

This guideline establishes a method and format for documenting inputs, assumptions, methods, and outputs utilized when conducting indoor-airflow and contaminant-transport modeling studies.

2. SCOPE

This guideline applies to the application of airflow and contaminant modeling for analyses of indoor air quality, thermal comfort, energy, and events related to chemical, biological, and radiological agents. This guideline only applies to modeling efforts using multizone network models, computational fluid dynamics (CFD), or combinations of the two.

3. DEFINITIONS

airflow path: a connection between two nodes of a multizone model through which air and contaminants can be transported.

analysis tool: a computer program that implements a multizone and/or computational fluid dynamics model and utilizes numerical techniques to solve the equations imposed by the underlying multizone or CFD model.

building envelope: the elements of a building that separate conditioned spaces from the exterior.

building model: a representation of a building or portion of a building for purposes of analysis with a multizone or CFD analysis tool.

computational fluid dynamics (CFD): quantitative prediction of thermal/fluid physical phenomena in an indoor space by numerically solving coupled, partial differential conservation equations.

contaminant: an airborne gas, particle, or liquid droplet of interest that is represented within an analysis tool.

leakage: airflow through cracks/openings in a building component or assembly.

multizone model: an analysis method whereby a building and its ventilation systems are idealized as a discrete set of air volumes or nodes that are interconnected by a set of airflow paths or links.

sink model: a representation within a building model of a contaminant removal mechanism.

source model: a representation within a building model of a contaminant emission or generation mechanism.

zone: a portion of a multizone building representation that is characterized by a well-defined volume of air.

4. PROJECT DOCUMENTATION

4.1 Project Description. Provide an overview of the project, the type of analysis being performed, and the tools used to perform the analysis. These might include the type of structure (e.g., whole building or section of a building) and its geographic location. Indicate which analysis methods are used (e.g., multizone, CFD, or coupled) and the type of evaluations being performed (e.g., airflow, contaminant transport, or energy consumption).

4.2 Objectives. Provide a statement of the overall objectives of the modeling study. Analysis tools often provide the option of implementing various modeling assumptions that are built into the tool. The objectives of a building simulation study can dictate the type of analysis to perform as well as the subset of modeling assumptions to be employed.

5. BUILDING DESCRIPTION

Provide a description of the building or structure being studied. If the study only pertains to a portion of a structure, then only the portion being studied needs to be addressed.

5.1 Site. Provide descriptions of building location, building shape and orientation, and surrounding terrain, including sketches, site plans, and images. Provide general climatic information, including climate zone, temperature range, and prevailing winds.

5.2 Drawings and Plans. Include references to building plans upon which the building information is based (e.g., drawing numbers and dates). These could include conceptual sketches, floor plans, elevation drawings, HVAC riser diagrams, sequences of operation, etc.

5.3 Layout and Dimensions. Provide a description of the number of floors above and below grade, space usage, layout, and dimensions of representative building floor plans. Provide nominal building volume and envelope surface area distinguished by above grade and below grade as well as roof surface area.