This is a preview of "ASHRAE Guideline 34-...". Click here to purchase the full version from the ANSI store.



ASHRAE Guideline 34-2019

Energy Guideline for Historic Buildings

Approved by ASHRAE on February 11, 2019.

GUIDELINE

ASHRAE[®] Guidelines are scheduled to be updated on a five-year cycle; the date following the Guideline number is the year of ASHRAE approval. The latest edition of an ASHRAE Guideline may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2019 ASHRAE ISSN 1049-894X

ASHRAE Guideline Project Committee 34 Cognizant TC: 9.1, Large Building Air-Conditioning Systems; Co-Cognizant TC: 9.8, Large Building Air-Conditioning Applications SPLS Liaison: Vinod P. Gupta

Sheila J. Hayter*, *Chair* Cecily M. Grzywacz*, *Vice-Chair* David Arnold* Constantinos A. Balaras* Oswaldo D.S. Bueno Susan Collins* Ronald Eligator* Michael C. Henry* Dawen Lu Janice K. Means* William B. Rose* Mariah C. Schwartz James Sultan Amanda Webb

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2018–2019

Donald M. Brundage, *Chair* Wayne H. Stoppelmoor, Jr., *Vice-Chair* Els Baert Charles S. Barnaby Niels Bidstrup Robert B. Burkhead Michael D. Corbat Drury B. Crawley Julie M. Ferguson Michael W. Gallagher Walter T. Grondzik Vinod P. Gupta Susanna S. Hanson Roger L. Hedrick Rick M. Heiden Jonathan Humble Kwang Woo Kim Larry Kouma R. Lee Millies, Jr. Karl L. Peterman Erick A. Phelps David Robin Lawrence J. Schoen Dennis A. Stanke Richard T. Swierczyna Russell C. Tharp Adrienne G. Thomle Craig P. Wray Lawrence C. Markel, *BOD ExO* Michael CA Schwedler, *CO*

Steven C. Ferguson, Senior Manager of Standards

SPECIAL NOTE

This Guideline was developed under the auspices of ASHRAE. ASHRAE Guidelines are developed under a review process, identifying a Guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a Guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by Project Committees appointed specifically for the purpose of writing Guidelines. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) Guidelines are not appealable, and (d) Guidelines are not submitted to ANSI for approval.

The Senior Manager of Standards of ASHRAE should be contacted for

a. interpretation of the contents of this Guideline,

b. participation in the next review of the Guideline,

- c. offering constructive criticism for improving the Guideline, or
- d. permission to reprint portions of the Guideline.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

This is a preview of "ASHRAE Guideline 34-...". Click here to purchase the full version from the ANSI store.

CONTENTS

ASHRAE Guideline 34-2019 Energy Guideline for Historic Buildings

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions and Acronyms	2
4 Background	5
5 Planning Phase	7
6 Building Envelopes	14
7 Environmental Control and Energy Systems	19
8 HVAC System Selection	21
9 Lighting	23
10 References	25
Informative Appendix A: Project Flow Overview	29
Informative Appendix B: Recommended Reading	
Informative Appendix C: Collected Case Studies	31
Informative Appendix D: Building Diagnostics	32
Informative Appendix E: Energy Modeling for Historic Buildings	34

NOTE

Approved addenda, errata, or interpretations for this guideline can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2019 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved. ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Guideline 34 provides comprehensive and detailed descriptions of the processes and procedures for the retrofitting of historic buildings in order to achieve greater measured energy efficiency.

Historic buildings are physical reminders of our heritage for both current and future generations. These unique buildings often create an irreplaceable character in communities through their distinctive designs and materials. Also, their associations with notable events or individuals make them significant reminders of our history. In addition, historic buildings generally have a great amount of embedded energy in their construction materials that is retained when they are adapted to new viable uses. For all of these reasons, historic preservation is becoming more important in various cultures throughout the world.

The members of the project committee that developed this guideline were exceptionally knowledgeable about the particular issues of buildings constructed prior to the advent of airconditioning. Communities throughout the world will find great benefit in the results of the many hours of effort the committee enthusiastically devoted to developing this important document.

Guideline 34 is directed to the entire Project Team and is not intended to address issues that are the responsibility of one discipline or trade. The studies and/or reports suggested in this document should be accounted for in the contract negotiations for the discipline most qualified to deal with that topic.

1. PURPOSE

The purpose of this guideline is to provide sound advice on the practices, processes, and workflows that should be followed when performing energy efficiency and energy conservation improvement projects and programs involving historic buildings, while minimizing disturbance to the historic character, characteristics, and materials (significance, value, and qualities) of the building.

2. SCOPE

2.1 This guideline applies to buildings that are listed as historic buildings or which are eligible to be so listed by applicable law in the jurisdiction where the building is located.

2.2 This guideline applies to projects that are intended to improve the following:

- a. Energy efficiency of operation and maintenance
- b. Efficiency of energy-using building systems and equipment
- c. Energy performance of the building's envelope

2.3 This guideline applies to projects that include the following:

- a. Envelope modifications and upgrades to control heat and moisture transfer and limit air infiltration
- b. Adding new HVAC, service water heating, or lighting systems, or modifying existing systems, to improve energy efficiency while maintaining or improving human comfort and indoor environmental quality

3. DEFINITIONS AND ACRONYMS

3.1 Definitions

acceptable indoor air quality: air in which there are no known contaminants at harmful concentration as determined by cognizant authorities and with which a substantial majority (80% or more) of the people exposed do not express dissatisfaction.

adaptive reuse: the process of reusing a historic site or building for a purpose other than that for which it was originally built or designed. Adaptive reuse is acceptable for a historic building only where it involves minimal impact on significance and minimal change to significant fabric. See also *rehabilitation*.

air conditioning: the process of treating air to meet the requirements of a conditioned space by controlling its temperature, humidity, cleanliness, pressurization, and distribution.

air leakage: see infiltration and exfiltration.

authenticity: a measure of the degree to which the attributes of cultural heritage (including form and design, materials and substance, use and function, traditions and techniques, location and setting, spirit and feeling, and other factors) credibly and accurately bear witness to their significance. See also *integrity*.

Basis of Design (BOD): a document that records the concepts, calculations, decisions, and product selections used to meet the Owner's project requirements and to satisfy applicable regulatory requirements, standards, and guidelines. The document includes both narrative descriptions and lists of individual items that support the design process.

bobeches: cupped ring, often glass, used to catch candle drippings on a chandelier.

building: a structure wholly or partially enclosed within exterior walls, or within exterior and party walls, and a roof, affording shelter to persons, animals, or property.

character: all those visual aspects and physical features that make up the appearance of every historic building and convey the building's sense of time and place.

character defining feature: a prominent or distinctive aspect, quality, or characteristic of a historic property that contributes significantly to its physical character and uniqueness. Character defining features include the overall shape of the building; its materials, craftsmanship, decorative details, interior spaces and features; and the various aspects of its site and environment. Character defining features may also include intangibles such as thermal, daylighting, or acoustical qualities. Also referred to as "character defining element."