



**GUIDELINE**

**ASHRAE Guideline 4-2019**  
(Supersedes ASHRAE Guideline 4-2008)

# **Preparation of Operations and Maintenance Documentation for HVAC&R Systems**

Approved by ASHRAE on January 17, 2019.

ASHRAE® Guidelines are scheduled to be updated on a five-year cycle; the date following the Guideline number is the year of ASHRAE approval. The latest edition of an ASHRAE Guideline may be purchased on the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2019 ASHRAE

ISSN 1049-894X

**ASHRAE Guideline Project Committee 4**  
**Cognizant TC: 7.3, Operation and Maintenance Management**  
**SPLS Liaison (2017–2018): Peter Simmonds**  
**SPLS Liaison (2018–2019): Craig Wray**

Davidge Warfield\*, *Chair*  
Michael F. Bobker\*, *Vice-Chair*  
Tina M. Brueckner\*

John G. Frugard\*  
Alexander H. Heckman\*  
Jared A. Higgins\*

Gerald J. Kettler\*  
Peter Rojeski, Jr.\*  
Thursten D. Simonsen\*

\* Denotes members of voting status when the document was approved for publication

---

**ASHRAE STANDARDS COMMITTEE 2018–2019**

Donald M. Brundage, *Chair*  
Wayne H. Stoppelmoor, Jr., *Vice-Chair*  
Els Baert  
Charles S. Barnaby  
Niels Bidstrup  
Robert B. Burkhead  
Michael D. Corbat  
Drury B. Crawley  
Julie M. Ferguson  
Michael W. Gallagher

Walter T. Grondzik  
Vinod P. Gupta  
Susanna S. Hanson  
Roger L. Hedrick  
Rick M. Heiden  
Jonathan Humble  
Kwang Woo Kim  
Larry Kouma  
R. Lee Millies, Jr.  
Karl L. Peterman

Erick A. Phelps  
David Robin  
Lawrence J. Schoen  
Dennis A. Stanke  
Richard T. Swierczyna  
Russell C. Tharp  
Adrienne G. Thomle  
Craig P. Wray  
Lawrence C. Markel, *BOD ExO*  
Michael CA Schwedler, *CO*

Steven C. Ferguson, *Senior Manager of Standards*

---

**SPECIAL NOTE**

This Guideline was developed under the auspices of ASHRAE. ASHRAE Guidelines are developed under a review process, identifying a Guideline for the design, testing, application, or evaluation of a specific product, concept, or practice. As a Guideline it is not definitive but encompasses areas where there may be a variety of approaches, none of which must be precisely correct. ASHRAE Guidelines are written to assist professionals in the area of concern and expertise of ASHRAE's Technical Committees and Task Groups.

ASHRAE Guidelines are prepared by Project Committees appointed specifically for the purpose of writing Guidelines. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Guideline.

Development of ASHRAE Guidelines follows procedures similar to those for ASHRAE Standards except that (a) committee balance is desired but not required, (b) an effort is made to achieve consensus but consensus is not required, (c) Guidelines are not appealable, and (d) Guidelines are not submitted to ANSI for approval.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Guideline,
- b. participation in the next review of the Guideline,
- c. offering constructive criticism for improving the Guideline, or
- d. permission to reprint portions of the Guideline.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

## CONTENTS

### ASHRAE Guideline 4-2019

#### Preparation of Operations and Maintenance Documentation for HVAC&R Systems

SECTION	PAGE
Foreword .....	2
1 Purpose.....	2
2 Scope.....	2
3 Definitions .....	2
4 Implementation.....	3
5 O&M Documentation Library.....	5
6 References.....	8
Informative Appendix A: Construction Documents.....	9
Informative Appendix B: Operations Manual.....	13
Informative Appendix C: Emergency Procedures Information .....	16
Informative Appendix D: Maintenance Manual.....	18
Informative Appendix E: HVAC Maintenance and Test Reports .....	22

#### NOTE

Approved addenda, errata, or interpretations for this guideline can be downloaded free of charge from the ASHRAE website at [www.ashrae.org/technology](http://www.ashrae.org/technology).

© 2019 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · [www.ashrae.org](http://www.ashrae.org) · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

**(This foreword is not part of this guideline. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*This is a revision of ASHRAE Guideline 4-2008. This guideline was prepared under the auspices of ASHRAE. It may be used, in whole or in part, by an association or government agency with due credit to ASHRAE. Adherence is strictly on a voluntary basis and merely in the interests of obtaining uniform guidelines throughout the industry.*

## 1. PURPOSE

To guide those responsible for the design, manufacturing, construction, commissioning, and operation of building HVAC&R and on-site generation systems in the preparation and delivery of operations and maintenance (O&M) documentation that

- a. is simple to prepare and update,
- b. is delivered on time,
- c. is easy to use, and
- d. provides accurate and relevant information.

## 2. SCOPE

This guideline covers the format, content, delivery, and updating of building HVAC&R systems operations and maintenance (O&M) documentation that is normally provided by the Design Team and Construction Team members.

This guideline can be used for two separate purposes. First, it can be used in the construction of new buildings that are not commissioned buildings. Second, it can be used as a guide for existing building documentation as a guideline for O&M documentation.

## 3. DEFINITIONS

Many of the terms used in this guideline and recommended for use in the O&M documents are defined in *ASHRAE Terminology of Heating, Ventilating, Air Conditioning, & Refrigeration*<sup>1</sup>. Others are defined in ASHRAE Guideline 0, *The Commissioning Process*<sup>2</sup>; ASHRAE Guideline 1.1, *HVAC&R Technical Requirements for The Commissioning Process*<sup>3</sup>; and ASHRAE Guideline 1.4, *Procedures for Preparing Facility Systems Manuals*<sup>4</sup>. Additional terms are defined as follows.

**Basis of Design (BoD):** a document that records the concepts, calculations, decisions, and product selections used to meet the Owner's Project Requirements (OPR) and to satisfy the applicable regulatory requirements, standards, and guidelines. The document includes both narrative descriptions and lists of individual items that support the design process.

**building project:** a task with the objective of delivering a base building or a building shell that must be fitted out before it is suitable for occupancy.

**Commissioning Provider (CxP):** an entity identified by the Owner who leads, plans, schedules, and coordinates the CxP Team to implement the Commissioning Process (Cx).

**Current Facility Requirements (CFR):** a written document in which the Owner details the current functional requirements of a facility and the expectations for how it should be used and operated. This includes goals, measurable performance criteria, cost considerations, benchmarks, success criteria, and supporting information to meet the requirements of occupants, users, and Owners of the facility.

**design authority:** a prime consultant, usually an architect, responsible for the quality of the design that is proposed to meet the Owner's requirements.

**design intent:** see *Basis of Design*.

**designer:** a member of the project team involved in providing design solutions to meet the Owner's requirements and in preparing construction and O&M documents during the conceptual design, the completion of construction documents (the design), the construction, and the operational stages of the project delivery.

**electronic documentation:** as used in this guideline, a compilation of electronic files relevant to all components and systems of a project. The documentation adheres to the content requirements described by this guideline and has an overall structure and search capabilities that allow navigation, access, and search of all files contained through networked, stand-alone, and/or portable devices.

**fit-out project:** a project through which furnishings, including partitions, furniture, and tenant equipment (e.g., copy machines, fax machines, personal computers) are delivered.

**O&M designer:** a designer specializing in the O&M aspects of a project.

**O&M documentation:** a comprehensive set of documents providing information pertaining to a specific facility, new construction, or renovation, including information regarding the design, operation, and maintenance of the facility.

**Owner:** the person or legal entity that will own the delivered facility or an agent representing the Owner. The Owner defines the project requirements.

**Owner's Project Requirements (OPR):** a written document that details the functional requirements of a project and the expectations for how it will be used and operated. This includes project goals, measurable performance criteria, cost considerations, benchmarks, success criteria, and supporting information. The term "Project Intent" is also used as a substitute by some Owners.

**Preliminary Operating Manual:** an elaboration of the design intent that includes operating information developed during the construction documents (design) stage.

**project brief:** see *Owner's Project Requirements*.

**project delivery stages:** the progressive stages in the development of a project marking the delivery of a distinct product: planning, conceptual design, construction document preparation, construction, operation, and evaluation.