

ASME FE.1-2018
Draft Standard for Trial Use

Rules for Construction of Fusion Energy Devices

This is a Draft Standard for Trial Use and Comment. This Draft Standard is not an approved consensus standard of ASME nor is it an American National Standard. ASME has approved its issuance and publication as a Draft Standard only. Distribution of this Draft Standard for comment shall not continue beyond 3 years from the date of issuance. The content of this Draft Standard for Trial Use and Comment was not approved through ASME's consensus process. Following the 3-year trial and comment period, this Draft Standard, along with comments received, will be submitted to a Consensus Committee or Project Team. The Consensus Committee or Project Team will review and revise this Draft Standard based, in part, upon experience during the trial term and resulting comments. A public review in accordance with established American National Standards Institute (ANSI) procedures is required at the end of the Trial-Use Period and before a Draft Standard for Trial Use is submitted to ANSI for approval as an American National Standard. Thereafter, it is expected that this Draft Standard (including any revisions thereto) will be submitted to ANSI for approval as an American National Standard. Suggestions for revision should be directed to the Chair, Subgroup on Fusion Energy Devices, using the following form: <http://go.asme.org/FE1CommentForm>.



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: November 30, 2018

This Draft Standard for Trial Use will be revised following the conclusion of the Trial-Use Period. There will be no written interpretations of the requirements of this Draft Standard for Trial Use issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

The Standards Committee that approved the Draft Standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a (draft) standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or (draft) standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this draft standard.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2018 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword		v
Committee Roster		vi
Subsection FA	Fusion Energy Device Facilities	1
Subpart FAA	General Requirements	2
Article FAA-1000	Introduction	2
FAA-1100	General	2
FAA-1110	Scope	2
FAA-1120	Definitions	2
FAA-1130	Limits of These Rules	2
FAA-1300	Fusion Technologies	2
Article FAA-2000	Classification of Components and Supports	6
FAA-2100	General Requirements	6
FAA-2120	Purpose of Classifying Items in a Fusion Power Plant	6
FAA-2130	Classifications and Rules of ASME FE.1	6
Article FAA-7000	Reference Standards	7
FAA-7100	General Requirements	7
Article FAA-8000	Certificates, Nameplates, Certification Mark, and Data Reports	8
FAA-8100	Authorization to Perform ASME BPVC Activities	8
Article FAA-9000	Glossary	9
FAA-9100	Introduction	9
FAA-9200	Definitions	9
Subpart FAB	Magnetic Confinement	10
Article FAB-1000	Introduction	10
FAB-1100	Scope	10
FAB-1200	Magnetic Confinement	10
FAB-1210	Magnet System	10
FAB-1220	Magnet Structures	12
FAB-1300	Vacuum Vessel	12
FAB-1310	Functional Requirements	12
FAB-1320	Vessel Shells	12
FAB-1330	Port Structures	13
FAB-1340	Supports and Mechanical Interfaces	13
FAB-1350	Cooling	13
FAB-1360	Loading Conditions	13
FAB-1400	In-Vessel Components	13
FAB-1410	Divertor	13
FAB-1420	Blanket	13
Subsection FB	Pressure Boundary Components	15

Subpart FBA	Magnet	16
Article FBA-1000	Introduction	16
FBA-1100	Scope	16
FBA-1110	Aspects of Construction Covered by These Rules	16
FBA-1120	Temperature Limits	16
FBA-1130	Boundaries of Jurisdiction Applicable to This Subsection	16
FBA-1140	Electrical and Mechanical Penetration Assemblies	16
Article FBA-2000	Material	17
FBA-2100	General Requirements for Material	17
FBA-2110	Scope of Principal Terms Employed	17
FBA-2120	Pressure-Retaining Material	17
FBA-2130	Certification of Material	18
FBA-2140	Welding Material	18
FBA-2150	Material Identification	18
FBA-2160	Deterioration of Material in Service	18
FBA-2170	Heat Treatment to Enhance Impact Properties	18
FBA-2180	Procedures for Heat Treatment of Material	18
FBA-2190	Non-Pressure-Retaining Material	19
FBA-2200	Material Test Coupons and Specimens for Ferritic Steel Material	19
FBA-2210	Procedure for Obtaining Test Coupons and Specimens for Quenched and Tempered Material	19
FBA-2300	Welding Material	19
FBA-2310	General Requirements	19
FBA-2400	Dimensional Standards	19
Article FBA-3000	Design	20
FBA-3100	General Design	20
FBA-3110	Loading Criteria	20
FBA-3200	Design by Analysis	20
 Nonmandatory Appendix		
A	Topics in Development	21
 Figures		
FAA-1300-1	A Typical Light Water Fission System	3
FAA-1300-2	A Theoretical Magnetic Confinement-Based Fusion System	5
FAB-1210-1	Example of a Magnet Confinement System in an ITER Machine	11
 Table		
FAA-7100-1	Standards Referenced in ASME FE.1 Associated With Fusion Components	7

FOREWORD

There is an ongoing effort within The American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (BPV) Committee on Construction of Nuclear Facility Components (Section III) to develop rules for the construction of fusion energy devices. The Standards Committee of Section III, Division 4 and its Subgroup on Fusion Energy Devices (FED) are developing these new fusion Code rules. These rules cover fusion-energy-related components such as vacuum vessels, cryostats, and superconducting magnet structures and the interactions of these components. Related support structures, including metallic and nonmetallic materials, containment or confinement structures, and in-vessel components such as fusion-system piping, vessels, valves, pumps, and supports, are also covered. The rules contain requirements for materials, design, fabrication, testing, examination, inspection, certification, and stamping.

ASME BOILER AND PRESSURE VESSEL COMMITTEE ON CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS (BPV III)

(The following is the roster of the Committee at the time of approval of this Draft Standard.)

STANDARDS COMMITTEE OFFICERS

R. Hill III, *Chair*
R. Keating, *Vice Chair*
J. Minichiello, *Vice Chair*
A. Byk, *Staff Secretary*

STANDARDS COMMITTEE PERSONNEL

T. Adams , Jensen Hughes	J. Minichiello , Bechtel National, Inc.
A. Appleton , Alloy Stainless Products Co., Inc.	M. Mitchell , USNC
R. Barnes , Anric Enterprises, Inc.	M. Morishita , Japan Atomic Energy Agency
W. Borter , Consultant	D. K. Morton , Consultant
C. Bruny , Consultant	T. Nagata , Hitachi-GE Nuclear Energy Ltd.
T. Burchell , Oak Ridge National Laboratory	J. Nestell , MPR Associates
A. Byk , The American Society of Mechanical Engineers	E. L. Pleins , Westinghouse Electric Co.
P. Deubler , Becht Engineering Co., Inc.	R. Reedy, Sr. , Reedy Engineering, Inc.
P. Donavin , DTE Energy, Fermi Nuclear Power Station	I. Saito , Japan Nuclear Safety Institute
A. Eberhardt , Sargent & Lundy, LLC	S. Sham , Argonne National Laboratory
R. Hill III , Hill Engineering Solutions	W. Sowder, Jr. , Quality Management Services Co., LLC
S. Hunter , Framatome, Inc.	W. Sperko , Sperko Engineering Services, Inc.
R. Jessee , Babcock & Wilcox	J. Tucker , Flowserve
B. Jetter , Consultant	C. Withers , National Board of Boiler and Pressure Vessel Inspectors
R. Keating , MPR Associates, Inc.	H.-T. Wang , <i>Delegate</i> , Tsinghua University Institute of Nuclear and New Energy Technology
C. Kim , Westinghouse Electric Co.	C. Smith , <i>Contributing Member</i> , Smith Associates Consulting Group, LLC
G. H. Koo , Korea Atomic Energy Research Institute	M. Zhou , <i>Contributing Member</i> , China Nuclear Power Design Co. Ltd.
M. Lockwood , Hartford Steam Boiler	
K. Manoly , U.S. Nuclear Regulatory Commission	
D. Matthews , Framatome, Inc.	

SUBGROUP ON FUSION ENERGY DEVICES (BPV III-4)

W. Sowder, Jr. , <i>Chair</i> , Quality Management Services Co., LLC	X. Li , Institute for Standardization of Nuclear Industry
D. Roszman , <i>Secretary</i> , Hayward Tyler, Inc.	P. Mokaria , ITER-India
M. Bashir , Culham Centre for Fusion Energy	T. R. Muldoon , American Exchanger Services, Inc.
L. C. Cadwallader , Battelle Energy Alliance, LLC	M. Porton , Culham Centre for Fusion Energy
B. R. Doshi , Institute for Plasma Research	F. Schaaf, Jr. , Sterling Refrigeration Corp.
G. Holtmeier , Lawrence Livermore National Laboratory	P. Smith , Consultant
K. Kavanagh , U.S. Nuclear Regulatory Commission	Y. Song , Institute of Plasma Physics, Chinese Academy of Sciences
K. Kim , National Fusion Research Institute	M. Trosen , Major Tool & Machine, Inc.
I. Kimihiro , Toyama Co. Ltd.	C. Waldon , UK Atomic Energy Authority
S. Lee , National Fusion Research Institute	I. Zatz , Princeton University Plasma Physics Laboratory
G. Li , Institute for Standardization of Nuclear Industry	R. Barnes , <i>Contributing Member</i> , Anric Enterprises, Inc.

WORKING GROUP ON GENERAL REQUIREMENTS (BPV III-4)

D. Roszman , <i>Chair</i> , Hayward Tyler, Inc.	W. Sowder, Jr. , Quality Management Services Co., LLC
--	--

WORKING GROUP ON IN-VESSEL COMPONENTS (BPV III-4)

M. Bashir, *Chair*, Culham Centre for Fusion Energy
Y. Carin, Fusion for Energy

M. Kalsey, UK Atomic Energy Authority

WORKING GROUP ON MAGNETS (BPV III-4)

S. Lee, *Chair*, National Fusion Research Institute

K. Kim, *Vice Chair*, National Fusion Research Institute

WORKING GROUP ON MATERIALS (BPV III-4)

M. Porton, *Chair*, Culham Centre for Fusion Energy

P. Mummery, University of Manchester School of Mechanical Engineering

WORKING GROUP ON VACUUM VESSELS (BPV III-4)

I. Kimihiro, *Chair*, Toyama Co. Ltd.

L. C. Cadwallader, Battelle Energy Alliance, LLC

B. R. Doshi, Institute for Plasma Research

Q. Shijun, Institute of Plasma Physics, Chinese Academy of Sciences

Y. Song, Institute of Plasma Physics, Chinese Academy of Sciences

INTENTIONALLY LEFT BLANK

SUBSECTION FA

FUSION ENERGY DEVICE FACILITIES

SUBPART FAA GENERAL REQUIREMENTS

ARTICLE FAA-1000 INTRODUCTION

FAA-1100 GENERAL

FAA-1110 Scope

The rules of [Subsection FA, Subpart FAA](#) constitute the general requirements associated with fusion components used in the construction of fusion devices and their supporting systems. Only those fusion components that are serving a pressure boundary and/or structural integrity function (see [FAA-2120](#)) are covered by these rules. Items that are specifically excluded are electrical components and superconducting strand. It is understood that these rules were developed to document rules for construction that are not adequately addressed within existing Divisions of Section III of the ASME Boiler and Pressure Vessel Code (BPVC) or other existing codes and standards used in the nuclear industry.

(a) The General Requirements of ASME FE.1 are provided in ASME BPVC, Section III, Subsection NCA, except for those paragraphs or subparagraphs (with numbered headers) replaced by corresponding numbered FAA paragraphs or subparagraphs or new numbered FAA paragraphs or subparagraphs.

(b) ASME BPVC, Section III, Division 1 terminology may differ from that in ASME FE.1 (e.g., Class 1 and Class 2 versus Class A and Class B), but the application and use of these rules are identical for ASME FE.1 construction except where otherwise noted.

(c) References to Appendices are to each respective Subsection of this Draft Standard, unless otherwise stated.

FAA-1120 Definitions

Definitions of key terms specific to this Draft Standard are included in [Article FAA-9000](#) or noted within the applicable text. The definitions in [Article FAA-9000](#) shall prevail should a conflict exist with definitions found in ASME BPVC, Section III, Subsection NCA or in other documents referenced in this Draft Standard. Unless a term is defined in [Article FAA-9000](#), the definition in ASME BPVC, Section III, Subsection NCA, Article NCA-9000 shall apply.

FAA-1130 Limits of These Rules

The rules of this Draft Standard for fusion components provide requirements for new construction and include consideration of mechanical and thermal stresses due to cyclic operation and high-temperature creep. These rules address the thermal and radiation effects on materials produced during the fusion activity. The rules do not cover deterioration that may occur in service as a result of corrosion, erosion, thermal embrittlement, or instability of material. These effects shall be taken into account with a view to realizing the design or the specified life of the components and support identified.

The rules are not intended to be applicable to valve operators, controllers, position indicators, pump impellers, pump drivers, or other accessories and devices, unless they are pressure-retaining parts or act as support structures or supports. If such items are in a support load path, the provisions of [FAA-1100](#) apply.

The rules of this Draft Standard do not apply to instruments, or permanently sealed fluid-filled tubing systems furnished with instruments, but they do apply to instrument, control, and sampling piping when specified in a Design Specification.

FAA-1300 FUSION TECHNOLOGIES

[Subsection FA](#) provides the rules for construction of nuclear fusion devices and their supporting systems. Nuclear fusion and nuclear fission are two different types of energy-releasing reactions in which energy is released from high-powered atomic bonds between the particles within a nucleus. The main difference between these two processes is that fission is the splitting of an atom into two or more smaller ones, whereas fusion is the fusing of two or more smaller atoms into a larger one.

Nuclear fission is a technology that has been in use since the 1950s. [Figure FAA-1300-1](#) illustrates a typical light water fission system. There is potential for new developments in nuclear energy technology to enhance nuclear energy's role in a sustainable-energy future.