

ASME OM-2015
(Revision of ASME OM-2012)

Operation and Maintenance of Nuclear Power Plants

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers

ASME OM-2015
(Revision of ASME OM-2012)

Operation and Maintenance of Nuclear Power Plants

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: September 30, 2015

The next edition of this Code is scheduled for publication in 2017.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Code. Interpretations are published on the Committee Web page and under go.asme.org/InterpsDatabase. Periodically certain actions of the ASME OM Committee may be published as Cases. Cases are published on the ASME Web site under the OM Committee Page at go.asme.org/OMcommittee as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2015 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

(A Detailed Contents Precedes Each Division)

Foreword	iv
Preparation of Technical Inquiries	v
Committee Roster	vii
Preface	ix
Summary of Changes	xi
Division 1 OM Code: Section IST	1
Division 2 OM Standards	105
Division 3 OM Guides	309

DIVISION 1: OM CODE: SECTION IST

CONTENTS

SUBSECTION ISTA	GENERAL REQUIREMENTS	6
ISTA-1000	Introduction	6
ISTA-1100	Scope	6
ISTA-1200	Jurisdiction	6
ISTA-1300	Application	6
ISTA-1400	Referenced Standards and Specifications	6
ISTA-1500	Owner's Responsibilities	6
ISTA-1600	Accessibility	6
ISTA-2000	Definitions	7
ISTA-3000	General Requirements	8
ISTA-3100	Test and Examination Program	8
ISTA-3200	Administrative Requirements	8
ISTA-3300	Corrective Actions	9
ISTA-4000	Instrumentation and Test Equipment	9
ISTA-4100	Range and Accuracy	9
ISTA-4200	Calibration	9
ISTA-5000	To Be Provided at a Later Date	9
ISTA-6000	To Be Provided at a Later Date	9
ISTA-7000	To Be Provided at a Later Date	9
ISTA-8000	To Be Provided at a Later Date	9
ISTA-9000	Records and Reports	9
ISTA-9100	Scope	9
ISTA-9200	Requirements	9
ISTA-9300	Retention	10
Table		
ISTA-1400-1	Referenced Standards and Specifications	7
SUBSECTION ISTB	INSERVICE TESTING OF PUMPS IN LIGHT-WATER REACTOR NUCLEAR POWER PLANTS — PRE-2000 PLANTS	11
ISTB-1000	Introduction	11
ISTB-1100	Applicability	11
ISTB-1200	Exclusions	11
ISTB-1300	Pump Categories	11
ISTB-1400	Owner's Responsibility	11
ISTB-2000	Supplemental Definitions	11
ISTB-3000	General Testing Requirements	11
ISTB-3100	Preservice Testing	11
ISTB-3200	Inservice Testing	12
ISTB-3300	Reference Values	12
ISTB-3400	Frequency of Inservice Tests	13
ISTB-3500	Data Collection	13
ISTB-4000	To Be Provided at a Later Date	14

ISTB-5000	Specific Testing Requirements	14
ISTB-5100	Centrifugal Pumps (Except Vertical Line Shaft Centrifugal Pumps)	14
ISTB-5200	Vertical Line Shaft Centrifugal Pumps	16
ISTB-5300	Positive Displacement Pumps	18
ISTB-6000	Monitoring, Analysis, and Evaluation	20
ISTB-6100	Trending	20
ISTB-6200	Corrective Action	20
ISTB-6300	Systematic Error	21
ISTB-6400	Analysis of Related Conditions	21
ISTB-7000	To Be Provided at a Later Date	21
ISTB-8000	To Be Provided at a Later Date	21
ISTB-9000	Records and Reports	21
ISTB-9100	Pump Records	21
ISTB-9200	Test Plans	21
ISTB-9300	Record of Tests	21
ISTB-9400	Record of Corrective Action	21
Figure		
ISTB-5223-1	Vibration Limits	18
Tables		
ISTB-3000-1	Inservice Test Parameters	12
ISTB-3400-1	Inservice Test Frequency	13
ISTB-3510-1	Required Instrument Accuracy	13
ISTB-5121-1	Centrifugal Pump Test Acceptance Criteria	15
ISTB-5221-1	Vertical Line Shaft Centrifugal Pump Test Acceptance Criteria	17
ISTB-5321-1	Positive Displacement Pump (Except Reciprocating) Test Acceptance Criteria	19
ISTB-5321-2	Reciprocating Positive Displacement Pump Test Acceptance Criteria	20
SUBSECTION ISTC	INSERVICE TESTING OF VALVES IN LIGHT-WATER REACTOR NUCLEAR POWER PLANTS	22
ISTC-1000	Introduction	22
ISTC-1100	Applicability	22
ISTC-1200	Exemptions	22
ISTC-1300	Valve Categories	22
ISTC-1400	Owner's Responsibility	22
ISTC-2000	Supplemental Definitions	22
ISTC-3000	General Testing Requirements	23
ISTC-3100	Preservice Testing	23
ISTC-3200	Inservice Testing	23
ISTC-3300	Reference Values	23
ISTC-3400	To Be Provided at a Later Date	23
ISTC-3500	Valve Testing Requirements	23
ISTC-3600	Leak Testing Requirements	25
ISTC-3700	Position Verification Testing	26
ISTC-3800	Instrumentation	26
ISTC-4000	To Be Provided at a Later Date	26
ISTC-5000	Specific Testing Requirements	26
ISTC-5100	Power-Operated Valves (POVs)	26
ISTC-5200	Other Valves	29
ISTC-6000	Monitoring, Analysis, and Evaluation	31

ISTC-7000	To Be Provided at a Later Date	31
ISTC-8000	To Be Provided at a Later Date	31
ISTC-9000	Records and Reports	31
ISTC-9100	Records	31
ISTC-9200	Test Plans	31
Table		
ISTC-3500-1	Inservice Test Requirements	24
SUBSECTION ISTD	PRESERVICE AND INSERVICE EXAMINATION AND TESTING OF DYNAMIC RESTRAINTS (SNUBBERS) IN LIGHT-WATER REACTOR NUCLEAR POWER PLANTS	33
ISTD-1000	Introduction	33
ISTD-1100	Applicability	33
ISTD-1400	Owner's Responsibility	33
ISTD-1500	Snubber Maintenance or Repair	33
ISTD-1600	Snubber Modification and Replacement	33
ISTD-1700	Deletions of Unacceptable Snubbers	33
ISTD-1800	Supported Component(s) or System Evaluation	34
ISTD-2000	Definitions	34
ISTD-3000	General Requirements	34
ISTD-3100	General Examination Requirements	34
ISTD-3200	General Testing Requirements	35
ISTD-3300	General Service-Life Monitoring Requirements	35
ISTD-4000	Specific Examination Requirements	35
ISTD-4100	Preservice Examination	35
ISTD-4200	Inservice Examination	36
ISTD-5000	Specific Testing Requirements	37
ISTD-5100	Preservice Operational Readiness Testing	37
ISTD-5200	Inservice Operational Readiness Testing	38
ISTD-5300	The 10% Testing Sample	39
ISTD-5400	The 37 Testing Sample Plan	40
ISTD-5500	Retests of Previously Unacceptable Snubbers	41
ISTD-6000	Service Life Monitoring	41
ISTD-6100	Predicted Service Life	41
ISTD-6200	Service Life Evaluation	41
ISTD-6300	Cause Determination	42
ISTD-6400	Additional Monitoring Requirements for Snubbers That Are Tested Without Applying a Load to the Snubber Piston Rod	42
ISTD-6500	Testing for Service Life Monitoring Purposes	42
ISTD-7000	To Be Provided at a Later Date	42
ISTD-8000	To Be Provided at a Later Date	42
ISTD-9000	Records and Reports	42
ISTD-9100	Snubber Records	42
ISTD-9200	Test Plans	42
ISTD-9300	Record of Tests	42
ISTD-9400	Record of Corrective Action	42
Figure		
ISTD-5431-1	The 37 Testing Sample Plan	41

Table		
ISTD-4252-1	Visual Examination Table	37
SUBSECTION ISTE	RISK-INFORMED INSERVICE TESTING OF COMPONENTS IN LIGHT-WATER REACTOR NUCLEAR POWER PLANTS	43
ISTE-1000	Introduction	43
ISTE-1100	Applicability	43
ISTE-1200	Alternative	43
ISTE-1300	General	43
ISTE-2000	Supplemental Definitions	43
ISTE-3000	General Requirements	44
ISTE-3100	Implementation	44
ISTE-3200	Probabilistic Risk Assessment	44
ISTE-3300	Integrated Decision Making	44
ISTE-3400	Evaluation of Aggregate Risk	45
ISTE-3500	Feedback and Corrective Actions	45
ISTE-4000	Specific Component Categorization Requirements	45
ISTE-4100	Component Risk Categorization	45
ISTE-4200	Component Safety Categorization	46
ISTE-4300	Testing Strategy Formulation	47
ISTE-4400	Evaluation of Aggregate Risk	47
ISTE-4500	Inservice Testing Program	48
ISTE-5000	Specific Testing Requirements	48
ISTE-5100	Pumps	48
ISTE-5200	Check Valves	49
ISTE-5300	Motor-Operated Valve Assemblies	49
ISTE-5400	Pneumatically Operated Valves	49
ISTE-5500	To Be Provided at a Later Date	50
ISTE-6000	Monitoring, Analysis, and Evaluation	50
ISTE-6100	Performance Monitoring	50
ISTE-6200	Feedback and Corrective Actions	50
ISTE-7000	To Be Provided at a Later Date	50
ISTE-8000	To Be Provided at a Later Date	50
ISTE-9000	Records and Reports	50
ISTE-9100	Plant Expert Panel Records	50
ISTE-9200	Component Records	50
Table		
ISTE-5121-1	LSSC Pump Testing	48
SUBSECTION ISTF	INSERVICE TESTING OF PUMPS IN LIGHT-WATER REACTOR NUCLEAR POWER PLANTS – POST-2000 PLANTS	51
ISTF-1000	Introduction	51
ISTF-1100	Applicability	51
ISTF-1200	Exclusions	51
ISTF-1300	Owner’s Responsibility	51
ISTF-2000	Supplemental Definitions	51
ISTF-3000	General Testing Requirements	51
ISTF-3100	Preservice Testing	51
ISTF-3200	Inservice Testing	51
ISTF-3300	Reference Values	51
ISTF-3400	Frequency of Inservice Tests	52
ISTF-3500	Data Collection	52

ISTF-4000	To Be Provided at a Later Date	53
ISTF-5000	Specific Testing Requirements	53
ISTF-5100	Centrifugal Pumps (Except Vertical Line Shaft Centrifugal Pumps)	53
ISTF-5200	Vertical Line Shaft Centrifugal Pumps	54
ISTF-5300	Positive Displacement Pumps	55
ISTF-6000	Monitoring, Analysis, and Evaluation	56
ISTF-6100	Trending	56
ISTF-6200	Corrective Action	56
ISTF-6300	Systematic Error	56
ISTF-6400	Analysis of Related Conditions	57
ISTF-7000	To Be Provided at a Later Date	57
ISTF-8000	To Be Provided at a Later Date	57
ISTF-9000	Records and Reports	57
ISTF-9100	Pump Records	57
ISTF-9200	Test Plans	57
ISTF-9300	Record of Tests	57
ISTF-9400	Record of Corrective Action	57
Tables		
ISTF-3000-1	Inservice Test Parameters	52
ISTF-3510-1	Required Instrument Accuracy	53
ISTF-5120-1	Centrifugal Pump Test Acceptance Criteria	54
ISTF-5220-1	Vertical Line Shaft and Centrifugal Pump Test Acceptance Criteria	55
ISTF-5320-1	Positive Displacement Pump (Except Reciprocating) Test Acceptance Criteria	56
ISTF-5320-2	Reciprocating Positive Displacement Pump Test Acceptance Criteria	56
Mandatory Appendices		
I	Inservice Testing of Pressure Relief Devices in Light-Water Reactor Nuclear Power Plants	59
II	Check Valve Condition Monitoring Program	69
III	Preservice and Inservice Testing of Active Electric Motor- Operated Valve Assemblies in Light-Water Reactor Power Plants	71
IV	To Be Provided at a Later Date	76
V	Pump Periodic Verification Test Program	77
Nonmandatory Appendices		
A	Preparation of Test Plans	78
B	Dynamic Restraint Examination Checklist Items	81
C	Dynamic Restraint Design and Operating Information	82
D	Comparison of Sampling Plans for Inservice Testing of Dynamic Restraints	83
E	Flowcharts for 10% and 37 Snubber Testing Plans	84
F	Dynamic Restraints (Snubbers) Service Life Monitoring Methods	87
G	Application of Table ISTD-4252-1, Snubber Visual Examination	89
H	Test Parameters and Methods	91
J	Check Valve Testing Following Valve Reassembly	93
K	Sample List of Component Deterministic Considerations	94
L	Acceptance Guidelines	95
M	Design Guidance for Nuclear Power Plant Systems and Component Testing	98

DIVISION 2: OM STANDARDS

CONTENTS

PART 2	PERFORMANCE TESTING OF CLOSED COOLING WATER SYSTEMS IN LIGHT-WATER REACTOR POWER PLANTS	109
PART 3	VIBRATION TESTING OF PIPING SYSTEMS	110
1	Scope	110
2	Definitions	110
3	General Requirements	111
4	Visual Inspection Method	115
5	Simplified Method for Qualifying Piping Systems	115
6	Rigorous Verification Method for Steady-State and Transient Vibration	120
7	Instrumentation and Vibration Measurement Requirements	121
8	Corrective Action	122
Figures		
1	Typical Components of a Vibration Monitoring System (VMS)	111
2	Deflection Measurement at the Intersection of Pipe and Elbow	116
3	Single Span Deflection Measurement	116
4	Cantilever Span Deflection Measurement	116
5	Cantilever Span/Elbow Span in-Plane Deflection Measurement	116
6	Cantilever Span/Elbow Guided Span in-Plane Deflection Measurement	117
7	Span/Elbow Span Out-of-Plane Deflection Measurement, Span Ratio < 0.5	117
8	Span/Elbow Span Out-of-Plane Deflection Measurement, Span Ratio > 0.5	117
9	Span/Elbow Span Out-of-Plane Configuration Coefficient Versus Ratio of Spans	117
10	Correction Factor C_1	119
Tables		
1	System Tolerances	113
2	Examples of Specifications of VMS Minimum Requirements; Measured Variable — Displacement	122
Nonmandatory Appendices		
A	Instrumentation and Measurement Guidelines	123
B	Analysis Methods	126
C	Test/Analysis Correlation Methods	127
D	Velocity Criterion	128
E	Excitation Mechanisms, Responses, and Corrective Actions	129
F	Flowchart — Outline of Vibration Qualification of Piping Systems	131
G	Qualitative Evaluations	133
H	Guidance for Monitoring Piping Steady-State Vibration Per Vibration Monitoring Group 2	134
I	Acceleration Limits for Small Branch Piping	139

PART 12	LOOSE PART MONITORING IN LIGHT-WATER REACTOR POWER PLANTS	141
1	Introduction	141
2	Definitions	141
3	References	142
4	Equipment	143
5	Program Elements	153
6	Documentation	157
Figures		
1	Typical Broadband Sensor Response to Nearby Impact	144
2	Typical Broadband Sensor Response to More Distant Impact	144
3	Range of Loose Part Signal Amplitude and Predominant Frequency Content	145
4	Field Equipment	145
5	Direct Stud Mount	146
6	Clamped Mount	146
7	Recommended Sensor Array for PWR With U-Tube Steam Generator	148
8	Recommended Sensor Array for PWR With Once-Through Steam Generator	149
9	Recommended Sensor Array for BWR	150
10	Block Diagram for Charge Converter Calibration Tests	154
11	Cable Properties (Typical for Twisted-Shielded Pair Cable)	155
Tables		
1	Recommended PWR Accelerometer Locations	147
2	Recommended BWR Accelerometer Locations	149
Nonmandatory Appendix		
A	References	158
PART 16	PERFORMANCE TESTING AND MONITORING OF STANDBY DIESEL GENERATOR SYSTEMS IN LIGHT-WATER REACTOR POWER PLANTS	159
1	Introduction	159
2	Nonoperating Checks	162
3	Testing	162
4	Inservice Monitoring of Component Operating and Standby Conditions	166
5	Other Condition Monitoring Methods/Guidelines	168
6	Alarm and Shutdown During Tests	170
7	Diesel Generator Operating Data and Records	171
Figure		
1	Boundary and Support Systems of Emergency Diesel Generator Systems	160
Table		
1	Periodic Tests	164
Nonmandatory Appendices		
A	Post-Major Maintenance Test Data	172
B	Functional/Inservice Test Data	173
C	Data Trending Examples	174
PART 21	INSERVICE PERFORMANCE TESTING OF HEAT EXCHANGERS IN LIGHT- WATER REACTOR POWER PLANTS	180
1	Introduction	180

2	Definitions	180
3	References	182
4	Selection and Prioritization of Heat Exchangers	182
5	Basic Requirements	183
6	Selection of Methods	184
7	Testing and Monitoring Conditions	191
8	Errors, Sensitivities, and Uncertainties	192
9	Acceptance Criteria	194
10	Corrective Action	195
11	Records and Record Keeping	195
Figures		
1	Intervals, Limits, and Parameter Trending (Typical)	185
2	Method Selection Chart	186
Nonmandatory Appendices		
A	Diagnostics	197
B	Precautions	200
C	Examples	203
PART 24	REACTOR COOLANT AND RECIRCULATION PUMP CONDITION MONITORING	234
1	Introduction	234
2	Definitions	234
3	References	236
4	Machine Faults	236
5	Vibration, Axial Position, and Bearing Temperature Monitoring Equipment	236
6	Vibration Data Analysis System Requirements	239
7	Seal Monitoring	241
8	Vibration, Axial Position, and Bearing Temperature Monitoring	242
9	Alarm Settings	244
10	Analysis and Diagnostics	245
11	Additional Technologies	246
12	Other	247
Tables		
1	Pumpset Mechanical Faults	237
2	Seal Faults	237
3	Electrical Motor Faults	238
4	Minimum Monitoring and Recording Intervals	242
5	Typical Thrust Position Alarm Setpoints for a Pump With Normal Upthrust	245
Nonmandatory Appendices		
A	References	248
B	Thermography	249
C	Lube Oil Analysis	250
D	Motor Current Signature Analysis	251
E	Loose Parts Monitoring	252

PART 25	PERFORMANCE TESTING OF EMERGENCY CORE COOLING SYSTEMS IN LIGHT-WATER REACTOR POWER PLANTS	253
PART 26	DETERMINATION OF REACTOR COOLANT TEMPERATURE FROM DIVERSE MEASUREMENTS	254
1	Introduction	254
2	Definitions	254
3	References	255
4	Requirements	255
5	Develop Test Procedures and Perform Testing	255
6	Documentation	257
Nonmandatory Appendix		
A	Measurement Equipment Uncertainties	258
PART 28	STANDARD FOR PERFORMANCE TESTING OF SYSTEMS IN LIGHT-WATER REACTOR POWER PLANTS	259
1	Introduction	259
2	Definitions	259
3	References	260
4	General Testing Requirements	260
5	Specific Testing Requirements	265
6	Evaluate Test Data	265
7	Documentation	265
Mandatory Appendices		
I	Specific Testing Requirements of Emergency Core Cooling Systems in BWR Power Plants	267
II	Specific Testing Requirements of Emergency Core Cooling Systems in PWR Power Plants	271
III	Specific Testing Requirements of Auxiliary or Emergency Feedwater Systems in LWR Power Plants	274
IV	Specific Testing Requirements of Closed Cooling Water Systems in LWR Power Plants	276
V	Specific Testing Requirements of Emergency Service Water Systems in LWR Power Plants (Open Cooling Water Systems)	280
VI	Specific Testing Requirements of Instrument Air Systems in LWR Power Plants	283
Nonmandatory Appendices		
A	Industry Guidance	288
B	Guidance for Testing Certain System Characteristics	292
C	Measurement Accuracy of System Characteristics	298
PART 29	ALTERNATIVE TREATMENT REQUIREMENTS FOR RISC-3 PUMPS AND VALVES	305
1	Introduction	305
2	Definitions	305
3	General Programmatic Requirements for RISC-3 Pumps and Valves	305
4	Alternative Treatment for Reasonable Confidence of RISC-3 Pump and Valve Performance	306
5	Corrective Action	306
6	Feedback and Treatment Adjustment	307
7	Records	307

DIVISION 3: OM GUIDES

CONTENTS

PART 5	INSERVICE MONITORING OF CORE SUPPORT BARREL AXIAL PRELOAD IN PRESSURIZED WATER REACTOR POWER PLANTS	312
1	Purpose and Scope	312
2	Background	312
3	Program Description	314
4	Baseline Phase	314
5	Surveillance Phase	316
6	Diagnostic Phase	316
Figure		
1	Reactor Arrangement Showing Typical Ex-Core Detector Locations	313
Table		
1	Summary of Program Phases	315
Nonmandatory Appendices		
A	Theoretical Basis	318
B	Data Reduction Techniques	320
C	Data Acquisition and Reduction	322
D	Data Evaluation	325
E	Guidelines for Evaluating Baseline Signal Deviations	329
F	Correlation of rms Amplitude of the Ex-Core Signal (Percent Noise) and Amplitude of Core Barrel Motion	334
G	Bibliography	335
PART 7	REQUIREMENTS FOR THERMAL EXPANSION TESTING OF NUCLEAR POWER PLANT PIPING SYSTEMS	336
1	Scope	336
2	Definitions	336
3	General Requirements	337
4	Reconciliation Methods	338
5	Corrective Action	340
6	Instrumentation Requirements for Thermal Expansion Measurement	340
Figures		
1	System Heatup, Reconciliation, and Corrective Action	339
2	Typical Components of a TEMS	341
Table		
1	An Example of Specification of TEMS Minimum Requirements	341
Nonmandatory Appendices		
A	Guidelines for the Selection of Instrumentation and Equipment of a Typical TEMS	343
B	Thermal Stratification and Thermal Transients	346

PART 11	VIBRATION TESTING AND ASSESSMENT OF HEAT EXCHANGERS	349
1	Introduction	349
2	Definitions	349
3	References	349
4	Background Description	349
5	Selection of Equipment to Be Tested	350
6	Selection of Test Method	351
7	Test Requirements	352
8	Test Conditions	359
9	Documentation	359
10	Precautions	359
Figure		
1	Tube Bundle Configuration With Tube Groupings Most Susceptible to Fluidelastic Instability Denoted by Cross-Hatching	353
Nonmandatory Appendices		
A	Causes of Vibration	360
B	Methods for Comparative Evaluation of Fluidelastic and Turbulence-Induced Vibration	364
C	Test Guidelines for Dynamic Characterization of Tubes	367
D	External Vibration Surveys	368
E	Detection Methods and Data Interpretation	369
F	Vibration Acceptance Guidelines	384
G	Installation of Strain Gages	386
PART 14	VIBRATION MONITORING OF ROTATING EQUIPMENT IN NUCLEAR POWER PLANTS	387
1	Introduction	387
2	Definitions	387
3	References	388
4	Vibration Monitoring	389
5	Establishing the Baseline	393
6	Establishing Vibration Limits	393
7	Data Acquisition	398
8	Hardware	398
9	Diagnostics	398
Figures		
1	An Example of a Vibration Data Sheet	394
2	An Example of a Vibration Trend Curve	395
3	Vibration Level Trend Plot of Condition One	396
4	Vibration Level Trend Plot of Condition Two	397
Tables		
1	Comparison of Periodic and Continuous Monitoring and Relative Advantages	389
2	Transducer Location Guidelines — Turbines	390
3	Transducer Location Guidelines — Equipment With Antifriction Bearings	390

4	Transducer Location Guidelines — Horizontal Pumps — Fluid Film Bearings	391
5	Transducer Location Guidelines — Motor-Driven Vertical Pumps — Fluid Film Bearings	391
6	Transducer Location Guidelines — Electric Motors	392
7	Vibration Troubleshooting Chart	399
Nonmandatory Appendices		
A	Instrumentation Selection and Use	400
B	Transducers and Analysis Equipment	402
PART 17	PERFORMANCE TESTING OF INSTRUMENT AIR SYSTEMS IN LIGHT-WATER REACTOR POWER PLANTS	407
PART 19	PRESERVICE AND PERIODIC PERFORMANCE TESTING OF PNEUMATICALLY AND HYDRAULICALLY OPERATED VALVE ASSEMBLIES IN LIGHT-WATER REACTOR POWER PLANTS	408
1	Introduction	408
2	Definitions	408
3	Test Guidance	409
4	Test Methods	409
5	Analysis and Evaluation of Data	410
6	Corrective Action	411
PART 23	INSERVICE MONITORING OF REACTOR INTERNALS VIBRATION IN PRESSURIZED WATER REACTOR POWER PLANTS	412
1	Introduction	412
2	Definitions	412
3	References	414
4	Internals Vibration Excitation Sources, Responses, and Modes	414
5	Signal Database	415
6	Data Review	420
Figures		
1	Schematic of a Pressurized Water Reactor (PWR) Showing Typical Sensor Arrangement	413
2	Beam and Shell Mode Vibration of a PWR Core Support Barrel	416
3	Typical Components in a Signal Data Acquisition System	418
Tables		
1	Sensor Types and Potential Applications in Reactor Noise Analysis	417
2	Relationships Between Sampling Rates and Analysis Results	418
Nonmandatory Appendices		
A	Discussion of Spectral Functions	422
B	Supporting Information on Component Vibrations	426
C	Pump-Induced Vibrations	428
D	Sampling Rate and Length of Data Record Requirement to Resolve a Spectral Peak	434