

AN AMERICAN NATIONAL STANDARD

**ASME
PTC 46-1996**

Performance Test Code on Overall Plant Performance



**The American Society of
Mechanical Engineers**

**PERFORMANCE
TEST CODES**

CONTENTS

Foreword	iii
Standards Committee Roster	v

Section

0	Introduction	1
1	Object and Scope	3
2	Definitions and Description of Terms	5
3	Guiding Principles	7
4	Instruments and Methods of Measurement	23
5	Calculations and Results	47
6	Report of Results	65

Figures

3.1	Generic Test Boundary	8
3.2	Typical Steam Plant Test Boundary	8
3.3	Typical Combined Cycle Plant Test Boundary	9
3.4	Three Post-Test Cases	20
4.1	Five-Way Manifold	28
4.2	Four-Wire RTDs	30
4.3	Three-Wire RTDs	30
4.4	Flow-Through Well	32
4.5	Duct Measurement Points	33
4.6	Three-Wire Open Delta Connected Metering System	40
4.7	Four-Wire Metering System	41
4.8	Typical Correction Curve	44
5.1	Typical Test Boundary for a Power Plant Requiring Application of Heat Sink Correction factor Δ_{5A} or ω_{5A}	54
5.2	Typical Test Boundary for a Power Plant Requiring Application of Heat Sink Correction Factor Δ_{5B} or ω_{5B}	55
5.3	Typical Test Boundary for a Power Plant or Thermal Island Requiring Application of Heat Sink Correction Factor Δ_{5C} or ω_{5C}	56
5.4	Output Versus Throttle Steam Flow	62
5.5	Steam Turbine Plant Test Boundary	63

Tables

1.1	Largest Expected Test Uncertainties	4
3.1	Design, Construction, and Start-up Considerations	12
3.2	Guidance for Establishing Permissible Deviations From Design	17
3.3	Typical Pretest Stabilization Periods	19
3.4	Recommended Minimum Test Run Durations	19

5.1	Summary of Additive Correction Factors in Fundamental Performance Equations	48
5.2	Summary of Multiplicative Correction Factors in Fundamental Performance Equations	49
5.3	Examples of Typical Cycles and Test Objectives — Corresponding Specific Performance Equations	51
5.4	Change in Compressor Inlet Temperature over a 30% Range in Evaporator Cooler Effectiveness on a 80°F Day, with 80% Relative Humidity	59
5.5	Required Test Series for Phased Construction Combined Cycle Plants . .	61

Nonmandatory Appendices

A	Sample Calculations Combined Cycle Cogeneration Plant Without Duct Firing Heat Sink: Completely Internal to Test the Boundary Test Goal: Specified Measurement Power — Fire to Desired Power Level by Duct Firing.	67
B	Sample Calculations Combined Cycle Cogeneration Plant With Duct Firing Heat Sink: External to the Test Boundary Test Goal: Specified Measurement Power — Fire to Desired Power Level by Duct Firing.	81
C	Sample Calculations Combined Cycle Cogeneration Plant Without Duct Firing Heat Sink: Cooling Tower External to the Test Boundary Test Goal: Specified Disposition is Gas Turbine Base Loaded (Power Floats)	101
D	Representation of Correction for Different Heat Sink Temperature than Gas Turbine Air Inlet Temperature (Δ_5 or ω_5) if Necessary, for a Typical Combined Cycle Plant	121
E	Sample Calculations Steam Power Cogeneration Plant Heat Sink: River Cooling Water Flow within Test Boundary Test Goal: Two Test Runs are Made with Different Goals Test Run 1: Specified Corrected Power — Fire to Desired Corrected Power Test Run 2: Specified Disposition by Firing to Desired Throttle Flow (Power Floats)	125
F	Uncertainty Analysis	177
G	Entering Air Conditions	181
H	Energy Balance Method	183
I	Solid Fuel and Ash Sampling	185