

American Society of Sanitary Engineering

Performance Requirements for

Double Check Backflow Prevention Assemblies and Double Check Fire Protection Backflow Prevention Assemblies

An American National Standard

General Information

Neither this standard, nor any portion thereof, may be reproduced without the written consent of the American Society of Sanitary Engineering.

Instructions for receiving authorization to display the ASSE Seal are available from ASSE's International Office. Organizations wishing to adopt or list any ASSE Standard should print the ASSE Standard number on the cover page first and in equal or larger type to that of the adopting or listing organization.

American Society of Sanitary Engineering
Westlake, Ohio
Copyright © 2011, 2009, 2005, 1999, 1993, 1988, 1971
All rights reserved.

Foreword

This foreword shall not be considered a part of the standard. However, it is offered to provide background information.

ASSE Product Standards are developed in the interest of consumer safety.

The recognition of probable sources or causes of contamination of a potable water supply system and the application of essential devices, or means, to prevent the entrance of contaminants to the potable water system, causing it to become unfit for human consumption, is vital to the maintenance of its continued potability.

There are two basic and practiced methods for the protection of potable water supplies:

a) Protection by Containment

The isolation, by suitable devices or means, of the system within the premises supplied, wherein may lie the source or sources of contamination, from the vendor's or public water supply system.

b) Protection of Each Individual Outlet

The protection of each individual outlet by suitable devices or means, which within the premises served may be a source of contamination.

Protection by containment protects the vendor's or public water supply only. It does not provide protection within the premises supplied.

In modern plumbing systems, there are many situations where backflow could occur due to backpressure conditions. In some, the pollutants that would get into the water supply would be undesirable, yet not be a hazard to the health of persons consuming the water.

This standard covers two (2) types of devices, which are identified as Double Check Backflow Prevention Assemblies (DC) and Double Check Fire Protection Backflow Prevention Assemblies (DCF). The DC and the DCF are identical in their backflow protection. The DCF, which was added to this standard in 1999, has specific performance requirements relating to their use on fire protection systems.

The devices described are suitable for either protection by containment or protection of individual outlets where pollutants, which could be caused to enter the potable water, are low hazard.

These devices are suitable for either hot or cold water service under continuous or intermittent pressure conditions.

Although many of the material specifications are detailed within Section 4.1 of this standard, it is the responsibility of the manufacturer and the installer to comply with the relevant jurisdictional requirements.

The working group, which developed this standard revision, was set up within the framework of the Product Standards Committee of the American Society of Sanitary Engineering.

Recognition is made of the time volunteered by members of this working group and of the support of the manufacturers who participated in meetings for this standard.

This standard does not imply ASSE's endorsement of a product which conforms to these requirements.

Compliance with this standard does not imply acceptance by any code body.

It is recommended that these devices be installed consistent with local codes by qualified and trained professionals.

This standard was promulgated in accordance with procedures developed by the American National Standards Institute (ANSI).

This edition was approved by the ASSE Board of Directors on August 9, 2011 as an ASSE standard.

2011 Product Standards Committee

Joseph Fugelo

*Product Standards Committee Chairman
Labov Co.
Philadelphia, Pennsylvania*

John F. Higdon P.E.

*Apollo Valves / Conbraco Industries Inc
Matthews, North Carolina*

Rand Ackroyd

*Rand Technical Consulting, LLC
Newburyport, Massachusetts*

Chuck Lott

*Precision Plumbing Products
Portland, Oregon*

William Briggs Jr.

*MGJ Associates
New York, New York*

Peter Marzec

*United Association of Plumbers and
Pipefitters
Pearl River, New York*

Maribel Campos

*ICC Evaluation Services
Whittier, California*

Hamid Naderi

*ICC – Texas
Austin, Texas*

Judson Collins

*Julyco Professionals
Mannford, Oklahoma*

Brad Noll

*Wilkins / A Division of Zurn
Paso Robles, California*

Ron George

*Plumb-Tech Design & Consulting
Services, LLC
Newport, Michigan*

Thomas Pitcherello

*State of New Jersey
Bordentown, New Jersey*

Steven Hazzard

*ASSE Staff Engineer
Westlake, Ohio*

Shabbir Rawalpindiwala

*Kohler Company
Kohler, Wisconsin*

Charles Hernandez

*Spears Manufacturing
Bolingbrook, Illinois*

Tsan-Liang Su, PhD

*Stevens Institute of Technology
Hoboken, New Jersey*

RP / DC Working Group

John F. Higdon, P.E.

*Working Group Chairman
Apollo Valves / Conbraco Industries, Inc.
Matthews, North Carolina*

Rand H. Ackroyd

*Rand Engineering
Newburyport, Massachusetts*

Stu Asay, P.E.

*Backflow Prevention Institute
Westminster, Colorado*

Paul Bladdick

*LPB Company, Inc.
White Lake, Michigan*

William Chapin

*Cash Acme / Reliance Worldwide
Cullman, Alabama*

Sean Cleary

*IAPMO
Scranton, Pennsylvania*

Steven Hazzard

*ASSE Staff Engineer
Westlake, Ohio*

Sara Marxen

*ASSE Compliance Coordinator
Westlake, Ohio*

Brad Noll

*Wilkins, a Division of Zurn Industries
Paso Robles, California*

Paul Schwartz, P.E.

*University of Southern California FCCCHR
Los Angeles, California*

Ken Van Wagnen

*ASSE Product Standards Coordinator
Westlake, Ohio*

Jeff Vlisides

*ABPA Michigan
Waterford, Michigan*

Stanley Ziobro

*Factory Mutual Approvals
Norwood, Massachusetts*

Table of Contents

Section I	1
1.0 General	1
1.1 Application	1
1.2 Scope	1
Table 1	2
1.3 Limitations on Design	3
1.4 Reference Standards	4
Section II	6
2.0 Test Specimens	6
2.1 Samples Submitted for Test	6
2.2 Samples Tested	6
2.3 Drawings	6
2.4 Rejection	6
2.5 Manifold Assembly	6
Section III	7
3.0 Performance Requirements and Compliance Testing	7
3.1 Independence of Components	7
3.2 Hydrostatic Test of Complete Assembly	7
Figure 1	8
Figure 1A	8
3.3 Seat Leakage Test for Shut-off Valves	8
3.4 Hydrostatic Backpressure Test of Checks	9
3.5 Allowable Pressure Loss at Rated Flow	9
3.6 Drip Tightness of First Check	11
3.7 Drip Tightness of Second Check	11
3.8 Deterioration at Manufacturer's Extremes of Temperature and Pressure Ranges	12
Table 2	13
3.9 Cycle Test	14
3.10 Body Strength Test for Type DCF Assemblies Only	15
3.11 Seat Adhesion Test for Type DCF Assemblies Only	15
3.12 High Velocity Test for Type DCF Assemblies	15
3.13 Field Evaluation Test for DC and DCF Devices When Required by the Authority	
Having Jurisdiction	16
Section IV	18
4.0 Detailed Requirements	18
4.1 Materials	18
4.2 Grooved Connections	19
4.3 Marking Instructions	19
4.4 Installation and Maintenance Instructions	19
Section V	20
5.0 Definitions	20
Appendix A - Installation Guidelines	21
A1.0 Recommended Installation Guidelines	21
A1.1 General	21
A1.2 Orientation	21
A1.3 Side Clearances	21

Double Check Backflow Prevention Assemblies and Double Check Fire Protection Backflow Prevention Assemblies

Section I

1.0 General

1.1 Application

The purpose of a Double Check Backflow Prevention Assembly (DC) and a Double Check Fire Protection Backflow Prevention Assembly (DCF) (herein referred to as the "assembly") is to keep polluted water from flowing into a potable water distribution system when some abnormality in the system causes the pressure to be temporarily higher in the polluted part of the system than in the potable water supply piping.

1.2 Scope

1.2.1 Description

This standard applies to two types of backflow prevention assemblies, identified as:

- (a) Double Check Backflow Prevention Assembly (DC); and
- (b) Double Check Fire Protection Backflow Prevention Assembly (DCF).

These assemblies consist of two (2) independently acting check valves, internally force loaded to a normally closed position, two (2) properly located, tightly closing shut-off valves, per Section 1.3.2.6, and properly located test cocks, per Section 1.3.2.4. These assemblies are designed and constructed to operate under intermittent or continuous pressure conditions.

This standard also applies to Manifold Double Check Backflow Prevention Assemblies consisting of two (2) or more complete Double Check Backflow Prevention Assemblies in parallel. The assemblies do not need to be of the same pipe size. The manifold size shall be identified by the single inlet and outlet of the manifold assembly. Manifold Double Check Backflow Prevention Assemblies shall include line-sized shut-off valves on each inlet and outlet of the assemblies making up the manifold.

1.2.2 Size Range

Connection pipe sizes shall be in accordance with Table 1.