PE Pipe—Design and Installation

AWWA MANUAL M55

First Edition



Science and Technology

AWWA unites the drinking water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

MANUAL OF WATER SUPPLY PRACTICES—M55, First Edition PE Pipe—Design and Installation

Copyright © 2006 American Water Works Association

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Disclaimer

The authors, contributors, editors, and publisher do not assume responsibility for the validity of the content or any consequences of their use. In no event will AWWA be liable for direct, indirect, special, incidental, or consequential damages arising out of the use of information presented in this book. In particular, AWWA will not be responsible for any costs, including, but not limited to, those incurred as a result of lost revenue. In no event shall AWWA's liability exceed the amount paid for the purchase of this book.

Project Manager/Copy Editor: Melissa Christensen Production: Glacier Publishing Services, Inc. Manuals Coordinator: Beth Behner

Library of Congress Cataloging-in-Publication Data

PE pipe : design and installation.-- 1st ed. p. cm.
Includes bibliographical references and index.
ISBN 1-58321-387-2
1. Pipe, Plastic Design and Construction. 2. Polyethylene.

TA448.P4 2005 628.1'5--dc22

2005055888

Printed in the United States of America.

American Water Works Association 6666 West Quincy Avenue Denver, CO 80235-3098

ISBN 1-58321-387-2



Contents

| List of Figures, vii |
|---|
| List of Tables, xi |
| List of Terms and Equation Symbols, xiii |
| List of Conversions, xvii Metric Conversions, xvii Celsius/Fahrenheit Comparison Graph, xxi Decimal Equivalents of Fractions, xxii |
| Preface, xxiii |
| Acknowledgments, xxv |
| Chapter 1 Engineering Properties of Polyethylene |
| Chapter 2 Manufacturing, Testing, and Inspection |
| Chapter 3 Hydraulics of PE Pipe |
| Chapter 4 Working Pressure Rating |

Molded and Fabricated Fittings, 47 References, 48

| Chapter 5 External Load Design | 9 |
|--|---|
| Introduction, 49 Dead Loads, 50 Live Loads, 51 Surcharge Loads, 54 Ring Deflection, 57 Wall Buckling, 61 Wall Compressive Stress, 63 Design Window, 64 Example No. 1, 65 Example No. 2, 67 Example No. 3, 68 Example No. 4, 69 Example No. 5, 70 References, 70 | |
| Chapter 6 Joining and Fittings | 3 |
| Heat Fusion Joining, 73 Mechanical Joining, 80 Mainline Fittings, 84 Branching and Tapping, 86 Service Connections, 87 References, 88 | |
| Chapter 7 Transportation, Handling, and Storage of Pipe | |
| and Fittings | 1 |
| Receiving Inspection, 91 Product Packaging, 91 Checking the Order, 92 Load Inspection, 92 Receiving Report and Reporting Damage, 94 Unloading Instructions, 94 Unloading Site Requirements, 94 Handling Equipment, 94 Unloading Large Fabrications, 95 Preinstallation Storage, 95 Pipe Stacking Heights, 95 Exposure to Ultraviolet Light and Weather, 96 Cold Weather Handling, 96 Field Handling, 96 | |
| Chapter 8 Installation | 9 |
| General Considerations, 99 Underground Installations, 99 Special Installation Techniques, 113 Marine Installations, 116 References, 126 | |

| Chapter 9 Hyd | drotesting and Commission | i ng | ••• | 127 |
|---------------|---------------------------|-------------|-----|---------|
| Flushing, 1 | 127 | | | |
| Filling, 12 | 7 | | | |
| Leak Testi | ng, 127 | | | |
| Records, 1 | 30 | | | |
| Disinfectio | on, 130 | | | |
| Commissio | oning, 131 | | | |
| References | s, 131 | | | |
| Chapter 10 Ma | aintenance and Repairs | | | 133 |
| Disinfection | ng Water Mains, 133 | | | |
| Cleaning, | 133 | | | |
| Maintenar | nce, 133 | | | |
| Repairs, 13 | 34 | | | |
| New Servi | ce Connections, 136 | | | |
| New Conn | ections to Mains, 140 | | | |
| References | s, 141 | | | |
| Index, 143 | | | | |
| AWWA Manuals | s, 151 | | | |

v

This is a preview of "AWWA M55-2006". Click here to purchase the full version from the ANSI store.

This page intentionally blank.

Figures

- 1-1 Traditional model of HDPE, 4
- 1-2 Generalized tensile stress-strain curve for PE pipe grades, 6
- 2-1 Typical extrusion line, 23
- 2-2 Typical pipe extruder, 23
- 2-3 Typical injection molding machine, 24
- 2-4 Prefabricated 90° elbow being attached in field, 24
- 3-1 Moody diagram, 35
- 5-1 AASHTO HS20 wheel load distribution, 52
- 5-2 Load distribution over buried pipe, 55
- 5-3 Ovality correction factor, 64
- 6-1 Butt fusion joint, 75
- 6-2 Typical butt fusion machine (butt fusion machines are available to fuse pipe up to 65 in. in diameter), 75
- 6-3 Conventional saddle fusion joint, 77
- 6-4 Typical electrofusion saddle fusion, 77
- 6-5 Socket fusion joining, 79
- 6-6 Typical electrofusion joint, 79
- 6-7 Typical electrofusion fitting and control box (lower right), 79
- 6-8 Mechanical compression coupling with restraint—PE restrained by electrofusion flex restraints—PVC pipe restrained using a tapered gripping ring, 81
- 6-9 PE flange adapter, 82
- 6-10 Mechanical flange adapter, 85
- 6-11 MJ adapter, 85
- 6-12 Transition fittings, 86
- 6-13 Molded and fabricated elbows, 86
- 6-14 Electrofusion branch saddle connected to gate valve by MJ adapters, 87
- 6-15 Conventional saddle fusion branch saddles, 87
- 6-16 Mechanical tapping saddle, 88
- 6-17 Saddle tapping tees, 88

- 6-18 High volume tapping tees (HVTT), 89
- 6-19 Corporation stop saddles, 89
- 7-1 Typical silo pack truckload (40-ft trailer), 93
- 7-2 Typical bulk pack truckload (40-ft trailer), 93
- 7-3 Typical strip load truckload (40-ft trailer), 93
- 7-4 Forklift load capacity, 95
- 7-5 Loose pipe storage, 97
- 8-1 Trench construction and terminology, 101
- 8-2 Trench width, 104
- 8-3 Trench box installation, 104
- 8-4 Bend radius, 106
- 8-5 Example haunch tamping tool, 108
- 8-6 Pullout prevention technique, 109
- 8-7 Pullout prevention technique, 109
- 8-8 In-line anchor using flex restraint, 110
- 8-9 In-line anchor using integral pipe collar (wall anchor), 110
- 8-10 Controlling shear and bending, 112
- 8-11 Flange support at wall, 112
- 8-12 Appurtenance support pad, 112
- 8-13 Split backup ring, 117
- 8-14 Concrete weight, 122
- 8-15 Concrete weight, 122
- 8-16 Flotation above the surface, 122
- 8-17 Flotation at the surface, 122
- 8-18 Deflection between floats, 124
- 8-19 Float submergence, 125
- 10-1 Damage to PE pipe by backhoe bucket, 135
- 10-2 Wrap-around repair sleeve used to repair small puncture holes in PE pipe, 135
- 10-3 Electrofusion saddles are available for repairs, 135
- 10-4 Repair using self-restraining mechanical couplings, 137
- 10-5 Bolted, sleeve-type coupling, 137

- 10-6 Insert stiffener, 137
- 10-7 Repair using electrofusion couplings, 137
- 10-8 Section replacement using flanged spool, 137
- 10-9 Section replacement by deflecting smaller pipes, 137
- 10-10 Damage to saddle by backhoe, 138
- 10-11 Threaded outlet repair saddle, 138
- 10-12 90° ell compression fitting, 138
- 10-13 Straight coupling, 138
- 10-14 Male adapter, 138
- 10-15 Reducing coupling, 138
- 10-16 Attachment of mechanical saddle, 139
- 10-17 Corp stop attached to mechanical saddle, 139
- 10-18 Electrofusion saddle, processor, corp stop, adapters, wrench, and cutter for hot tap, 139
- 10-19 Electrofusion saddle with corp stop and cutter attached through corp stop to make hot tap, 140
- 10-20 A 6-in. outlet saddle with MJ adapter for fusion on 8-in. PE pipe, 140
- 10-21 Electrofusion coupling connecting PE reducing tee with mechanical joint adapter to PE pipeline, 141
- 10-22 In-the-trench sidewall fusion to attach saddle to water line, 141
- 10-23 Tapping sleeve with MJ outlet, 141
- 10-24 Compression by flange coupling for use in joining PE to other materials, 141

This is a preview of "AWWA M55-2006". Click here to purchase the full version from the ANSI store.

This page intentionally blank.

Tables

- 1-1 Effects of density, molecular weight, and molecular weight distribution, 2
- 1-2 Electrical properties of PE, 9
- 1-3 ASTM D3350 cell classification limits, 16
- 1-4 Example of D3350 cell class specification, 16
- 3-1 PE 3408 polyethylene pipe iron pipe size (IPS) pipe data, 32
- 3-2 PE 3408 polyethylene pipe ductile iron pipe size (DIPS) pipe data, 34
- 3-3 Representative equivalent length in pipe diameters of various piping components, 37
- 4-1 Hydrostatic design basis (*HDB*) for standard PE 3408 and PE 2406 materials, 40
- 4-2 Pressure class for PE 3408 and PE 2406 pipe, 42
- 4-3 Surge pressures generated by a sudden change in water flow velocity for PE pipes operating at service temperatures through 80°F (27°C), 44
- 4-4 Pressure class, surge allowance, and corresponding sudden velocity change for PE 3408 pipe operating at service temperatures through 80°F (27°C), 45
- 4-5 Pressure class, surge allowance, and corresponding sudden velocity change for PE 2406 pipe operating at service temperatures through 80°F (27°C), 45
- 4-6 Temperature compensation multipliers, F_T , 47
- 4-7 PE 3408 working pressure rating for recurring surge events as a result of instantaneous change in water column velocity, 47
- 5-1 Impact factors for paved road, 52
- 5-2 H20 loading (rigid pavement), 53
- 5-3 AASHTO H20 loading under flexible pavement and unpaved roads, 53
- 5-4 Cooper E-80 railroad loads, 55
- 5-5 Influence coefficients, 56
- 5-6 Apparent modulus of elasticity @ 73°F, 58
- 5-7 Bureau of Reclamation values for E', modulus of soil reaction, 59
- 5-8 Duncan-Hartley's values of *E*', modulus of soil reaction, 60
- 5-9 Values of E'_N , modulus of soil reaction for native soil, from Howard, 61
- 5-10 Soil support factor, S_c , 61
- 5-11 Design deflection for pressure pipe, 62

- 6-1 Approximate joining rates for butt fusion, 76
- 7-1 Suggested jobsite loose storage stacking heights for conventionally extruded pipe lengths, 97
- 8-1 Minimum trench width, 104
- 8-2 Minimum cold (field) bending radius (long-term), 106
- 8-3 Embedment soil classification, 107
- 8-4 Approximate Poisson effect pullout force, 111
- 8-5 Recommended design factors, 115
- 8-6 Approximate tensile yield strength values, 115
- 8-7 Minimum short-term bending radius, 115
- 8-8 Underwater environment factor, K_e , 119
- 8-9 Specific gravities and specific weights at 60° F (15°C), 119
- 8-10 Pipe weight conversion factors, 120
- 8-11 Approximate ballast weight spacing, 121
- 8-12 Polyethylene float properties, 125
- 8-13 Submergence factor, f_S , 125
- 9-1 Standard pressure class, 129

Terms and Equation Symbols

| Term or | | | | |
|----------------------------|---|--|--|--|
| Symbol | Meaning | | | |
| а | wave velocity (celerity), ft/sec | | | |
| А | wheel contact area, $in.^2$ | | | |
| ATL | allowable tensile load, lb | | | |
| В | float buoyancy, lb/ft | | | |
| В' | soil elastic support factor | | | |
| $\mathbf{B}_{\mathbf{d}}$ | trench width at the pipe springline, in. | | | |
| B_N | negative buoyancy, lb/ft | | | |
| B_P | buoyancy of pipe, lb/ft | | | |
| С | Hazen-Williams flow coefficient, dimensionless | | | |
| D | average inside pipe diameter, ft | | | |
| d | float outside diameter, in. | | | |
| DF | design factor, dimensionless — the factor that is used to reduce the hydrostatic design basis to arrive at the hydrostatic design stress from which the pressure class is determined. Unless otherwise noted, the design factor for water applications is 0.5 | | | |
| D_i | average inside pipe diameter, in. | | | |
| DIPS | ductile iron pipe size — the nominal outside diameter is the same as ductile iron pipe | | | |
| D_{M} | mean diameter, in. $(D_0 - t)$ | | | |
| $\mathbf{D}_{\mathbf{o}}$ | average outside diameter of the pipe, in. | | | |
| DR | dimension ratio (dimensionless) — the ratio of the average specified outside diameter to the specified minimum wall thickness (D_0/t) for outside diameter controlled polyethylene pipe | | | |
| E | apparent modulus of elasticity for pipe material, psi | | | |
| e | natural log base number, 2.71828 | | | |
| E' | design modulus of soil reaction, psi | | | |
| $\mathbf{E}_{\mathbf{d}}$ | dynamic instantaneous effective modulus of elasticity of the pipe material, psi (150,000 psi for polyethylene) | | | |
| E'_E | modulus of soil reaction of embedment soil, psi | | | |
| E'_{N} | modulus of soil reaction of native soil, psi | | | |
| f | Darcy-Weisbach fraction factor, dimensionless | | | |
| \mathbf{F} | pullout force, lb | | | |
| $\mathbf{f}_{\mathbf{O}}$ | ovality compensation factor | | | |
| $\mathbf{f}_{\mathbf{SA}}$ | actual float submergence factor | | | |
| $\mathbf{F}_{\mathbf{T}}$ | temperature compensation multiplier, dimensionless | | | |
| \mathbf{f}_{T} | tensile yield design (safety) factor | | | |
| $\mathbf{f}_{\mathbf{Y}}$ | time under tension design (safety) factor | | | |
| g | acceleration due to gravity, 32.2 ft/sec ² | | | |
| Η | soil height above pipe crown, ft | | | |
| h | float submergence below water level, in. | | | |

-

| Term or Symbol | Meaning |
|----------------------------|--|
| HDB | hydrostatic design basis, psi — the categorized long-term strength in the circumferential or hoop direction for the polyethylene material as established from long-term pressure tests in accordance with PPI TR-3 and the methodology contained in ASTM D2837 |
| HDS | hydrostatic design stress, psi — the hydrostatic design basis multiplied by the design factor (HDB \times DF) |
| $\mathbf{h_{f}}$ | frictional head loss, ft of liquid |
| H_{OT} | depth of open trench, ft |
| $\mathbf{H}_{\mathbf{W}}$ | groundwater height above pipe, ft |
| Ι | moment of inertia, in. ⁴ |
| I_{C} | influence coefficient, dimensionless |
| IDR | inside dimension ratio, dimensionless — the ratio of the average specified inside diameter to the specified minimum wall thickness (D/t) for inside diameter controlled polyethylene pipe |
| I_{f} | impact factor, dimensionless |
| IPS | iron pipe size — the nominal outside diameter is the same as iron (steel) pipe |
| K | bulk modulus of liquid at working temperature (300,000 psi for water at 73°F [23°C]) |
| K_{e} | underwater environment factor |
| \mathbf{L} | length of pipe, ft |
| L_{BS} | ballast weight spacing, ft |
| $\mathbf{L}_{\mathbf{eq}}$ | equivalent length of straight pipe, ft — for fittings, the equivalent length of straight pipe that has the same frictional head loss as the fitting |
| $L_{\rm F}$ | length of float, ft |
| LOT | length of open trench, ft |
| L_S | distance between supports, ft |
| L_{SP} | length of supported pipeline, ft |
| $\mathbf{L}_{\mathbf{t}}$ | time-lag factor, dimensionless |
| $\mathbf{M}_{\mathbf{M}}$ | density of foam fill, lb/ft ³ |
| Ν | safety factor |
| Р | pipe internal pressure, psi |
| P(MAX)(OS) | maximum allowable system pressure during occasional surge, psi |
| P(MAX)(RS) | maximum allowable system pressure during recurrent surge, psi |
| PC | pressure class, psi — the pressure class is the design capacity to resist working pressure up to 80°F (27°C) with specified maximum allowances for recurring positive pressure surges above working pressure. Pressure class also denotes the pipe's maximum working pressure rating for water at 80°F (27°C) |
| P_{CA} | allowable external pressure for constrained pipe, psi |
| PE | polyethylene |
| $P_{\rm E}$ | earth pressure on pipe, psi |
| PE 2406 | a standard code designation for polyethylene pipe and fittings materials that has a minimum cell classification of 213333C, D, or E per ASTM D3350 and a hydrostatic design basis at 73.4°F (23°C) of 1250 psi |
| PE 3408 | a standard code designation for polyethylene pipe and fittings materials that has a minimum cell classification of 334434C, D, or E per ASTM D3350 and a hydrostatic design basis at 73.4°F (23°C) of 1600 psi |
| $\mathbf{P}_{\mathbf{ES}}$ | surcharge earth load pressure at point on pipe crown, psf |

| Term or Symbol | Meaning |
|----------------------------|--|
| PL | vertical stress acting on pipe crown, psi |
| P _{OS} | pressure allowance for occasional surge pressure, psi — occasional surge pressures are caused by emergency operations that are usually the result of a malfunction such as power failure or system component failure, which includ pump seize-up, valve stem failure, and pressure-relief-valve failure |
| \mathbf{P}_{RS} | pressure allowance for recurring surge pressure, psi — recurring surge pressur occur frequently and inherent in the design and operation of the system (such normal pump startup and shutdown and normal valve opening or closure) |
| P_S | transient surge pressure, psi — the maximum hydraulic transient pressure increase (water hammer) in excess of the operating pressure that is anticipat in the system as a result of sudden changes in the velocity of the water colum |
| P_{UA} | allowable external pressure for unconstrained pipe, psi |
| P_V | negative internal pressure (vacuum) in pipe, psi |
| Q | volumetric liquid flow rate, U.S. gal/min |
| R | equivalent radius, ft |
| R_b | buoyancy reduction factor |
| Re | Reynolds Number, dimensionless |
| s | hydraulic slope, ft/ft — frictional head loss per foot of pipe (h _f /L) |
| S | hoop compressive wall stress, psi |
| $\mathbf{S}_{\mathbf{C}}$ | soil support factor |
| SDR | standard dimension ratio (dimensionless) — the ratio of the average specified outside diameter to the specified minimum wall thickness for outside diameter controlled polyethylene pipe, the value of which is derived by adding one to the pertinent number selected from the ANSI Preferred Number Series R10. Som of the values are as follows: R10 SDR 5 6 6.3 7.3 8 9 10 11 12.5 13.5 16 17 20 21 25 26 31.5 32.5 40 41 |
| \mathbf{S}_{L} | specific gravity of liquid |
| $\mathbf{S}_{\mathbf{P}}$ | internal pressure hoop stress, psi |
| t | minimum specified wall thickness, in. |
| t_{a} | average wall thickness, in. — 106% of minimum wall thickness $(t*1.06)$ |
| T_{Y} | pipe tensile yield strength, psi |
| v | average velocity of flowing fluid, ft/sec |
| $V_{\rm B}$ | pipe bore volume, ft ³ /ft |
| V_{F} | float internal volume, ft ³ /ft |
| V_{P} | displaced volume of pipe, ft ³ /ft |
| w | unit weight of soil, lb/ft ³ |
| W | supported load, lb |
| W_{BD} | weight of dry ballast, lb/ft |
| W_{BS} | weight of submerged ballast, lb/ft |

| Term or Symbol | Meaning |
|-------------------|---|
| WF | float weight, lb/ft |
| WF | float load supporting capacity, lb |
| WL | vehicular wheel load, lb |
| WLI | weight of liquid inside pipe, lb/ft |
| WM | weight of floam fill, lb/ft |
| WP | pipe weight, lb/ft |
| WP | working pressure, psi — the maximum anticipated sustained operating pressure applied to the pipe exclusive of surge pressures |
| WPR | working pressure rating, psi — the working pressure rating is the pipe's design capacity to resist working pressure at the anticipated operating temperature with sufficient capacity against the actual anticipated positive pressure surges above working pressure. A pipe's WPR may be equal to or less than its nomina pressure class depending on the positive transient pressure characteristics of the system and pipe operating temperature if above 80°F (27°C) |
| W_s | distributed surcharge pressure acting over ground surface, psf |
| w_S | weight of float attachment structure, lb |
| Уs | deflection between supports, in. |
| γ | kinematic viscosity of the flowing fluid, ft ² /sec |
| Δv | velocity change occurring within the critical time 2L/a, sec |
| ΔY | change in diameter due to deflection, in. |
| ε | absolute roughness of the pipe, ft |
| μ | Poisson's ratio |
| $\omega_{\rm B}$ | specific weight of ballast material, lb/ft ³ |
| $\omega_{\rm L}$ | specific weight of liquid, lb/ft ³ |
| $\omega_{\rm LI}$ | specific weight of the liquid inside the pipe, lb/ft^3 |
| $\omega_{\rm LO}$ | specific weight of the liquid outside the pipe, lb/ft ³ |

Conversions

METRIC CONVERSIONS

Linear Measurement

| inch (in.) | $\times 25.4$ | = millimeters (mm) |
|-----------------|------------------|--------------------|
| inch (in.) | $\times 2.54$ | = centimeters (cm) |
| foot (ft) | $\times 304.8$ | = millimeters (mm) |
| foot (ft) | $\times 30.48$ | = centimeters (cm) |
| foot (ft) | $\times 0.3048$ | = meters (m) |
| yard (yd) | $\times 0.9144$ | = meters (m) |
| mile (mi) | $\times 1,609.3$ | = meters (m) |
| mile (mi) | $\times 1.6093$ | = kilometers (km) |
| millimeter (mm) | $\times 0.03937$ | = inches (in.) |
| centimeter (cm) | $\times 0.3937$ | = inches (in.) |
| meter (m) | $\times 39.3701$ | = inches (in.) |
| meter (m) | $\times 3.2808$ | = feet (ft) |
| meter (m) | $\times 1.0936$ | =yards (yd) |
| kilometer (km) | $\times 0.6214$ | = miles (mi) |
| | | |

Area Measurement

| square meter (m ²) | $\times 10,000$ | = square centimeters (cm^2) |
|--------------------------------------|-------------------|--|
| hectare (ha) | $\times 10,000$ | = square meters (m^2) |
| square inch $(in.^2)$ | $\times 6.4516$ | = square centimeters (cm^2) |
| square foot (ft ²) | $\times 0.092903$ | = square meters (m^2) |
| square yard (yd ²) | $\times 0.8361$ | = square meters (m^2) |
| acre | $\times 0.004047$ | = square kilometers (km ²) |
| acre | $\times 0.4047$ | = hectares (ha) |
| square mile (mi ²) | $\times 2.59$ | = square kilometers (km ²) |
| square centimeter (cm ²) | $\times 0.16$ | = square inches (in. ²) |
| square meters (m ²) | $\times 10.7639$ | = square feet (ft ²) |
| square meters (m ²) | $\times 1.1960$ | = square yards (yd ²) |
| hectare (ha) | $\times 2.471$ | = acres |
| square kilometer (km ²) | $\times 247.1054$ | = acres |
| square kilometer (km ²) | $\times 0.3861$ | = square miles (mi ²) |
| | | |

Volume Measurement

| cubic inch (in. ³) | $\times 16.3871$ | = cubic centimeters (cm ³) |
|--------------------------------|-------------------|--|
| cubic foot (ft^3) | $\times 28,317$ | = cubic centimeters (cm^3) |
| cubic foot (ft^3) | $\times 0.028317$ | = cubic meters (m^3) |
| cubic foot (ft^3) | $\times 28.317$ | = liters (L) |
| cubic yard (yd ³) | $\times 0.7646$ | = cubic meters (m^3) |
| acre foot (acre-ft) | $\times 123.34$ | = cubic meters (m^3) |
| ounce (US fluid) (oz) | $\times 0.029573$ | = liters (L) |
| quart (liquid) (qt) | $\times 946.9$ | = milliliters (mL) |
| quart (liquid) (qt) | $\times 0.9463$ | = liters (L) |
| gallon (gal) | $\times 3.7854$ | = liters (L) |

| $\times0.0037854$ | = cubic meters (m^3) |
|-------------------|----------------------------------|
| $\times 0.881$ | = decaliters (dL) |
| $\times 0.3524$ | = hectoliters (hL) |
| $\times 0.061$ | = cubic inches $(in.^3)$ |
| $\times 35.3183$ | = cubic feet (ft^3) |
| $\times 1.3079$ | = cubic yards (yd ³) |
| $\times 264.2$ | =gallons (gal) |
| $\times 0.000811$ | = acre-feet (acre-ft) |
| $\times 1.0567$ | =quart (liquid) (qt) |
| $\times 0.264$ | =gallons (gal) |
| $\times 0.0353$ | = cubic feet (ft^3) |
| $\times 2.6417$ | =gallons (gal) |
| $\times 1.135$ | = pecks (pk) |
| $\times 3.531$ | = cubic feet (ft^3) |
| $\times 2.84$ | = bushels (bu) |
| $\times 0.131$ | = cubic yards (yd ³) |
| $\times 26.42$ | =gallons (gal) |
| | |

Pressure Measurement

| pound/square inch (psi) | $\times 6.8948$ | = kilopascals (kPa) |
|--|-------------------|---|
| pound/square inch (psi) | $\times 0.00689$ | = pascals (Pa) |
| pound/square inch (psi) | $\times 0.070307$ | = kilograms/square centimeter (kg/cm ²) |
| pound/square foot (lb/ft ²) | $\times 47.8803$ | = pascals (Pa) |
| pound/square foot (lb/ft ²) | $\times 0.000488$ | = kilograms/square centimeter (kg/cm ²) |
| pound/square foot (lb/ft ²) | $\times 4.8824$ | = kilograms/square meter (kg/m ²) |
| inches of mercury | $\times 3,376.8$ | = pascals (Pa) |
| inches of water | $\times 248.84$ | = pascals (Pa) |
| bar | $\times 100,000$ | = newtons per square meter |
| pascals (Pa) | ×1 | = newtons per square meter |
| pascals (Pa) | $\times 0.000145$ | = pounds/square inch (psi) |
| kilopascals (kPa) | $\times 0.145$ | = pounds/square inch (psi) |
| pascals (Pa) | $\times 0.000296$ | = inches of mercury (at 60° F) |
| $kilogram/square\ centimeter\ (kg/cm^2)$ | $\times 14.22$ | = pounds/square inch (psi) |
| $kilogram/square\ centimeter\ (kg/cm^2)$ | $\times 28.959$ | = inches of mercury (at 60° F) |
| kilogram/square meter (kg/m ²) | $\times 0.2048$ | = pounds per square foot (lb/ft^2) |
| centimeters of mercury | $\times 0.4461$ | = feet of water |
| | | |

Weight Measurement

| ounce (oz) | imes 28.3495 | = grams (g) |
|---|-------------------|-----------------------------------|
| pound (lb) | $\times 0.045359$ | = grams (g) |
| pound (lb) | $\times 0.4536$ | = kilograms (kg) |
| ton (short) | $\times 0.9072$ | = megagrams (metric ton) |
| pounds/cubic foot (lb/ft ³) | $\times 16.02$ | = grams per liter (g/L) |
| pounds/million gallons (lb/mil gal) | $\times 0.1198$ | = grams per cubic meter (g/m^3) |
| gram (g) | $\times 15.4324$ | =grains (gr) |
| gram (g) | $\times 0.0353$ | =ounces (oz) |
| gram (g) | $\times 0.0022$ | = pounds (lb) |
| kilograms (kg) | $\times 2.2046$ | = pounds (lb) |
| kilograms (kg) | $\times 0.0011$ | =tons (short) |
| megagram (metric ton) | $\times 1.1023$ | = tons (short) |

| grams/liter (g/L) $\times 0.0624$ grams/cubic meter (g/m ³) $\times 8.3454$ | = pounds per cubic foot (lb/ft ³) = pounds/million gallons (lb/mil gal) |
|---|--|
|---|--|

Flow Rates

| | 0 505 | |
|---|---------------------|---|
| gallons/second (gps) | × 3.785 | = liters per second (L/sec) |
| gallons/minute (gpm) | × 0.00006308 | = cubic meters per second (m^3/sec) |
| gallons/minute (gpm) | × 0.06308 | = liters per second (L/sec) |
| gallons/hour (gph) | ×0.003785 | = cubic meters per hour (m ³ /hr) |
| gallons/day (gpd) | | 5 = million liters per day (ML/day) |
| gallons/day (gpd) | $\times 0.003785$ | = cubic meters per day (m^3/day) |
| cubic feet/second (ft ³ /sec) | $\times 0.028317$ | = cubic meters per second (m^{3}/sec) |
| cubic feet/second (ft ³ /sec) | $\times 1,699$ | = liters per minute (L/min) |
| cubic feet/minute (ft ³ /min) | $\times 472$ | = cubic centimeters/second (cm ³ /sec) |
| cubic feet/minute (ft ³ /min) | $\times 0.472$ | = liters per second (L/sec) |
| cubic feet/minute (ft ³ /min) | $\times 1.6990$ | = cubic meters per hour (m ³ /hr) |
| million gallons/day (mgd) | $\times 43.8126$ | = liters per second (L/sec) |
| million gallons/day (mgd) | $\times 0.003785$ | = cubic meters per day (m ³ /day) |
| million gallons/day (mgd) | $\times 0.043813$ | = cubic meters per second (m^3/sec) |
| gallons/square foot (gal/ft ²) | $\times 40.74$ | = liters per square meter (L/m^2) |
| gallons/acre/day (gal/acre/day) | $\times 0.0094$ | = cubic meters/hectare/day (m ³ /ha/day) |
| gallons/square foot/day (gal/ft ² /day) | $\times 0.0407$ | = cubic meters/square meter/day $(m^3/m^2/day)$ |
| gallons/square foot/day (gal/ft²/day) | $\times 0.0283$ | = liters/square meter/day (L/m ² /day) |
| gallons/square foot/minute (gal/ft ² /min) | $\times 2.444$ | = cubic meters/square meter/hour $(m^3/m^2/hr) = m/hr$ |
| gallons/square foot/minute (gal/ft ² /min) | × 0.679 | = liters/square meter/second (L/m ² /sec) |
| gallons/square foot/minute (gal/ft ² /min) | $\times 40.7458$ | = liters/square meter/minute (L/m²/min) |
| gallons/capita/day (gpcd) | $\times 3.785$ | = liters/day/capita (L/d per capita) |
| liters/second (L/sec) | $\times 22,\!824.5$ | = gallons per day (gpd) |
| liters/second (L/sec) | $\times 0.0228$ | = million gallons per day (mgd) |
| liters/second (L/sec) | $\times 15.8508$ | =gallons per minute (gpm) |
| liters/second (L/sec) | $\times 2.119$ | = cubic feet per minute (ft ³ /min) |
| liters/minute (L/min) | $\times 0.0005886$ | = cubic feet per second (ft^3/sec) |
| cubic centimeters/second (cm ³ /sec) | $\times 0.0021$ | = cubic feet per minute (ft^3/min) |
| cubic meters/second (m ³ /sec) | $\times 35.3147$ | = cubic feet per second (ft^3/sec) |
| cubic meters/second (m ³ /sec) | $\times 22.8245$ | = million gallons per day (mgd) |
| cubic meters/second (m ³ /sec) | $\times 15,850.3$ | = gallons per minute (gpm) |
| cubic meters/hour (m ³ /hr) | × 0.5886 | = cubic feet per minute (ft^3/min) |
| cubic meters/hour (m ³ /hr) | $\times 4.403$ | = gallons per minute (gpm) |
| cubic meters/day (m ³ /day) | ×264.1720 | = gallons per day (gpd) |
| cubic meters/day (m ³ /day) | × 0.00026417 | = million gallons per day (mgd) |
| cubic meters/hectare/day (m ³ /ha/day) | | = gallons per acre per day (gal/acre/day) |
| cubic meters/square meter/day | $\times 24.5424$ | = gallons/square foot/day (gal/dt²/day) |
| (m ³ /m ² /day) liters/square meter/minute | × 0.0245 | = gallons/square foot/minute (gal/ft ² /min) |
| $(L/m^2/min)$ | | |
| liters/square meter/minute (L/m ² /min) | × 35.3420 | =gallons/square foot/day (gal/ft²/day) |

Work, Heat, and Energy

| British thermal units (Btu) | $\times 1.0551$ | = kilojoules (kJ) |
|---|--------------------|---|
| British thermal units (Btu) | $\times 0.2520$ | = kilogram-calories (kg-cal) |
| foot-pound (force) (ft-lb) | $\times 1.3558$ | = joules (J) |
| horsepower-hour (hp·hr) | $\times 2.6845$ | = megajoules (MJ) |
| watt-second (W-sec) | $\times 1.000$ | = joules (J) |
| watt-hour (W·hr) | $\times 3.600$ | = kilojoules (kJ) |
| kilowatt-hour (kW·hr) | ×3,600 | = kilojoules (kJ) |
| kilowatt-hour (kW·hr) | $\times 3,600,000$ | =joules (J) |
| British thermal units per pound (Btu/lb) | $\times 0.5555$ | = kilogram-calories per kilogram (kg-cal/kg) |
| British thermal units per cubic foot (Btu/ft ³) | × 8.8987 | = kilogram-calories/cubic meter (kg-cal/m ^{3}) |
| kilojoule (kJ) | $\times 0.9478$ | = British thermal units (Btu) |
| kilojoule (kJ) | $\times0.00027778$ | = kilowatt-hours (kW·hr) |
| kilojoule (kJ) | $\times 0.2778$ | = watt-hours (W·hr) |
| joule (J) | $\times 0.7376$ | = foot-pounds (ft-lb) |
| joule (J) | $\times 1.0000$ | = watt-seconds (W-sec) |
| joule (J) | $\times 0.2399$ | = calories (cal) |
| megajoule (MJ) | $\times 0.3725$ | = horsepower-hour $(hp \cdot hr)$ |
| kilogram-calories (kg-cal) | $\times 3.9685$ | = British thermal units (Btu) |
| kilogram-calories per kilogram (kg-cal/kg) | ×1.8000 | =British thermal units per pound (Btu/lb) |
| kilogram-calories per liter (kg-cal/L) | $\times 112.37$ | = British thermal units per cubic foot (Btu/ft ³) |
| kilogram-calories/cubic meter (kg-cal/m ³) | $\times 0.1124$ | = British thermal units per cubic foot (Btu/ft ³) |


-

- .

Velocity, Acceleration, and Force

| feet per minute (ft/min) | $\times 18.2880$ | = meters per hour (m/hr) |
|--|------------------|--|
| feet per hour (ft/hr) | $\times 0.3048$ | = meters per hour (m/hr) |
| miles per hour (mph) | $\times 44.7$ | = centimeters per second (cm/sec) |
| miles per hour (mph) | $\times 26.82$ | = meters per minute (m/min) |
| miles per hour (mph) | $\times 1.609$ | = kilometers per hour (km/hr) |
| feet/second/second (ft/sec ²) | $\times 0.3048$ | = meters/second/second (m/sec^2) |
| inches/second/second (in./sec ²) | $\times 0.0254$ | = meters/second/second (m/sec ²) |
| pounds force (lbf) | $\times 4.44482$ | = newtons (N) |
| centimeters/second (cm/sec) | $\times 0.0224$ | = miles per hour (mph) |
| meters/second (m/sec) | $\times 3.2808$ | = feet per second (ft/sec) |
| meters/minute (m/min) | $\times 0.0373$ | = miles per hour (mph) |
| meters per hour (m/hr) | $\times 0.0547$ | = feet per minute (ft/min) |
| meters per hour (m/hr) | $\times 3.2808$ | = feet per hour (ft/hr) |
| kilometers/second (km/sec) | $\times 2.2369$ | = miles per hour (mph) |
| kilometers/hour (km/hr) | $\times 0.0103$ | = miles per hour (mph) |
| $meters/second/second (m/sec^2)$ | $\times 3.2808$ | = feet/second/second (ft/sec^2) |
| $meters/second/second\ (m/sec^2)$ | $\times 39.3701$ | = inches/second/second (in./sec ²) |
| newtons (N) | $\times 0.2248$ | = pounds force (lbf) |
| | | |

CELSIUS/FAHRENHEIT COMPARISON GRAPH



| 0.555 (°F – 32) | = | degrees Celsius (°C) |
|-----------------|---|-------------------------|
| (1.8 × °C) + 32 | = | degrees Fahrenheit (°F) |
| °C + 273.15 | = | kelvin (K) |
| boiling point* | = | 212 °F |
| | = | 100 °C |
| | = | 373 K |
| freezing point* | = | 32 °F |
| | = | 0 °C |
| | = | 273 K |
| | | |

*At 14.696 psia, 101.325 kPa.

DECIMAL EQUIVALENTS OF FRACTIONS

| Fraction | Decimal | Fraction | Decimal |
|-------------------------------|---------|-------------------------------|---------|
| 1/64 | 0.01563 | ³³ / ₆₄ | 0.51563 |
| 1/32 | 0.03125 | 17/32 | 0.53125 |
| 3/64 | 0.04688 | 35/64 | 0.54688 |
| 1/16 | 0.06250 | 9/16 | 0.56250 |
| 5/64 | 0.07813 | 37/64 | 0.57813 |
| 3/32 | 0.09375 | 19 / 32 | 0.59375 |
| 7/64 | 0.10938 | ³⁹ / ₆₄ | 0.60938 |
| 1/8 | 0.12500 | 5 / 8 | 0.62500 |
| 9/64 | 0.14063 | 41/64 | 0.64063 |
| ⁵ / ₃₂ | 0.15625 | 21/32 | 0.65625 |
| 11/64 | 0.17188 | 43/64 | 0.67188 |
| 3/16 | 0.18750 | 11/16 | 0.68750 |
| 13/64 | 0.20313 | 45/64 | 0.70313 |
| 7/32 | 0.21875 | 23/ ₃₂ | 0.71875 |
| 15/64 | 0.23438 | 47/64 | 0.73438 |
| 1/4 | 0.25000 | 3/4 | 0.75000 |
| 17/64 | 0.26563 | 49/64 | 0.76563 |
| 9/ ₃₂ | 0.28125 | 25/ ₃₂ | 0.78125 |
| 19/64 | 0.29688 | ⁵¹ / ₆₄ | 0.79688 |
| 10/32 | 0.31250 | 13/16 | 0.81250 |
| 21/64 | 0.32813 | 53 / 64 | 0.82813 |
| 11/32 | 0.34375 | 27/32 | 0.84375 |
| 23/64 | 0.35938 | 55 / 64 | 0.85938 |
| 3/8 | 0.37500 | 7/8 | 0.87500 |
| ²⁵ / ₆₄ | 0.39063 | 57/64 | 0.89063 |
| 13/ ₃₂ | 0.40625 | 29/ ₃₂ | 0.90625 |
| 27/64 | 0.42188 | 59 / 64 | 0.92188 |
| 7/16 | 0.43750 | 15/16 | 0.93750 |
| 29/64 | 0.45313 | 61 / 64 | 0.95313 |
| 15/ ₃₂ | 0.46875 | 31/ ₃₂ | 0.96875 |
| 31/64 | 0.48438 | 63 / 64 | 0.98438 |
| 1/2 | 0.50000 | | |

Preface

This is the first edition of AWWA M55 *PE Pipe—Design and Installation*. The manual provides the user with both technical and general information to aid in the design, specification, procurement, installation, and understanding of the high-density polyethylene (HDPE) pipe and fittings. It is a discussion of recommended practice, not an American Water Works Association (AWWA) standard calling for compliance with certain specifications. It is intended for use by utilities and municipalities of all sizes, whether as a reference book or textbook for those not fully familiar with HDPE pipe and fittings products. Municipal and consulting engineers may use this manual in preparing plans and specifications for new HDPE pipe projects.

The manual describes HDPE pipe and fittings products and certain appurtenances, and their applications to practical installations, whether of a standard or special nature. For adequate knowledge of these products, the entire manual needs to be studied. Readers will also find the manual a useful source of information for assistance with specific or unusual conditions. The manual contains a list of applicable national standards, which may be purchased from the respective standards organizations (e.g., AWWA, ASTM, etc.). Readers should use the latest editions of the Standards that are referenced.

Credit is extended to The Plastics Pipe Institute, Inc. (www.plasticpipe.org) for its contribution to the manual.

This is a preview of "AWWA M55-2006". Click here to purchase the full version from the ANSI store.

This page intentionally blank.

Acknowledgments

The following members of the PE Manual Subcommittee and the Polyolefin Pressure Pipe and Fittings Committee helped author this new manual.

William I. Adams, W.L. Plastics, Cedar City, Utah
Will Bezner, CSR Poly Pipe Inc., Gainesville, Texas
Dudley Burwell, ISCO Industries, Huntsville, Ala.
Nancy Conley, NOVA Chemicals, Kirkland, Que.
Jim M. Craig, McElroy Manufacturing Inc., Tulsa, Okla.
Richard P. Fuerst, Bureau of Reclamation, Denver, Colo.
Larry J. Petroff, Performance Pipe, Plano, Texas
Steve D. Sandstrum, BP Solvay Polyethylene North America, Deer Park, Texas
Terry Stiles, Central Plastics Company, Shawnee, Okla.

This new manual was reviewed and approved by the PE Manual Subcommittee and the Polyolefin Pressure Pipe and Fittings Committee and included the following personnel through the time of development and approval:

Camille G. Rubeiz, Chair

W.I. Adams, W.L. Plastics, Cedar City, Utah
Will Bezner, CSR Poly Pipe Inc., Gainesville, Texas
M.G. Boyle, Pflugerville, Texas
Dudley Burwell, ISCO Industries, Huntsville, Ala.
Nancy Conley, NOVA Chemicals, Kirkland, Que.
J.D. Cox, Stockton, Calif.
J.M. Craig, McElroy Manufacturing Inc., Tulsa, Okla.
R.P. Fuerst, Bureau of Reclamation, Denver, Colo.
S.W. King, North American Pipe Corporation, Houston, Texas
L.J. Petroff, Performance Pipe, Plano, Texas
C.G. Rubeiz, Plastics Pipe Institute, Washington, D.C.
S.D. Sandstrum, BP Solvay Polyethylene North America, Deer Park, Texas
Terry Stiles, Central Plastics Company, Shawnee, Okla.
Donna Stoughton, Charter Plastics Inc., Titusville, Pa.
Harvey Svetlik, Independent Pipe Products Inc., Dallas, Texas

Michael G. Boyle, Chair

General Interest Members

J.P. Castronovo, CH2M Hill, Gainesville, Fla. K.C. Choquette, Des Moines, Iowa W.J. Dixon^{*}, Dixon Engineering Inc., Lake Odessa, Mich. D.E. Duvall, Engineering Systems Inc., Aurora, Ill.

^{*} Liaison

M.L. Magnant, Iowa Department of Public Health, Des Moines, Iowa
D.L. McPherson, MWH Americas Inc., Cleveland, Ohio
S.A. Mruk, New Providence, N.J.
Jim Paschal, Bodycote-Broutman, Ypsilanti, Mich.
J.R. Peters, M.D. Wessler & Associates Inc., Indianapolis, Ind.
J.M. Stubbart^{*}, Standards Group Liaison, AWWA, Denver, Colo.
Stanley Ziobro, FM Approvals, West Glocester, R.I.

Producer Members

W.I. Adams, W.L. Plastics, Cedar City, Utah
J.M. Craig, McElroy Manufacturing Inc., Tulsa, Okla.
L.J. Gill, Ipex Inc., Mississauga, Ont.
Scott C. Rademacher, Uponor Wirsbo Company, Apple Valley, Minn.
C.G. Rubeiz, Plastic Pipe Institute, Washington, D.C.
Harvey Svetlik, Independent Pipe Products Inc., Dallas, Texas

User Members

M.G. Boyle, Pflugerville, Texas
O.J. Duane Cox, Stockton, Calif.
M.R. Falarski, East Bay Municipal Utility District, Oakland, Calif.
R.P. Fuerst, Bureau of Reclamation, Denver, Colo.
W.F. Guillaume, Orlando, Fla.

^{*} Liaison

AWWA MANUAL M55



Chapter

Engineering Properties of Polyethylene

INTRODUCTION

A fundamental understanding of material characteristics is an inherent part of the design process for any piping system. With such an understanding, the piping designer can use the properties of the material to design for optimum performance. This chapter provides basic information that should assist the reader in understanding how polyethylene's (PE's) material characteristics influence its engineering behavior.

PE is a thermoplastic, which means that it is a polymeric material that can be softened and formed into useful shapes by the application of heat and pressure and which hardens when cooled. PE is a member of the polyolefins family, which also includes polypropylene. As a group of materials, the polyolefins generally possess low water absorption, moderate to low gas permeability, good toughness and flexibility at low temperatures, and a relatively low heat resistance. PE plastics form flexible but tough products and possess excellent resistance to many chemicals.

POLYMER CHARACTERISTICS

In general terms, the performance capability of PE in piping applications is determined by three main parameters: density, molecular weight, and molecular weight distribution. Each of these polymer properties has an effect on the physical performance associated with a specific PE resin. The general effect of variation in these three physical properties as related to polymer performance is shown in Table 1-1.

Density

PE is a semicrystalline polymer composed of long, chain-like molecules of varying lengths and numbers of side branches. As the number of side branches increases, polymer crystallinity and hence, density decreases because the molecules cannot pack as