



**American Water Works  
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA B402-06  
(Revision of ANSI/AWWA B402-00)

---

---

*AWWA Standard*

---

---

# Ferrous Sulfate

Effective date: Feb. 1, 2007.

First edition approved by AWWA Board of Directors June 2, 1968.

This edition approved Jan. 11, 2006.

Approved by American National Standards Institute Aug. 31, 2006.

---

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

Advocacy  
Communications  
Conferences  
Education and Training  
► **Science and Technology**  
Sections

## ***AWWA Standard***

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## ***American National Standard***

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

**CAUTION NOTICE:** The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

---

## ***Science and Technology***

---

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2006 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA Standards Committee on Iron Salts, Aluminum Salts, and Related Coagulant Aids, which reviewed and approved this standard, had the following personnel at the time of approval:

John P. Corless, *Chair*  
Gene Shull, *Vice Chair*

### *User Members*

B.S. Aptowicz, Philadelphia Water Department, Philadelphia, Pa.	(AWWA)
T.A. Barber Jr., Coca-Cola Company, Atlanta, Ga.	(AWWA)
J.P. Corless, U.S. Naval Reserve, Rockville, Md.	(AWWA)
L.V. Landry, City of Shreveport, Shreveport, La.	(AWWA)
C.A. Owen, Tampa Bay Water, Clearwater, Fla.	(AWWA)
J.S. Trotter, City of Bloomington Utilities, Bloomington, Ind.	(AWWA)
D.P. Wolz, Clean Water Plant, Wyoming, Mich.	(AWWA)

### *General Interest Members*

M.B. Alvarez, CH2M Hill, Orlando, Fla.	(AWWA)
K.K. Au, Greeley & Hansen, Chicago, Ill.	(AWWA)
D.T. Duke, Bloomington, Ind.	(AWWA)
J.D. Edwards, Burgess & Niple Ltd., Columbus, Ohio	(AWWA)
J.J. Gemin, Earth Tech (Canada) Inc., Kitchener, Ont., Canada	(AWWA)
R.H. Hargette, Black & Veatch Engineers, Greenville, S.C.	(AWWA)
R.D. Harriger, Williamsburg, Va.	(AWWA)
C.B. Lind, Mauser Corporation., Bridgewater, N.J.	(AWWA)
C.L. McLain,* Moorhead Public Service, Moorhead, Minn.	(AWWA)
P.J. Olson,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)

---

\*Liaison, nonvoting

J.W. Patterson, J.W. Patterson Environmental Consultants, Silverthorne, Colo.	(AWWA)
L.W. VandeVenter, Metcalf & Eddy Inc., Wakefield, Mass.	(AWWA)
B.H. Wilder, Daytona Beach, Fla.	(AWWA)

*Producer Members*

J.E. Brown, Southern Ionics Inc., Whitney, Texas	(AWWA)
J.P. Crass, Eaglebrook Inc., Ventura, Calif.	(AWWA)
J.M. Gonzalez, PVS Technologies Inc., South New Berlin, N.Y.	(AWWA)
D.E. Gordon, QC Corporation Ltd., Baltimore, Md.	(AWWA)
L.N. Hjersted,* Kemiron Inc., Bartow, Fla.	(AWWA)
B. Keogh, Dundas, Ont., Canada	(AWWA)
K.E. Ruehl, General Chemical Corporation, Ballwin, Mo.	(AWWA)
G. Shull, Kemiron Inc., Bacliff, Texas	(AWWA)

---

\*Alternate

# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.		PAGE	SEC.		PAGE
<b><i>Foreword</i></b>					
I	Introduction.....	vii	1.3	Application .....	1
I.A	Background.....	vii	2	<b>References</b> .....	2
I.B	History.....	viii	3	<b>Definitions</b> .....	2
I.C	Acceptance .....	viii		<b>Requirements</b>	
II	Special Issues.....	ix	4	Physical Requirements .....	2
II.A	Storage and Handling Precautions....	ix	4.1	Chemical Requirements .....	3
II.B	Basis for Payment .....	x	4.2	Impurities .....	3
III	Use of This Standard .....	x	4.3		
III.A	Purchaser Options and Alternatives ...	x	5	<b>Verification</b>	
III.B	Modification to Standard.....	xi	5.1	Sampling.....	4
IV	Major Revisions .....	xi	5.2	Test Procedures.....	5
V	Comments .....	xi	5.3	Basis for Rejection .....	9
<b><i>Standard</i></b>					
1	<b>General</b>		6	<b>Delivery</b>	
1.1	Scope .....	1	6.1	Marking.....	9
1.2	Purpose .....	1	6.2	Packaging and Shipping.....	10
			6.3	Affidavit of Compliance.....	11

This page intentionally blank.

## Foreword

*This foreword is for information only and is not a part of ANSI/AWWA B402.*

### I. Introduction.

I.A. *Background.* In 1903, the use of ferrous sulfate ( $\text{FeSO}_4$ ) as a coagulant was introduced in the United States in Quincy, Ill., by William B. Bull. Lime was used in conjunction with ferrous sulfate because it aided in the oxidation and precipitation of the iron as ferric hydroxide. The first large city to use this combination was St. Louis, Mo., in 1904. "This was done in great haste in order that the visitors to the St. Louis Exposition might not be repelled by the turbid water which St. Louisans put up with since Kirkwood's recommendation for sedimentation and slow sand filtration was ruthlessly thrust aside in 1866. A permanent plant was soon built. Next among the large cities to use sulfate of iron and lime were Cincinnati, 1907, and New Orleans, 1909."\*

The combination of ferrous sulfate and lime is an effective coagulant for the clarification of turbid raw waters. Ferrous sulfate is also used as a base material for the preparation of chlorinated copperas, another effective coagulant used for the treatment of some waters. Chlorinated copperas is formed by reacting ferrous sulfate ( $\text{FeSO}_4 \cdot 7\text{H}_2\text{O}$ ) with chlorine in the ratio of 7:1. Chlorine solution is added to a solution of ferrous sulfate, usually in an enlarged pipe section that serves as a retention tank and permits complete oxidation of the ferrous sulfate to the ferric form.

Ferrous sulfate is produced as a co-product in the manufacture of certain metals and compounds, such as titanium dioxide. The principal sources providing the greatest quantity of ferrous sulfate are the sulfate process for the manufacture of titanium dioxide and the spent sulfuric acid solutions from the pickling of steel, known as pickle liquor. For shipping, solutions made from these two sources are reduced to moist and dried crystalline forms. For applications, they are dissolved and applied to water through chlorine oxidizers or with lime. Moist ferrous sulfate crystals are produced in a heptahydrate form ( $\text{FeSO}_4 \cdot 7\text{H}_2\text{O}$ ) containing up to 10 percent free moisture and 17 to 19 percent iron. This form of ferrous sulfate is not free flowing and is generally used in large quantities for water

---

\*Baker, M.N., 1948. *The Quest for Pure Water*, ANSI/AWWA, Denver, Colo.

treatment. Dried ferrous sulfate, which is produced by dehydrating moist ferrous sulfate crystals, can be obtained in two hydrate forms—heptahydrate ( $\text{FeSO}_4 \cdot 7\text{H}_2\text{O}$ ) containing 19.5 to 20.5 percent iron and monohydrate ( $\text{FeSO}_4 \cdot 1\text{H}_2\text{O}$ ) containing 29 to 31 percent iron. The practice of shipping “pickle liquor” in liquid form began in about 1965 and is still largely confined to areas within reasonable hauling distance of heavy-steel producers. Today, liquid ferrous sulfate, produced by dissolving moist or dried crystals, contains less free sulfuric acid than “pickle liquor.” Because of transportation costs, it is generally sold within a 250-mi (402-km) radius of suppliers. Liquid ferrous sulfate normally contains a minimum of 5.5 percent ferrous iron or 0.5 lb of ferrous iron per gal of liquid ferrous sulfate solution ( $60 \text{ kg/m}^3$ ).

I.B. *History.* The first edition of this standard was prepared by the AWWA Committee on Ferrous Sulfate and was approved by the AWWA Board of Directors on June 2, 1968. Subsequent revisions to ANSI/AWWA B402 were prepared by the AWWA Standards Committee on Iron Salts, Aluminum Salts, and Related Coagulant Aids and approved on Jan. 27, 1985, Jan. 28, 1990, Jan. 22, 1995, and June 11, 2000. This sixth edition was approved by the AWWA Board of Directors on June 11, 2006.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.\* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the

---

\*Persons outside the United States should contact the appropriate authority having jurisdiction.

direction of NSF, NSF<sup>\*</sup>/ANSI<sup>†</sup> 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B402 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of greater concern. The language in Sec. 4.3.2 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

## II. Special Issues.

II.A. *Storage and Handling Precautions.* Moist ferrous sulfate heptahydrate has a tendency to compact or cake in storage and has to be contained to prevent any leakage of liquid ferrous sulfate, necessitating increased handling requirements. The particle sizes and particle-size distributions of dried ferrous sulfate heptahydrate are important if the material is to be stored for extended periods and then fed by mechanical conveying equipment. The smaller the particles, the more readily the

---

<sup>\*</sup>NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

<sup>†</sup>American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

compound will compact or cake in storage. Caking is an impediment to feeding with conventional dry-conveying equipment. Heterogeneous particle size is also undesirable for feeding. In general, the cost of ferrous sulfate increases as particle coarseness and uniformity increase. Particle size is of little importance if the compound is to be dissolved and stored in an aqueous solution.

Ferrous sulfate monohydrate will not cake in storage if the material is maintained in a dry storage area. Because of its concentrated state, monohydrate normally takes longer to dissolve into a solution than does heptahydrate even though both forms of ferrous sulfate are equally soluble.

For safety precautions, refer to material safety data sheets (MSDS) available from the supplier or manufacturer.

**II.B. *Basis for Payment.*** The basis for payment when purchasing moist and dried ferrous sulfate according to this standard is the net weight of the ferrous sulfate supplied, excluding the weight of the container. One ton (907 kg) of dried ferrous sulfate heptahydrate containing 19.5 percent soluble iron is equivalent to 0.67 tons (608 kg) of dried ferrous sulfate monohydrate containing 29 percent soluble iron.

The basis for payment for liquid ferrous sulfate purchased according to this standard is the quantity equal to the number of tons equivalent to dried ferrous sulfate containing 19.5 percent soluble iron. This is calculated by determining the total soluble-iron content of the liquid ferrous sulfate and dividing the weight (in tons) of the liquid ferrous sulfate received by the ratio of 19.5 to the percentage of total soluble iron in the liquid. For example, if 10 tons (9,070 kg) of liquid ferrous sulfate are received with a total soluble-iron content of 7.5 percent, then calculate  $19.5/7.5 = 2.6$  and  $10/2.6 = 3.85$ . Therefore, 3.85 tons (3,493 kg) of dried ferrous sulfate heptahydrate containing 19.5 percent total soluble iron is equivalent to 10 tons (9,070 kg) of liquid ferrous sulfate containing 7.5 percent total soluble iron.

**III. Use of This Standard.** It is the responsibility of the user of an ANSI/AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

**III.A. *Purchaser Options and Alternatives.*** The following items should be specified by the purchaser:

1. Standard used—that is, ANSI/AWWA B402, Standard for Ferrous Sulfate, of latest revision.
2. Type of ferrous sulfate to be supplied (moist heptahydrate, dried heptahy-

drate, dried monohydrate, or liquid).

3. Whether compliance with NSF/ANSI 60 Drinking Water Treatment Chemicals—Health Effects, is required.

4. The requirements should state if an analysis by a certified laboratory for the presence of barium, cadmium, chromium, mercury, nitrate, nitrite, selenium, antimony, berillium, cyanide, nickel, thallium, and manganese is required.

5. If liquid ferrous sulfate is required, the quantity equal to the number of tons equivalent to dried ferrous sulfate containing 19.5 percent soluble iron (Sec. II.B).

6. Particle size required for dried ferrous sulfate, if different from that specified in Sec. 4.1.

7. If an analysis by a referee laboratory is required, the assignment of testing costs (Sec. 5.3.1).

8. If dried ferrous sulfate is required, the quantity, container size, type, and method of shipping (Sec. 6.2.1).

9. If liquid ferrous sulfate in tank cars is required, whether or not steam coils for heating before unloading are required (Sec. 6.2.2).

10. Affidavit of compliance, certified analysis, or both, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. **Major Revisions.** Major changes made to the standard in this revision include the following:

1. A definition of *day* has been added to the standard to clarify the time period for completion of lab testing and notification of nonconformance (Section 2).

2. The time period to complete laboratory testing after receipt of shipment has been clarified (Sec. 5.2).

3. The time periods for notification of nonconformance and for supplier response have been clarified (Sec. 5.3.1).

V. **Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer & Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail [standards@awwa.org](mailto:standards@awwa.org).

This page intentionally blank.



American Water Works  
Association

ANSI/AWWA B402-06  
(Revision of ANSI/AWWA B402-00)

---

---

## *AWWA Standard*

---

---

# Ferrous Sulfate

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard describes ferrous sulfate ( $\text{FeSO}_4$ ) in moist, dried, and solution (liquid) forms for water supply service application.

### Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for ferrous sulfate, including physical, chemical, packaging, shipping, and testing requirements.

### Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving ferrous sulfate and can be used as a guide for testing the physical and chemical properties of ferrous sulfate samples. The stipulations of this standard apply when this document has been referenced and only to ferrous sulfate used in water supply service applications.