



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA B502-11
(Revision of ANSI/AWWA B502-05)

AWWA Standard

Sodium Polyphosphate, Glassy (Sodium Hexametaphosphate)



Effective date: June 1, 2011.

First edition approved by AWWA Board of Directors June 1, 1967.

This edition approved Jan. 23, 2011.

Approved by American National Standards Institute April 8, 2011.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2011 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Scale and Corrosion-Control Chemicals, which reviewed and approved this standard, had the following personnel at the time of approval:

Robert A. Ryder, *Chair*

General Interest Members

| | |
|---|--------|
| J.H. Bambei, Jr.,* Denver Water, Denver, Colo. | (AWWA) |
| M.P. Chaulk, CBCL Limited Consultants Ltd., Halifax Regional Municipality, N.S. | (AWWA) |
| M.S. McFadden, HDR Engineering Inc., Bellevue, Wash. | (AWWA) |
| D. Orozco, Cole & Associates Engineers, Safety Harbor, Fla. | (AWWA) |
| R.A. Ryder, Kennedy/Jenks Consultants, San Francisco, Calif. | (AWWA) |
| S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo. | (AWWA) |
| R. Vaidya, Camp Dresser & McKee, Tampa, Fla. | (AWWA) |

Producer Members

| | |
|--|--------|
| H.T. Belcher Jr., Corrtac Systems Corporation, Currituck, N.C. | (AWWA) |
| C.P. Principi, Carus Corporation, Belmont, N.C. | (AWWA) |
| V.J. Verdone, Pristine Water Solutions Inc., Waukegan, Ill. | (AWWA) |
| Y. Zhang, DXV Water Technologies Inc., Tustin, Calif. | (AWWA) |

User Members

| | |
|--|--------|
| E.J. Kiefer, North Shore Water Commission, Milwaukee, Wis. | (AWWA) |
| R.M. Powell, Pinellas County Utilities, Largo, Fla. | (AWWA) |
| J.C. Thurrott, City of Daytona Beach, Daytona Beach, Fla. | (AWWA) |

* Liaison, nonvoting

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

| SEC. | PAGE | SEC. | PAGE |
|-----------------|----------------------------------|----------|--|
| Foreword | | 1.3 | Application..... 1 |
| I | Introduction..... vii | 2 | References 2 |
| I.A | Background..... vii | 3 | Definitions 2 |
| I.B | History..... vii | 4 | Requirements |
| I.C | Acceptance..... vii | 4.1 | Physical Requirements..... 3 |
| II | Special Issues..... viii | 4.2 | Chemical Requirements 4 |
| II.A | Storage and Handling | 4.3 | Impurities..... 5 |
| | Precautions..... viii | 5 | Verification |
| III | Use of This Standard..... ix | 5.1 | Sampling..... 5 |
| III.A | Purchaser Options and | 5.2 | Test Procedures 6 |
| | Alternatives ix | 5.3 | Notice of Nonconformance..... 8 |
| III.B | Modification to Standard..... ix | 6 | Delivery |
| IV | Major Revisions..... ix | 6.1 | Marking..... 9 |
| V | Comments ix | 6.2 | Packaging and Shipping 9 |
| | | 6.3 | Affidavit of Compliance or Certified Analysis..... 10 |
| Standard | | | |
| 1 | General | | |
| 1.1 | Scope 1 | | |
| 1.2 | Purpose 1 | | |

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA B502.*

I. Introduction.

I.A. *Background.* Sodium polyphosphate, glassy ($\text{Na}_{n+2} \text{P}_n \text{O}_{n+1}$, $n = 12-16$ or $18-21$), is a manufactured product obtained by combining comparatively pure chemicals—soda ash (Na_2CO_2) or caustic soda (NaOH)—with phosphoric acid. Although the resulting product is consistent in quality and content, each manufacturer may produce it in several different physical forms (Section 4). The density of crushed or granular material is approximately 80 lb/ft^3 (approximately $1,280 \text{ kg/m}^3$). A solution of 2 lb/gal (0.24 kg/L) has a specific gravity of approximately 1.2.

The uses of sodium polyphosphate, glassy, include corrosion control, scale prevention, iron and manganese stabilization, and sequestering of metallic ions. The chemical is available in a wide range of physical forms and sizes, allowing flexibility in the type of dissolving or feeding apparatus to be used.

I.B. *History.* The first edition of AWWA B502 was approved as tentative on Jan. 23, 1966. It was approved as a standard on June 1, 1967, and published as AWWA B502-67. Subsequent revisions were approved by the AWWA Board of Directors as ANSI/AWWA B502-78, ANSI/AWWA B502-83, ANSI/AWWA B502-88, ANSI/AWWA B502-94, ANSI/AWWA B502-01, and ANSI/AWWA B502-05. This edition was prepared by the AWWA Standards Committee on Scale and Corrosion-Control Chemicals and was approved on Jan. 23, 2011.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now Water Research Foundation[†]) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† Water Research Foundation, 6666 W. Quincy Ave., Denver, CO 80235.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF†/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B502 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or to residual solids is becoming a problem of great concern. The language in Sec. 4.3.3 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60 Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Storage and Handling Precautions.* Sodium polyphosphate, glassy, is hygroscopic in nature and must be stored under dry conditions. Exposure to humidity produces a sticky film on the exposed material. This results in poor flow and in caking, which interfere with the rate of dissolution of the product. Refer to material safety data

* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

sheets (MSDS) available from the chemical supplier or manufacturer for additional information.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser.

1. Standard used—that is, ANSI/AWWA B502, Sodium Polyphosphate, Glassy (Sodium Hexametaphosphate), of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Details of other federal, state, or provincial, and local requirements (Section 4).
4. Physical form(s) and quantity (Sec. 4.1.1).
5. Specific maximum impurity content limits, if required (Sec. 4.3).
6. Whether the purchaser will reject product from containers or packaging with missing or damaged seals. The purchaser may reject product from bulk containers or packages with missing or damaged seals unless the purchaser's tests of representative samples, conducted in accordance with Sec. 5.2, demonstrate that the product meets the standard. Failure to meet the standard or the absence of, or irregularities in, seals may be sufficient cause to reject a shipment.
7. Form of shipment—bulk or package, type, and size of container (Sec. 6.2.1).
8. Whether alternative security measures have been adopted to replace or augment the security measures set out in Sec. 6.2.3 and 6.2.4.
9. Affidavit of compliance, certified analysis, or both, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major changes made to the standard in this revision include the following:

1. Inclusion of a requirement for compliance with the Safe Drinking Water Act and other federal regulations.
2. Inclusion of a requirement for tamper-evident packaging (Sec. 6.2.3 and 6.2.4).

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.

This page intentionally blank.



**American Water Works
Association**

AWWA Standard

Sodium Polyphosphate, Glassy (Sodium Hexametaphosphate)

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes sodium polyphosphate, glassy, for use in the treatment of potable water, wastewater, and reclaimed water. This material is also known as sodium hexametaphosphate, sodium tetrapolyphosphate, and Graham's salt.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for sodium polyphosphate, glassy, including physical, chemical, sampling, packaging, shipping, and testing requirements.

Sec. 1.3 Application

This standard can be referenced in documents for purchasing and receiving sodium polyphosphate, glassy, and can be used as a guide for testing the physical and chemical properties of sodium polyphosphate, glassy, samples. The stipulations of this standard apply when this document has been referenced and only to sodium polyphosphate used in the treatment of potable water, wastewater, and reclaimed water.