



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA B512-15
(Revision of ANSI/AWWA B512-08)

AWWA Standard

Sulfur Dioxide

Effective date: May 1, 2015.
First edition approved by AWWA Board of Directors Jan. 27, 1991.
This edition approved Jan. 24, 2015.
Approved by American National Standards Institute Jan. 28, 2015.




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal - American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal - American Water Works Association* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org.



ISBN-13, print: 978-1-62576-078-4

eISBN-13, electronic: 978-1-61300-332-9

DOI: <http://dx.doi.org/10.12999/AWWA.B512.15>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2015 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Taste and Odor Control Chemicals, which reviewed and approved this standard, had the following personnel at the time of approval:

Nathan K. Dunahee, *Chair*

General Interest Members

N.K. Dunahee, Burns & McDonnell, Kansas City, Mo.	(AWWA)
T.E.T. Gillogly, Carollo Engineers, Miami, Fla.	(AWWA)
C.B. Lind, Mauser Corporation, East Brunswick, N.J.	(AWWA)
S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
B.H. Wilder, Daytona Beach, Fla.	(AWWA)

Producer Members

J.E. Boll, Carus Chemical Co., Peru, Ill.	(AWWA)
J.M. Gonzalez, South New Berlin, N.Y.	(AWWA)

User Members

M. Ramon, City of Houston, Houston, Texas	(AWWA)
R. Sparks, City Utilities of Springfield, Springfield, Mo.	(AWWA)
P. Zielinski, Pennsylvania American Water, Hershey, Pa.	(AWWA)

* Liaison, nonvoting.

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		2	References2
I	Introduction.....vii	3	Definitions2
I.A	Background.....vii	4	Requirements
I.B	History.....viii	4.1	Physical Requirements.....3
I.C	Acceptance.....viii	4.2	Chemical Requirements3
II	Special Issues.....ix	4.3	Impurities.....3
II.A	Safety and Accidental Release Reporting.....ix	5	Verification
III	Use of This Standard.....ix	5.1	Sampling.....4
III.A	Purchaser Options and Alternativesx	5.2	Laboratory Examination.....5
III.B	Modification to Standardx	5.3	Test Procedures for Sulfur Dioxide, Nonvolatile Residue, Moisture, and Heavy Metals6
IV	Major Revisions.....x	5.4	Basis for Shipment and Acceptance7
V	Commentsx	5.5	Notice of Nonconformance8
Standard		6	Delivery
1	General	6.1	Marking.....9
1.1	Scope1	6.2	Packaging and Shipping9
1.2	Purpose1	6.3	Affidavit of Compliance10
1.3	Application.....1		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA B512.*

I. Introduction.

I.A. *Background.* Sulfur dioxide (SO₂), or sulfurous oxide, is a colorless, nonflammable, pungent, suffocating gas. This reducing agent is widely used to remove chlorine and other oxidants from water. Sulfur dioxide is corrosive to mild steel if moisture is present.

Sulfur dioxide is manufactured by burning sulfur in air or from the roasting and smelting of sulfide ores. Generally, sulfur dioxide is purified by using intricate scrubbing methods to remove metal impurities. The sulfur dioxide gas is compressed to form liquid sulfur dioxide, which can then be fed either as a liquid or as a gas. Sulfur dioxide liquid or gas is commercially available at nominally 100 percent strength.

Sulfur dioxide dosage for dechlorination is based on the level of residual chlorine to be removed. The required theoretical dosage for dechlorination is 0.9 mg/L of SO₂ per 1.0 mg/L of residual chlorine (not chlorine dosage). In practice, a ratio of 1:1 is generally used.

Sulfur dioxide mixed with water reacts almost instantaneously with chlorine, converting the chlorine (Cl₂) to chloride (Cl⁻) and the residual sulfur dioxide to sulfate (SO₄²⁻).

When plant capacity is expressed in million gallons per day (mgd), the sulfur dioxide feed rate in pounds per day (lb/d) can be calculated using the following formula:

$$\text{SO}_2 \text{ lb/d} = \text{Cl}_2 \text{ residual ppm} \times 8.34 \times \text{mgd of plant}$$

The following properties of sulfur dioxide (SO₂) may be useful:

Odor	Pungent
Melting point	-99°F (-72.7°C)
Boiling point at atmosphere	14.0°F (-10°C)
Specific gravity of liquid at 0°C (water = 1)	1.434
Specific gravity at 80°F (27°C)	1.363
Critical temperature	314.8°F (174.9°C)
Molecular weight	64.06

For additional information on chemical and physical properties and safety information, refer to the technical information and material safety data sheet/safety data

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

sheet (MSDS/SDS) available from the supplier or manufacturer and the Compressed Gas Association's (CGA's) booklet CGA G-3, Sulfur Dioxide.*

I.B. *History.* The first edition of ANSI/AWWA B512, Sulfur Dioxide, was developed by the AWWA Standards Committee on Taste and Odor Control Chemicals and approved by the AWWA Board of Directors on Jan. 27, 1991, with an effective date of June 1, 1991. Subsequent editions of ANSI/AWWA B512 were approved on June 15, 1997, Jan. 20, 2002, and Jan. 27, 2008. This edition was approved on Jan. 24, 2015.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.† Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF‡: NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

* Compressed Gas Association, 4221 Walney Road, 5th Floor, Chantilly, VA 20151.

† Persons outside the United States should contact the appropriate authority having jurisdiction.

‡ NSF International, 789 North Dixboro Road, Ann Arbor, MI 48113.

ANSI/AWWA B512 addresses additives requirements in Sec. 4.3.2 of the standard. The transfer of contaminants from chemicals to processed water or to residual solids is becoming a problem of great concern. The language in Sec. 4.3.2 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, *Drinking Water Treatment Chemicals—Health Effects*. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Safety and Accidental Release Reporting.* Sulfur dioxide is a colorless, nonflammable, pungent gas or liquid with a vapor density of 2.26. Sulfur dioxide reacts with water or free moisture to form sulfurous acid, which is corrosive.

The odor threshold for sulfur dioxide is usually from 0.3 ppm to 2.5 ppm. Levels of 20 ppm usually cause coughing, while short exposures to 400 ppm to 500 ppm may be fatal. The Occupational Safety and Health Administration (OSHA) has set the permissible exposure level for sulfur dioxide* at 2 ppm as the 8-hr–time weighted average and 5 ppm as the short-term exposure level because sulfur dioxide is irritating to the respiratory system. Sulfur dioxide is corrosive to the eyes and skin and causes burns.

When handling sulfur dioxide, wear chemical safety glasses, rubber gloves, and rubber protective clothing. For additional information, study the supplier's material safety data sheet (MSDS).

Emergency release of sulfur dioxide is reportable under the US Comprehensive Environmental Response Compensation and Liability Act of 1980, Sec. 302.† At present, the reportable quantity of sulfur dioxide is 1 lb.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

* Code of Federal Regulations, Title 29, Part 1910, Superintendent of Documents, US Government Printing Office, Washington, DC 20402.

† Code of Federal Regulations, Title 40, Part 300, Superintendent of Documents, US Government Printing Office, Washington, DC 20402.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA B512, Sulfur Dioxide, of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Details of other federal, state or provincial, and local requirements (Section 4).
4. The grade or purity required (see Sec. 4.1, 4.2, and 4.3).
5. Whether the purchaser will reject product from containers or packaging with missing or damaged seals. The purchaser may reject product from bulk containers or packages with missing or damaged seals unless the purchaser's tests of representative samples, conducted in accordance with Sec. 5.1 through Sec. 5.3, demonstrate that the product meets the standard. Failure to meet the standard or the absence of, or irregularities in, seals may be sufficient cause to reject the shipment.
6. If the purchaser desires to sample and analyze shipments received, agreement with the supplier as to the number of samples to be taken is necessary (Sec. 5.1.3.1).
7. If required, an affidavit of compliance or certificate of analysis (Sec. 5.4 and 6.3).
8. Size of containers (Sec. 6.2).
9. Quantity required (see Sec. 6.2.1.1).
10. Whether alternative security measures have been adopted to replace or augment the security measures set out in Sec. 6.2.2 and 6.2.3.

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. Inclusion of the use of this material for wastewater and reclaimed water as well as definitions of these terms (Sections 1 and 3).

V. Comments. If you have any comments or questions about this standard, please contact AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA B512-15
(Revision of ANSI/AWWA B512-08)

AWWA Standard

Sulfur Dioxide

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes sulfur dioxide, a compressed, nonflammable liquefied gas, for use in the treatment of potable water, wastewater, or reclaimed water to remove excess residual chlorine.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for sulfur dioxide, including physical, chemical, sampling, testing, packaging, and shipping requirements.

Sec. 1.3 Application

This standard can be referenced in documents for purchasing and receiving sulfur dioxide and can be used as a guide for testing the physical and chemical properties of sulfur dioxide samples. The stipulations of this standard apply when this document has been referenced and then only to sulfur dioxide used in the treatment of potable water, wastewater, or reclaimed water.