



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA B550-10
(Revision of ANSI/AWWA B550-05)

AWWA Standard

Calcium Chloride



Effective date: Aug. 1, 2010.

First edition approved by AWWA Board of Directors June 23, 1985.

This edition approved Jan. 17, 2010.

Approved by American National Standards Institute June 14, 2010.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

*Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections*

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Softening and Conditioning Chemicals, which reviewed and approved this standard, had the following personnel at the time of approval:

Clyde R. Dugan, *Chair*

General Interest Members

R.J. Casale,* American Water, Voorhees, N.J.	(AWWA)
W.J. Conlon, Parsons Brinckerhoff, Tampa, Fla.	(AWWA)
T.O. Crowley, Carollo Engineers, Lee's Summit, Mo.	(AWWA)
S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
M.H. Winegard, Consoer Townsend Envirodyne, Wheaton, Ill.	(AWWA)

Producer Members

J. Althouse, Dow Chemical Company, Ludington, Mich.	(AWWA)
E.W. Coyner, National Lime Association, Arlington, Va.	(AWWA)
W.B. Huebner, Mine Hill, N.J.	(AWWA)
J.M. Shepard, Middletown, Del.	(AWWA)

User Members

I. Alvarez,† John Preston Water Plant, Hialeah, Fla.	(AWWA)
C.R. Dugan, Bath, Mich.	(AWWA)
P.M. Marchand, Providence Water Supply Board, Providence, R.I.	(AWWA)
G.C. Rosati, City of Mankato Public Utilities, Mankato, Minn.	(AWWA)
A.T. Segars, Miami-Dade Water & Sewer Department, Hialeah, Fla.	(AWWA)
J.C. Thurrott, City of Daytona Beach, Daytona Beach, Fla.	(AWWA)
D.A. Visintainer, St. Louis, Mo.	(AWWA)
B.H. Wilder, Daytona Beach, Fla.	(AWWA)

* Liaison, nonvoting

† Alternate

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>		1.3	Application..... 1
I	Introduction..... vii	2	References 2
I.A	Background..... vii	3	Definitions 2
I.B	History..... vii	4	Requirements
I.C	Acceptance..... vii	4.1	Materials 3
II	Special Issues..... ix	4.2	Physical Requirements..... 3
II.A	Storage and Handling	4.3	Chemical Requirements 3
	Precautions..... ix	4.4	Impurities..... 4
III	Use of This Standard..... ix	5	Verification
III.A	Purchaser Options and	5.1	Sampling..... 4
	Alternatives ix	5.2	Test Procedures 5
III.B	Modification to Standard x	5.3	Notice of Nonconformance 7
IV	Major Revisions..... x	6	Delivery
V	Comments x	6.1	Marking..... 8
		6.2	Packaging and Shipping 8
		6.3	Affidavit of Compliance 10
<i>Standard</i>			
1	General		
1.1	Scope 1		
1.2	Purpose 1		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA B550.*

I. Introduction.

I.A. *Background.* Calcium chloride, CaCl_2 , is produced in various states of hydration, all of which are highly deliquescent (that is, they dissolve in the water absorbed). It is obtained commercially from natural brines as a by-product of soda ash manufacture or by the reaction of calcium carbonate and hydrochloric acid.

Calcium chloride is used in water treatment as a source of soluble calcium where its addition is needed but a substantial increase in pH or alkalinity is undesirable. It can also be used to increase the calcium ion concentration in waters with high alkalinity and high sodium ion content or in waters with acceptable magnesium ion concentrations and high alkalinities. These waters can then be softened by the addition of lime, therefore reducing the alkalinity to acceptable levels. In classic municipal lime softening, this practice would be counterproductive, but for the previously mentioned uses, it is essential. Calcium chloride is less frequently used as a coagulant aid in certain waters.

I.B. *History.* Authorization for the development of this standard was given by the AWWA Standards Council in 1982. The first edition of the standard was developed by the AWWA Standards Committee on Quicklime, Hydrated Lime, and Calcium Chloride and was approved by the AWWA Board of Directors on June 23, 1985, with an effective date of Dec. 1, 1985. In 1988, the Softening and Conditioning Chemicals Committee assumed responsibility for maintaining and updating the standard. The second edition was approved on Jan. 28, 1990, and had an effective date of Sept. 1, 1990. ANSI/AWWA B550-96 was approved on Feb. 4, 1996. ANSI/AWWA B550-00 was approved on Jan. 23, 2000. ANSI/AWWA B550-05 was approved on Jan. 16, 2005. This edition was approved on Jan. 17, 2010.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now Water Research Foundation) and the Conference of State

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF†/ANSI‡ 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B550 addresses additives requirements in Sec. 4.4 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of great concern. The language in Sec. 4.4.4 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60 Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Rd., Ann Arbor, MI 48105.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

II. Special Issues.

II.A. *Storage and Handling Precautions.* Calcium chloride is hygroscopic (that is, it absorbs moisture from the atmosphere) and deliquescent. It should be stored in a dry place. Calcium chloride dust will rapidly absorb moisture until it is in solution.

Calcium chloride is usually dissolved in water and fed into the treatment process in solution form. Solutions may be corrosive to copper, brass, mild iron, steel, and some stainless steels. Calcium chloride will attack yellow brass and aluminum. Most synthetic rubbers, plastics, stainless steels designed for high-chloride service, and fiberglass are adequate for solution handling and storage.

When calcium chloride is dissolved in water, heat is liberated. Preparation of a 40 percent, by weight, calcium chloride solution (75 percent calcium chloride dihydrate) may increase the original water temperature by approximately 84°F (29°C). A similar 40 percent, by weight, solution prepared with anhydrous calcium chloride may increase the original water temperature by approximately 158°F (70°C). In the interest of safety and to avoid the capital cost of high-temperature equipment, hot water should not be used for dissolution.

For safety information, refer to material safety data sheets (MSDS) available from the supplier or manufacturer.

III. **Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser.

1. Standard used—that is, ANSI/AWWA B550, Standard for Calcium Chloride, of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Details of other federal, state or provincial, and local requirements (Sec. 4.1).
4. Quantity, form, and size required (Sec. 4.2).
5. Percent-available calcium chloride required (Sec. 4.3). Refer to the note at the end of this section.
6. Limit on insoluble matter if other than 0.5 percent, by weight (Sec. 4.4.2).
7. Whether the purchaser will reject product from containers or packaging with missing or damaged seals. The purchaser may reject product from bulk containers or packages with missing or damaged seals unless the purchaser's tests of representative samples, conducted in accordance with Sec. 5.2, demonstrate that the product meets

the standard. Failure to meet the standard or the absence of, or irregularities in, seals may be sufficient cause to reject the shipment.

8. Whether alternative security measures have been adopted to replace or augment the security measures set out in Sec. 6.2.3 and 6.2.4.

9. Form of shipment—bulk or package, type, and size of container (Sec. 6.2).

10. Basis of payment (Sec. 6.2.2.2).

11. If an affidavit of compliance or certified analysis or both is required. (Sec. 6.3)

NOTE: When purchasing calcium chloride according to the provisions of this standard, the purchaser must state the percent-available calcium chloride required. The purchase of calcium chloride should be based on percent-available calcium chloride. A minimum of 75 percent calcium chloride is desirable because both the dihydrate and anhydrous products are readily available commercial products. Less than 75 percent calcium chloride may be used effectively. The economics should be examined, especially the shipping costs (See Sec. 6.2).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major changes made to the standard in this revision include the following:

1. Inclusion of a requirement for compliance with the Safe Drinking Water Act and other federal regulations (Sec. 4.1).

2. Inclusion of a requirement for tamper-evident packaging (Sec. 6.2.3 and 6.2.4).

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail the group at standards@awwa.org.



**American Water Works
Association**

AWWA Standard

Calcium Chloride

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes calcium chloride, CaCl, in powder, pellet, granule, flake, or briquette form for use in the treatment of potable water, wastewater, and reuse or reclaimed water.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for calcium chloride, including physical, chemical, sampling, packaging, shipping, and testing requirements.

Sec. 1.3 Application

This standard can be referenced in documents for purchasing and receiving calcium chloride and can be used as a guide for testing the physical and chemical properties of calcium chloride samples. The stipulations for this standard apply when this document has been referenced and then only to calcium chloride used in the treatment of potable, wastewater, and reuse or reclaimed water.