



**American Water Works
Association**

The Authoritative Resource on Safe WaterSM

ANSI/AWWA B601-05
(Revision of ANSI/AWWA B601-00)

AWWA Standard

Sodium Metabisulfite



Effective date: May 1, 2005.

First edition approved by AWWA Board of Directors June 17, 1955.

This edition approved Jan. 16, 2005.

Approved by American National Standards Institute Feb. 24, 2005.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

Science and Technology

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2005 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Taste and Odor Control Chemicals, which reviewed and approved this standard, had the following personnel at the time of approval.

Jeff Robinson, *Chair*

Philip A. Vella, *Secretary*

General Interest Members

C.A. Blanck, Richmond, Ind.	(AWWA)
C.R. Dugan,* Lansing Board of Water & Light, Lansing, Mich.	(AWWA)
J.S. Kippin, Ipswich, Mass.	(NEWWA)
N.E. Otto, Denver, Colo.	(AWWA)
S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
Mohammed Siddiqui, University of Utah, Salt Lake City, Utah	(AWWA)
B.H. Wilder, Daytona Beach, Fla.	(AWWA)

Producer Members

I.P. Fairchild, Chemical Specialty Group Inc., Cartersville, Ga.	(AWWA)
C.B. Lind, General Chemical Corporation, Parsippany, N.J.	(AWWA)
P.A. Vella, CARUS Chemical Company, Lasalle, Ill.	(AWWA)
T.R. Walton, Stuart, Fla.	(AWWA)

User Members

J.T. Harvey, Central Arkansas Water, Little Rock, Ark.	(AWWA)
J.J. Parker, Springfield, Mo.	(AWWA)
Jeff Robinson, Indiana-American Water Company, Greenwood, Ind.	(AWWA)

*Liaison, nonvoting

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.		PAGE	SEC.		PAGE
<i>Foreword</i>			2	References	2
I	Introduction.....	vii	3	Definitions	2
I.A	Background.....	vii	4	Requirements	
I.B	History.....	viii	4.1	Physical Requirements	2
I.C	Acceptance	viii	4.2	Chemical Requirements.....	2
II	Special Issues.....	ix	4.3	Impurities	3
III	Use of This Standard	ix	5	Verification	
III.A	Purchaser Options and Alternatives	ix	5.1	Sampling.....	3
III.B	Modification to Standard.....	x	5.2	Test Procedures.....	4
IV	Major Revisions	x	5.3	Sulfur Dioxide	4
V	Comments	x	5.4	Notice of Nonconformance	6
<i>Standard</i>			6	Delivery	
1	General		6.1	Marking.....	6
1.1	Scope	1	6.2	Packaging and Shipping.....	6
1.2	Purpose	1	6.3	Affidavit of Compliance.....	7
1.3	Application	1			

This page intentionally blank.


Foreword

This foreword is for information only and is not a part of ANSI/AWWA B601.

I. Introduction.

I.A. *Background.* Sodium metabisulfite, $\text{Na}_2\text{S}_2\text{O}_5$, also known as sodium pyrosulfite or anhydrous bisulfite of soda, is a manufactured product. It is one of several salts known collectively as the sulfur dioxide family. All members of this family have the ability to react with and thereby reduce chlorine. Sodium metabisulfite is a white powder that is readily soluble in water, producing a mildly acidic reaction.

Sodium metabisulfite has been used as a dechlorinating agent for many years in the textile, pulp, and paper industries. Its use in water treatment began in the early 1930s at a plant in Glencoe, Ill., which adopted superchlorination for taste and odor control and higher bacterial destruction. Sodium metabisulfite is usually added to the clearwell to prevent high chlorine residuals in water distributed to consumers. The reaction with chlorine can be represented by the following equation:



From this equation, the theoretical reducing ability is calculated as 1.34 mg/L of sodium metabisulfite for 1.00 mg/L of chlorine. Commercially available sodium metabisulfite tests greater than 98 percent in strength. Therefore, approximately 1.37 mg/L of sodium metabisulfite is required per 1.00 mg/L of chlorine in actual practice. The reaction is very rapid and complete.

The use of dry (gravimetric) feeders for sodium metabisulfite has become less common. Sodium metabisulfite tends to scavenge oxygen from the air and loses strength if exposed to air for long periods, as is common in dry feeders. Smaller users purchase the solid form and use solutions that are fed with small metering pumps (positive displacement, such as diaphragm pumps). Larger users purchase the bulk solution (analogous to dry solid and liquid alums) and feed directly from storage with metering devices.

Sodium metabisulfite is a high-strength, dry form of sulfur dioxide (SO_2 equivalent of 66 percent). As such, it has application in plants where moderate amounts of dechlorinating agents are involved and where storage and handling of dry material is desired.

For safety aspects, refer to material safety data sheets (MSDS) available from the chemical supplier or manufacturer.

I.B. *History.* This standard was first approved by the AWWA Board of Directors on Dec. 18, 1953, as ANSI/AWWA B601-53T, Tentative Standard Specifications for Sodium Pyrosulfite. It was advanced to standard on June 17, 1955, and published as ANSI/AWWA B601-55, Standard for Sodium Pyrosulfite. A second revised edition was approved Jan. 27, 1964, and published with the same title. Additional revisions were approved by the AWWA Board of Directors on May 8, 1977, June 5, 1983, Jan. 25, 1988, and published with the title Standard for Metabisulfite (Sodium Pyrosulfite). On Jan. 31, 1993, another revision was approved by the AWWA Board of Directors and published with the title Standard for Metabisulfite. ANSI/AWWA B601-00 was approved by the AWWA Board of Directors on Jan. 23, 2000. This edition was approved by the AWWA Board of Directors on Jan. 16, 2005.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF†/ANSI‡ 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to

*Persons outside the US should contact the appropriate authority having jurisdiction.

†NSF International, 789 Dixboro Rd., Ann Arbor, MI 48105.

‡American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B601 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of greater concern. The language in Sec. 4.3.2 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.

3. Determine current information on product certification.

II. Special Issues. This standard has no applicable information for this section.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. Purchaser Options and Alternatives. The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA B601, Standard for Sodium Metabisulfite, of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Quantity of sodium metabisulfite required and method of packaging and shipping (Sec. 6.2).
4. Whether an affidavit of compliance is required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. **Major Revisions.** Major revisions made to the standard in this edition include the following:

1. Sec. III has been revised to approved wording.
2. Sec. III.A has been revised to approved wording.
3. Sec. 5.4 has been revised to approved wording.

V. **Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at (303) 794-7711, FAX (303) 795-7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standard@awwa.org.



American Water Works
Association

ANSI/AWWA B601-05
(Revision of A NSI/AWWA B601-00)

AWWA Standard

Sodium Metabisulfite

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes the use of sodium metabisulfite ($\text{Na}_2\text{S}_2\text{O}_5$) in the treatment of municipal and industrial water supplies.

Sec. 1.2 Purpose

The purpose of this standard is to provide purchasers, manufacturers, and suppliers with the minimum requirements for sodium metabisulfite, including physical, chemical, packaging, shipping, and testing requirements.

Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving sodium metabisulfite and can be used as a guide for testing the physical and chemical properties of sodium metabisulfite samples. The stipulations of this standard apply when this document has been referenced and only to sodium metabisulfite used in the treatment of municipal and industrial water supplies.