



**American Water Works  
Association**

ANSI/AWWA B703a-08  
Addendum to  
ANSI/AWWA B703-06  
Standard  
for

## **Fluorosilicic Acid**

Approved by AWWA Board of Directors June 8, 2008.  
Approved by American National Standards Institute Sept. 17, 2008.

1. On pages 2–3, Section 4.1.2 *Color* shall read:

The fluorosilicic acid supplied according to this standard shall be white to straw yellow. Straw yellow shall be determined as a material with a maximum of 200 units in accordance with method 2120B, visual comparison method.\*

---

\* *Standard Methods for the Examination of Water and Wastewater.*



**American Water Works  
Association**

The Authoritative Resource on Safe Water<sup>SM</sup>

ANSI/AWWA B703-06  
(Revision of ANSI/AWWA B703-00)

---

---

*AWWA Standard*

---

---

# Fluorosilicic Acid



Effective date: March 1, 2006.

First edition approved by AWWA Board of Directors July 30, 1954.

This edition approved Feb 12, 2006.

Approved by American National Standards Institute Oct. 19, 2005.

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

---

## **Science and Technology**

---

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2006 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA Standards Committee on Fluorides, which reviewed and approved this standard, had the following personnel at the time of approval:

David W. Heumann, *Chair*

Marion E. Casto, *Vice-Chair*

Paul B. Maasen, *Secretary*

### *General Interest Members*

D.M. Apanian, US Environmental Protection Agency Region 4 GW/DW, Atlanta, Ga.	(USEPA)
F. Barker, Department of Public Health—Radiation Control Program, Dorchester, Mass.	(NEWWA)
K. Duchon, Centers for Disease Control and Prevention, Atlanta, Ga.	(USCDC)
M.L. Magnant, Department of Public Health, Des Moines, Iowa	(AWWA)
J.W. Munden, Division of Environmental Health, Raleigh, N.C.	(AWWA)
P.J. Olson, * Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
N.G. Pizzi, * Standards Council Liaison, Environmental Engineering & Technology, Twinsburg, Ohio	(AWWA)
J.U. Tamburini, Rothberg Tamburini & Winsor Inc., Denver, Colo.	(AWWA)
M.L. Wentink, Nebraska Health and Human Services Drinking Water Program, North Platte, Neb.	(AWWA)

### *Producer Members*

M.E. Looney, Solvay Fluorides, Houston, Texas	(AWWA)
P.B. Maasen, KC Industries, Chesterfield, Mo.	(AWWA)
G. Navar, LCI Ltd., Jacksonville Beach, Fla.	(AWWA)
S. Quiggle, Cargill, Riverview, Fla.	(AWWA)

---

\*Liaison, nonvoting

*User Members*

M.E. Casto, Murfreesboro Water & Sewer, Murfreesboro, Tenn.	(AWWA)
M.B. Gilton, South San Joaquin Irrigation District, Ripon, Calif.	(AWWA)
D.W. Heumann, Los Angeles Department of Water & Power, San Gabriel, Calif.	(AWWA)
S. Rezania, City of Minneapolis, Minneapolis, Minn.	(AWWA)
S.A. Smith, Gwinnett County Department of Public Utilities, Buford, Ga.	(AWWA)
J.S. Trotter, City of Bloomington Utilities, Bloomington, Ind.	(AWWA)

# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.		PAGE	SEC.		PAGE
<i>Foreword</i>			4	<b>Requirements</b>	
I	Introduction.....	vii	4.1	Physical Requirements .....	2
I.A	Background.....	vii	4.2	Chemical Requirements.....	3
I.B	History.....	viii	4.3	Impurities .....	3
I.C	Acceptance .....	viii	5	<b>Verification</b>	
II	Special Issues.....	ix	5.1	Sampling and Laboratory	
II.A	Storage, Handling, and			Examination.....	4
	Safety Precautions .....	ix	5.2	Test Procedures.....	4
III	Use of This Standard .....	x	6	<b>Delivery</b>	
III.A	Purchaser Options and		6.1	Marking.....	9
	Alternatives .....	x	6.2	Packaging and Shipping.....	10
III.B	Modification to Standard.....	x	6.3	Affidavit of Compliance or	
IV	Major Revisions. ....	xi		Certified Analyses .....	10
V	Comments. ....	xi			
<i>Standard</i>			<i>Appendix</i>		
1	<b>General</b>		A	<b>Materials Compatibility</b> .....	11
1.1	Scope .....	1	B	<b>Fluorosilicic Acid—</b>	
1.2	Purpose .....	1		<b>Contaminants</b> .....	13
1.3	Application .....	1	<i>Tables</i>		
2	<b>References</b> .....	2	1	Impurity Analytic Methods.....	8
3	<b>Definitions</b> .....	2	B.1	Fluorosilicic Acid—	
				Contaminants .....	13

This page intentionally blank.

# Foreword

*This Foreword is for information only and is not a part of ANSI/AWWA B703.*

## I. Introduction.

I.A. *Background.* Fluorosilicic acid ( $\text{H}_2\text{SiF}_6$ ) is one of several fluoride compounds presently being added to drinking water to reduce the incidence of dental caries. Since the first fluoridation installation during 1945, studies have shown that dental decay can be reduced by 20 to 40 percent among children who have consumed fluoridated water since birth.

Fluorosilicic acid is an aqueous solution of  $\text{H}_2\text{SiF}_6$ —water white to straw yellow in color. It is a corrosive acid, irritating to the skin, and has a pungent odor. It is not known to exist in any anhydrous form. The boiling point increases with increasing acid content. At a typical commercial strength of 25 percent acid content, the boiling point is  $105.8^\circ\text{C}$  ( $222.5^\circ\text{F}$ ), and the freezing point is approximately  $-15.5^\circ\text{C}$  ( $4^\circ\text{F}$ ). A 25 percent solution has a pH of 1.2 and weighs 10.1 lb/gal (1.20 kg/L). The molecular weight of  $\text{H}_2\text{SiF}_6$  is 144.08.

Fluorosilicic acid is produced as a co-product in the manufacture of wet-process phosphoric acid and other phosphate fertilizers. The raw material, phosphate rock, contains fluoride and silica and is treated with sulfuric acid, which evolves the gases silicon tetrafluoride ( $\text{SiF}_4$ ) and hydrogen fluoride (HF). These gases are passed through scrubbers and react with water to form fluorosilicic acid. This acid is the principal raw material in the production of all silicofluoride salts. It is also used in the ceramic, brewing, paint, and metallurgical industries.

Fluorosilicic acid is added to water using various liquid-feeding devices and metering pumps. It is normally fed directly into the water to produce the optimal fluoride concentration. Dilution of the acid before feeding is not recommended. If the acid is too concentrated for the solution feeder to control, solutions of other compounds are generally indicated, for example, solutions of sodium fluoride or sodium fluorosilicate. If the acid must be diluted, dilutions in the range of 10 to 1 and 20 to 1 (parts water to parts acid) should be avoided, because they often result in the formation of an insoluble silica precipitate that can clog feeders, orifices, and other equipment. The use of softened or distilled water has no effect on the formation of this precipitate. However, the precipitate can be avoided by using dilutions outside the critical range (dilutions in the range of 200:1 to 100:1 are

known to work well), or by using acid that has been fortified with hydrogen fluoride (HF).

Refer to AWWA Manual M4, *Water Fluoridation Principles and Practices*,\* for additional technical information concerning the application and use of fluorosilicic acid.

I.B. *History.* This standard was first published in the November 1954 issue of *Journal AWWA* as tentative, having been approved on July 30, 1954, by the AWWA Board of Directors. Subsequent revisions to ANSI/AWWA B703 were approved by the AWWA Board of Directors on May 15, 1960; June 18, 1971; Jan. 30, 1984; Jan. 29, 1989; Jan. 30, 1994; and Jan. 23, 2000. This eighth edition was prepared by the AWWA Standards Committee on Fluorides and approved by the AWWA Board of Directors on Feb. 12, 2006.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.† Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF‡/ANSI§ 60, *Drinking Water Treatment Chemicals—Health Effects*, and NSF/ANSI 61, *Drinking Water System Components—Health Effects*.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to

---

\*AWWA Manual M4, *Water Fluoridation Principles and Practices*, AWWA, Denver, Colo.

† Persons outside of the United States should contact the appropriate authority having jurisdiction.

‡ NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

§ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 60 does not stipulate a single product allowable concentration (SPAC) value of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The SPAC values of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B703 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of greater concern. The language in Sec. 4.3.3 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, *Drinking Water Treatment Chemicals—Health Effects*. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

## II. Special Issues.

II.A. *Storage, Handling, and Safety Precautions.* Fluorosilicic acid must be handled carefully because it is corrosive. If the acid comes in contact with skin, the affected parts should be immediately rinsed thoroughly with water. For information on safety, refer to the material safety data sheets (MSDS) available from the chemical supplier or manufacturer. Protective safety gear should be worn when handling fluorosilicic acid. The following protective clothing and equipment should be the minimum available:

1. Gauntlet neoprene gloves (12-in. [300-mm] minimum glove length).
2. Full 8-in. (200-mm) face shield or acid-proof-type safety goggles.
3. Heavy-duty, acid-proof-type neoprene aprons.
4. Safety shower and eyewash in an easily accessible location.

Materials such as glass, ceramics, steel, concrete, and wood are not suitable for fluorosilicic acid containers and other equipment because they are attacked by the hydrofluoric acid (HF) and silicon tetrafluoride ( $\text{SiF}_4$ ) formed at the surface of the fluorosilicic acid. Bulk storage tanks and other containers can be made of polyethylene, rubber-lined steel, or other appropriate materials. The polyethylene should be manufactured from high-density, cross-linked material (cross-linking provides strength). The polyethylene should contain a minimum of 0.25 percent ultraviolet stabilizer to protect against sunlight. Steel tanks must always be lined. The linings are commonly made of natural rubber, neoprene, butyl rubber, or equivalent and should be at least 2.4-mm ( $3/32$ -in.) thick. Structural carbon, Hastelloy C, Durimet 20, or equivalent materials can be used for hardware. The rooms where the acid is stored and used should be thoroughly ventilated with a vent located near the ceiling because acid fumes are lighter than air. Closed tanks should be vented to the outside. Additional information on materials compatibility appears in Appendix A.

**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

*III.A. Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA B703, Standard for Fluorosilicic Acid, of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Quantity required.
4. If an analysis by a referee laboratory is required, the assignment of testing costs should be addressed.
5. Concentration (strength of acid desired) (Sec. 4.2). The acid shall contain between 20 and 30 percent  $\text{H}_2\text{SiF}_6$  by weight. Where variations in acid strength are acceptable, arrangements should be made between the purchaser and the supplier as to the method of payment, based on the aggregated acid content.
6. Form of shipment—bulk or package (type) (Sec. 6.2.2).
7. Affidavit of compliance or certified analyses, or both, if required (Sec. 6.3).

*III.B. Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be specified by the purchaser.

**IV. Major Revisions.** Major changes made in this revision of the standard include the following:

1. Impurity requirements have been tied to the SPACs listed in NSF/ANSI 60, Drinking Water Treatment Chemical—Health Effects (Sec. 4.3.3).

2. Test procedures for impurities have been defined and referenced (Sec. 5.2.5 and Table 1).

3. A table showing SPACs for impurities regulated under NSF/ANSI 60, Drinking Water Treatment Chemical—Health Effects, has been added as an appendix (Appendix B).

**V. Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer & Technical Support group, 303.794.7711, FAX 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at [standards@awwa.org](mailto:standards@awwa.org).

This page intentionally blank.



American Water Works  
Association

ANSI/AWWA B703-06  
(Revision of ANSI/AWWA B703-00)

---

---

## *AWWA Standard*

---

---

# Fluorosilicic Acid

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard describes fluorosilicic acid ( $H_2SiF_6$ ) for water supply service application.

### Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for fluorosilicic acid, including physical, chemical, packaging, shipping, and testing requirements.

### Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving fluorosilicic acid and can be used as a guide for testing the physical and chemical properties of fluorosilicic acid samples. The stipulations of this standard apply when this document has been referenced and only to fluorosilicic acid used in water supply service application.