



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA B703-11
(Revision of ANSI/AWWA B703-06)

AWWA Standard

Fluorosilicic Acid



Effective date: Nov. 1, 2011.

First edition approved by AWWA Board of Directors July 30, 1954.

This edition approved June 12, 2011.

Approved by American National Standards Institute Aug. 17, 2011.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Committee Personnel

The AWWA Standards Committee on Fluorides, which reviewed and approved this standard, had the following personnel at the time of approval:

David W. Heumann, *Chair*

Gus Navar, *Secretary*

General Interest Members

F. Barker, Department of Public Health—Radiation Control Program, Dorchester, Mass.

(NEWWA)

K. Duchon, Centers for Disease Control and Prevention, Atlanta, Ga. (USCDC)

H.C. Liang, Tetra Tech, Denver, Colo. (AWWA)

M.L. Magnant, Department of Public Health, Des Moines, Iowa (AWWA)

C. Marcos, Northeast Pump & Instrument, Lunenburg, Mass. (AWWA)

S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo. (AWWA)

L.F. Vaughn,* Linda Vaughn Inc., Chapel Hill, N.C. (AWWA)

M.L. Wentink, Nebraska Health and Human Services Drinking Water Program,
North Platte, Neb. (AWWA)

Producer Members

R.L. Horne, Pennco Inc., Sealy, Texas (AWWA)

M.E. Looney, Solvay Fluorides, Houston, Texas (AWWA)

P.B. Maasen, KC Industries, Chesterfield, Mo. (AWWA)

M.T. Merlo, BHS Marketing, Nampa, Idaho (AWWA)

G. Navar, LCI Ltd., Jacksonville Beach, Fla. (AWWA)

User Members

J.E. Fields, Metropolitan Water District of Southern California, Whittier, Calif. (AWWA)

M.B. Gilton, South San Joaquin Irrigation District, Ripon, Calif. (AWWA)

D.W. Heumann, Los Angeles Department of Water & Power, San Gabriel, Calif. (AWWA)

G. Pihera, Clayton County Water Authority, Jonesboro, Ga. (AWWA)

S. Rezania, City of Minneapolis, Minneapolis, Minn. (AWWA)

C.E. Stringer, Dallas Water Utilities, Dallas, Texas (AWWA)

C.R. Thomerson, City of Columbus, Columbus, Neb. (AWWA)

J.S. Trotter, City of Bloomington Utilities, Bloomington, Ind. (AWWA)

* Liaison, nonvoting

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>		4	Requirements
I	vii	4.1	Physical Requirements..... 2
I.A	vii	4.2	Chemical Requirements 3
I.B	viii	4.3	Impurities..... 3
I.C	viii	5	Verification
II	ix	5.1	Sampling and Laboratory Examination 3
II.A	ix	5.2	Test Procedures 4
	ix	5.3	Notice of Nonconformance 7
III	x	6	Delivery
III.A	x	6.1	Marking..... 8
	x	6.2	Packaging and Shipping 9
III.B	xi	6.3	Affidavit of Compliance or Certified Analyses 10
IV	xi		
V	xi		
<i>Standard</i>		<i>Appendixes</i>	
1	General	A	Materials Compatibility 11
1.1	Scope 1	B	Fluorosilicic Acid—Contaminants .. 13
1.2	Purpose 1		
1.3	Application..... 1	<i>Tables</i>	
2	References 1	1	Impurity Analytic Methods..... 8
3	Definitions 2	B.1	Fluorosilicic Acid—Contaminants .. 13

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA B703.*

I. Introduction.

I.A. *Background.* Community water fluoridation is an effective, safe, and inexpensive way to prevent tooth decay. Since the first fluoridation installation during 1945, studies have shown that this method of fluoride delivery benefits Americans of all ages and socioeconomic status. Dental decay can be reduced by 20 to 40 percent among children who have consumed fluoridated water since birth. Fluorosilicic acid (H_2SiF_6) is one of several fluoride compounds presently being added to drinking water to reduce the incidence of dental caries.

Fluorosilicic acid is an aqueous solution of H_2SiF_6 —water white to amber in color. It is a corrosive acid, irritating to the skin, and has a pungent odor. It is not known to exist in any anhydrous form. The boiling point increases with increasing acid content. At a typical commercial strength of 25 percent acid content, the boiling point is 105.8°C (222.5°F), and the freezing point is approximately -15.5°C (4°F). A 25 percent solution has a pH of 1.2 and weighs 10.1 lb/gal (1.20 kg/L). The molecular weight of H_2SiF_6 is 144.08.

Fluorosilicic acid is produced as a co-product in the manufacture of wet-process phosphoric acid and other phosphate fertilizers. The raw material, phosphate rock, contains fluoride and silica and is treated with sulfuric acid, which evolves the gases silicon tetrafluoride (SiF_4) and hydrogen fluoride (HF). These gases are passed through scrubbers and react with water to form fluorosilicic acid. This acid is the principal raw material in the production of all silicofluoride salts. It is also used in the ceramic, brewing, paint, and metallurgical industries.

Fluorosilicic acid is added to water using various liquid-feeding devices and metering pumps. It is normally fed directly into the water to produce the optimal fluoride concentration. Dilution of the acid before feeding is not recommended. If the acid is too concentrated for the solution feeder to control, solutions of other compounds are generally indicated, for example, solutions of sodium fluoride or sodium fluorosilicate. If the acid must be diluted, dilutions in the range of 10 to 1 and 20 to 1 (parts water to parts acid) should be avoided, because they often result in the formation of an insoluble silica precipitate that can clog feeders, orifices, and other equipment. The use of softened or

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

distilled water has no effect on the formation of this precipitate. However, the precipitate can be avoided by using dilutions outside the critical range (dilutions in the range of 200:1 to 100:1 are known to work well), or by using acid that has been fortified with hydrogen fluoride (HF).

Refer to AWWA Manual M4, *Water Fluoridation Principles and Practices*,* for additional technical information concerning the application and use of fluorosilicic acid.

I.B. *History.* This standard was first published in the November 1954 issue of *Journal AWWA* as tentative, having been approved on July 30, 1954, by the AWWA Board of Directors. Subsequent revisions to ANSI/AWWA B703 were approved on May 15, 1960; June 18, 1971; Jan. 30, 1984; Jan. 29, 1989; Jan. 30, 1994; Jan. 23, 2000; and Feb. 12, 2006. This edition was prepared by the AWWA Standards Committee on Fluorides and approved on June 12, 2011.

I.C. *Acceptance.* In September 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now Water Research Foundation[†]) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later. In April 1990, USEPA formally withdrew its list of acceptable drinking water additives, and regulatory oversight of direct and indirect drinking water additives passed to the process developed by the consortium under the leadership of NSF.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[‡] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF[§]/ANSI 60, Drinking Water Treatment Chemicals—Health Effects (NSF/ANSI 60), and NSF/ANSI 61, Drinking Water System Components—Health Effects (NSF/ANSI 60). NSF, in cooperation with ASDWA, does a biennial

* AWWA Manual M4, *Water Fluoridation Principles and Practices*, AWWA, Denver, Colo.

† Water Research Foundation, 6666 W. Quincy Avenue, Denver, CO 80235.

‡ Persons outside the United States should contact the appropriate authority having jurisdiction.

§ NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

survey of the US state and Canadian provinces/territories to determine which states and provinces/territories require, by legislation, regulations or policies that products and drinking water additives be evaluated by NSF/ANSI 60 and 61. Survey results from 2009 show adoption of NSF/ANSI 60 by 47 states and 9 provinces/territories, and adoption of NSF/ANSI 61 by 46 states and 11 provinces/territories.

Several organizations are accredited by national or international third-party agencies to certify products in accordance with NSF/ANSI 60. States, provinces/territories, local agencies, and water utilities can determine which certification organizations are acceptable within their individual jurisdictions.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 60 does not stipulate a total allowable concentration (TAC) or a single product allowable concentration (SPAC) value of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The TACs and SPACs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B703 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or to residual solids is becoming a problem of greater concern. Sec. 4.3.3 recommends that material covered by this standard be certified by an accredited agency for compliance with NSF/ANSI 60. As noted above, most states and provinces/territories require that direct additives be certified to NSF/ANSI 60. A user of this standard should consult with the state, province/territory, or local agency having jurisdiction for certification requirements, but the user may require certification even in the absence of such a requirement by the agency having jurisdiction.

II. Special Issues.

II.A. *Storage, Handling, and Safety Precautions.* Fluorosilicic acid must be handled carefully because it is corrosive. If the acid comes in contact with skin, the affected parts should be immediately rinsed thoroughly for at least 15 min with water. Then apply 2.5 percent calcium gluconate gel liberally to areas suspected of fluorosilicic acid contact, paying particular attention to areas under the fingernails. It is recommended that a supply of the gel be kept on-site wherever fluorosilicic acid is handled or stored. Prompt medical attention should follow. For information on safety, refer to the material safety data sheets (MSDS) available from the chemical supplier or manufacturer. Protective safety gear should be worn when handling fluorosilicic acid. The following protective clothing and equipment should be the minimum available:

1. Gauntlet neoprene gloves (12-in. [300-mm] minimum glove length).
2. Full 8-in. (200-mm) face shield and chemical splash-proof safety goggles.
3. Heavy-duty, acid-proof-type neoprene aprons.
4. Safety shower and eyewash in an easily accessible location.

Materials such as glass, ceramics, steel, concrete, and wood are not suitable for fluorosilicic acid containers and other equipment because they are attacked by the hydrofluoric acid (HF) and silicon tetrafluoride (SiF₄) formed at the surface of the fluorosilicic acid. Bulk storage tanks and other containers can be made of polyethylene, rubber-lined steel, fiberglass, or other appropriate materials. The polyethylene should be manufactured from high-density, cross-linked material (cross-linking provides strength). The polyethylene should contain a minimum of 0.25 percent ultraviolet stabilizer to protect against sunlight. Steel tanks must always be lined. The linings are commonly made of natural rubber, neoprene, butyl rubber, or equivalent, and should be at least 2.4-mm (³/₃₂-in.) thick. Fiberglass for fluorosilicic acid applications must be composed of a vinyl ester resin and a synthetic veil/liner. Structural carbon, Hastelloy C, Durimet 20, or equivalent materials can be used for hardware. The rooms where the acid is stored and used should be thoroughly ventilated with a vent located near the ceiling because acid fumes are lighter than air. Closed tanks should be vented to the outside, and such tank venting systems should be pressure-tested for leaks before being placed into service. When cross-linked polyethylene tank venting systems are pressure-tested, extreme care must be exercised, as maximum allowed tank overpressures are typically ~5 psig. Additional information on materials compatibility appears in appendix A.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser.

1. Standard used—that is, ANSI/AWWA B703, Fluorosilicic Acid, of latest revision.
2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.
3. Quantity required.
4. Details of other federal, state or provincial, and local requirements (Section 4).
5. Concentration (strength of acid desired) (Sec. 4.2). The acid shall contain between 20 and 30 percent H₂SiF₆ by weight. Where variations in acid strength are acceptable, arrangements should be made between the purchaser and the supplier as to the method of payment, based on the aggregated acid content.

6. Whether the purchaser will reject product from containers or packaging with missing or damaged seals. The purchaser may reject product from bulk containers or packages with missing or damaged seals unless the purchaser's tests of representative samples, conducted in accordance with Sec. 5.2, demonstrate that the product meets the standard. Failure to meet the standard or the absence of, or irregularities in, seals may be sufficient cause to reject a shipment.

7. Form of shipment—bulk or package, package type, and package size (Sec. 6.2.2).

8. Whether alternative security measures have been adopted to replace or augment the security measures set out in Sec. 6.2.5 and 6.2.6.

9. Affidavit of compliance or certified analyses, or both, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major changes made in this revision of the standard include the following:

1. Inclusion of a requirement for compliance with the Safe Drinking Water Act and other federal regulations (Section 4).

2. Inclusion of a requirement for tamper-evident packaging (Sec. 6.2.5 and 6.2.6).

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.

This page intentionally blank.



**American Water Works
Association**

AWWA Standard

Fluorosilicic Acid

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes fluorosilicic acid (H_2SiF_6) for use in the treatment of potable water.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for fluorosilicic acid, including physical, chemical, sampling, packaging, shipping, and testing requirements.

Sec. 1.3 Application

This standard can be referenced in documents for purchasing and receiving fluorosilicic acid and can be used as a guide for testing the physical and chemical properties of fluorosilicic acid samples. The stipulations of this standard apply when this document has been referenced and only to fluorosilicic acid used in the treatment of potable water.

SECTION 2: REFERENCES

This standard references the following documents. In their latest editions, they form a part of this standard to the extent specified within the standard. In any case of conflict, the requirements of this standard shall prevail.