This is a preview of "AWWA C153-11". Click here to purchase the full version from the ANSI store.



The Authoritative Resource on Safe Water®

ANSI/AWWA C153/A21.53-11 (Revision of ANSI/AWWA C153/A21.53-06)

AWWA Standard

Ductile-Iron Compact Fittings





Effective date: Nov. 1, 2011. First edition approved by AWWA Board of Directors Jan. 30, 1984. This edition approved June 12, 2011. Approved by American National Standards Institute Aug. 8, 2011.

6666 West Quincy Avenue Denver, C0 80235-3098 **T** 800.926.7337 www.awwa.org Advocacy Communications Conferences Education and Training Science and Technology Sections

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the official notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2011 by American Water Works Association Printed in USA

Committee Personnel

Subcommittee 3, Fittings, which developed this standard, had the following personnel at the time:

Larry R. Dunn, Chair

General Interest Members

P.I. McGrath Jr., Consultant, Birmingham, Ala.	(AWWA)
E.S Ralph,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
P.A. Selig, Vestavia Hills, Ala.	(AWWA)
Producer Members	
S. Bhattacharji, Sigma Corporation, Cream Ridge, N.J.	(AWWA)
M. Bowsher, Star Pipe Products Inc., Houston, Texas	(AWWA)
L.R. Dunn, US Pipe & Foundry Company, Birmingham, Ala.	(AWWA)
J.H. Eddings, McWane Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
G.A. Fox, Sigma Corp., Alexander City, Ala.	(AWWA)
M.D. Gaston, American Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
M.B. Harrington, Harrington Corporation, Lynchburg, Va.	(AWWA)
L.G. Horn, Ductile Iron Pipe Research Association, Birmingham, Ala.	(AWWA)
R.J. Huggins, Griffin Pipe Products Company, Lynchburg, Va.	(AWWA)
J.C. Jones, S&B Technical Products, Fort Worth, Texas	(AWWA)
H. Kennedy Jr., Harold Kennedy & Associates, Fuquay Varina, N.C.	(AWWA)
T.M. Kiley, Victaulic Company of America, Easton, Pa.	(AWWA)
B. Leider, Star Pipe Products Inc., Evergreen, Colo.	(AWWA)
T.J. Muntz, Fab Pipe Inc., Rogers, Minn.	(AWWA)
G. Oliver, [†] American Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
User Members	

T.E. Coughran, City of La Habra, La Habra, Calif.	(AWWA)
D.D. Montgomery, City of Independence, Independence, Mo.	(AWWA)

* Liaison, nonvoting

†Alternate

AWWA Standards Committee A21, Ductile-Iron Pipe and Fittings, which reviewed and approved this standard, had the following personnel at the time of approval:

John R. Plattsmier, Chair

General Interest Members

H.E. Holcomb, Consultant, Saint Marys, Ga.	(AWWA)
M.B. Horsley, Black & Veatch Corporation, Kansas City, Mo.	(AWWA)
D.H. Kroon, Corrpro Companies Inc., Houston, Texas	(AWWA)
D.D. Lary,* Wright-Pierce, Topsham, Maine	(NEWWA)
G.E. Laverick, Underwriters Laboratories Inc., Northbrook, Ill.	(UL)
P.I. McGrath Jr., Consultant, Birmingham, Ala.	(AWWA)
P.J. Mourt, Hatch Mott MacDonald, Milburn, N.J.	(AWWA)
J.R. Plattsmier, HDR Engineering Inc., Denver, Colo.	(AWWA)
E.S. Ralph, [†] Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
C.R. Schwenker, Malcolm Pirnie Inc., Arlington, Va.	(AWWA)
T.M. Stinson, Kleinfelder SEA, Cambridge, Mass.	(NEWWA)
L.C. Yates, McGoodwin Williams & Yates, Fayetteville, Ark.	(AWWA)
K. Zastrow,* Underwriters Laboratories Inc., Northbrook, Ill.	(AWWA)
Producer Members	
L.R. Dunn, US Pipe & Foundry Company, Birmingham, Ala.	(AWWA)

	(
J.H. Eddings, McWane Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
M.D. Gaston, American Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
L.G. Horn, Ductile Iron Pipe Research Association, Birmingham, Ala.	(AWWA)
R.J. Huggins, Griffin Pipe Products Company, Lynchburg, Va.	(AWWA)
J.C. Jones, S&B Technical Products, Fort Worth, Texas	(AWWA)
H. Kennedy Jr., Harold Kennedy & Associates, Fuquay Varina, N.C.	(AWWA)
T.J. Muntz, Fab Pipe Inc., Rogers, Minn.	(AWWA)
G. Oliver,* American Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)

^{*} Alternate

[†] Liaison, nonvoting

User Members

D.T. Bradley, Oak Lodge Water District, Portland, Ore.	(AWWA)
T.E. Coughran, City of La Habra, La Habra, Calif.	(AWWA)
A.J. DeBoy,* Indiana American Water, Greenwood, Ind.	(AWWA)
M.W. Griffin, Missouri-American Water Company, Saint Louis, Mo.	(AWWA)
J.M. Kennedy, Tampa Bay Water, Clearwater, Fla.	(AWWA)
D.D. Montgomery, City of Independence, Independence, Mo.	
K.C. Morgan, [†] Standards Council Liaison, City of Phoenix Water Services Dept.,	
Phoenix, Ariz.	(AWWA)
C.J. Patla, Connecticut Water Service Inc., Clinton, Conn.	(AWWA)
A. Shively, City of Kansas City, Kansas City, Mo.	(AWWA)
R.L. Worden, COMCD, Norman, Okla.	(AWWA)

^{*} Alternate

[†]Liaison, nonvoting

This is a preview of "AWWA C153-11". Click here to purchase the full version from the ANSI store.

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE
Forei	vord
Ι	Introduction ix
I.A	Background ix
I.B	History ix
I.C	Acceptance x
II	Special Issues xii
II.A	Special Service Application xii
II.B	Orientation of Bolt Holes xii
II.C	Connecting Mechanical Joint Fittings
	and Aged Gray-Iron Pipe xii
II.D	Advisory Information on Product
	Testing xii
II.E	Advisory Information for the
	Purchaser and Specifier xiii
III	Use of This Standard xiii
III.A	Purchaser Options and
	Alternatives xiii
III.B	Modification to Standard xiv
IV	Major Revisions xiv
V	Comments xiv

Standard

1 General

2	References	2
1.3	Application	2
1.2	Purpose	2
1.1	Scope	1

SEC.	PAGE
3	Definitions
4	Requirements
4.1	Materials 3
4.2	Permeation 4
4.3	General Requirements 4
4.4	Coatings and Linings 5
4.5	Tolerances or Permitted Variations 6
4.6	Markings on Fittings 7
4.7	Special Requirements for Flanged
	Fittings 7
5	Verification
5.1	Inspection 8
5.2	Test Procedures 8
5.3	Chemical Limitations
5.4	Additional Tests Required by
	Purchaser
5.5	Performance Requirements
5.6	Defective Specimens and Retests 10
5.7	Nonconforming Fittings 10
5.8	Affidavit of Compliance 10
6	Delivery 10

Appendix

A Flanged Fittings: Bolts, Gaskets, and Installation

A.1	Bolts and Nuts	35
A.2	Gaskets	35
A.3	Installation	36

Figures

1	Mechanical-Joint by Mechanical-Joint
	Bends 11
2	Mechanical-Joint by Plain-End
	Bends 12
3	Mechanical-Joint Tees 13
4	Mechanical-Joint Crosses 16
5	Mechanical-Joint Reducers
6	Mechanical-Joint Sleeves 20
7	Mechanical-Joint Caps 21
8	Mechanical-Joint Plugs 21
9	Mechanical-Joint Tapped Tees 22
10	Mechanical-Joint and Flange
	Connecting Pieces 23
11	Mechanical-Joint Offsets 24
12	Push-on Joint Bends 26
13	Push-on Joint Tees and Crosses 28
14	Push-on Joint Reducers 30
15	Flange Details
16	Flanged Bends 32
17	Flanged Tees and Crosses 33
18	Flanged Reducers

Tables

1	Mechanical-Joint by	
	Mechanical-Joint Bends	11
2	Mechanical-Joint by Plain-End	
	Bends	12
3	Mechanical-Joint Tees	13
4	Mechanical-Joint Crosses	16
5	Mechanical-Joint Reducers	18
6	Mechanical-Joint Sleeves	20
7	Mechanical-Joint Caps	21
8	Mechanical-Joint Plugs	21
9	Mechanical-Joint Tapped Tees	22
10	Mechanical-Joint and Flange	
	Connecting Pieces	23
11	Mechanical-Joint Offsets	25
12	Push-on Joint Bends	27
13	Push-on Joint Tees and Crosses	29
14	Push-on Joint Reducers	30
15	Flange Details	31
16	Flanged Bends	33
17	Flanged Tees and Crosses	33
18	Flanged Reducers	34
A.1	Flange Gasket Details	36

Foreword

This foreword is for information only and is not a part of ANSI*/AWWA C153/A21.53.

I. Introduction.

I.A. *Background*. The earliest record of an AWWA standard for cast-iron pipe appears in the 1890 AWWA annual conference proceedings. In 1902, the New England Water Works Association (NEWWA) adopted a more detailed standard titled "Standard Specification for Cast-Iron Pipe and Special Castings." The next AWWA standard for pipe and fittings, 7C.1-1908, was approved May 12, 1908, and was followed by AWWA C100-52T, Tentative Standard Specifications for Cast Iron Pressure Fittings, which was approved Dec. 31, 1952. A complete listing and description of subsequent cast-iron-fittings standards is presented in the foreword of ANSI/AWWA C110/A21.10, Standard for Ductile-Iron and Gray-Iron Fittings.

In 1926, the American Standards Association (ASA), now the American National Standards Institute (ANSI), Committee A21 on Cast-Iron Pipe and Fittings, was organized under the sponsorship of the American Gas Association (AGA), the American Society for Testing and Materials (ASTM), AWWA, and NEWWA. Between 1972 and 1984, the co-secretariats were AGA, AWWA, and NEWWA, with AWWA serving as administrative secretariat. In 1984, the committee became an AWWA committee named AWWA Standards Committee A21 on Ductile Iron Pipe and Fittings. In 1988, NEWWA withdrew as a separate secretariat; however, it continues to maintain its representation on the A21 committee. In 1997, AGA withdrew as co-secretariat. The present scope of Committee A21 activity is the development of standards and manuals addressing ductile-iron pressure pipe for water and ductile-iron and gray-iron fittings for use with such pipe. These standards and manuals include topics such as design, dimensions, materials, coatings, linings, joints, accessories, methods of inspection and testing, and installation.

The work of Committee A21 is conducted by subcommittees. The scope of Subcommittee 3, Fittings, includes the periodic review of all current A21 standards for ductile-iron and gray-iron fittings; preparation of revisions and new standards when needed; and examination of other matters pertaining to standards for fittings.

I.B. *History.* At the meeting of Standards Committee A21 in 1981, Subcommittee 3 was directed to prepare a standard for 3-in. through 12-in. (75-mm

^{*} American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

through 300-mm) compact fittings designed to use the attendant strength of ductile iron. The subcommittee was directed to present this standard to the committee for action in 1983. The first edition of this standard, designated ANSI/AWWA C153/ A21.53-84, ANSI Standard for Ductile-Iron Compact Fittings, 3 In. Through 12 In. (75 mm Through 300 mm), for Water and Other Liquids, was approved by the AWWA Board of Directors on Jan. 30, 1984, and by ANSI on Feb. 4, 1985.

The second edition of this standard, designated ANSI/AWWA C153/A21.53-88, ANSI Standard for Ductile-Iron Compact Fittings, 3 In. Through 16 In., for Water and Other Liquids, was approved on June 19, 1988, and by ANSI on July 5, 1988. Major revisions included expansion of the sizes covered to include 14-in. and 16-in. sizes, addition of "long" laying-length sleeves, changes in acceptance testing, and new sections on rejection of fittings and determination of rejection.

The third edition of this standard, designated ANSI/AWWA C153/A21.53-94, ANSI Standard for Ductile-Iron Compact Fittings, 3 In. Through 24 In. (76 mm Through 610 mm) and 54 In. Through 64 In. (1,400 mm Through 1,600 mm), for Water Service, was approved on Jan. 30, 1994, and by ANSI on Aug. 18, 1994. Major revisions included expansion of the sizes covered to include 18- through 24-in. sizes and 54- through 64-in. sizes; bends with plain-ends were added; crosses were added; coverage of reducers was expanded to four types, push-on and flange fittings were added; and the appendix on bolts, gaskets, and installation was added.

The fourth edition of this standard, designated ANSI/AWWA C153/A21.53-00, ANSI Standard for Ductile-Iron Compact Fittings for Water Service, was approved on Jan. 23, 2000, and by ANSI on June 28, 2000. Major revisions included the introduction of surge allowances, fusion-bonded epoxy coating systems, and 30- through 48-in. fittings. The fifth edition of this standard, designated ANSI/AWWA C153/A21.53-06, ANSI Standard for Ductile-Iron Compact Fittings for Water Service, was approved on Feb. 12, 2006, and by ANSI on May 19, 2006. Major revisions included the deletion of the figure and table giving details of the mechanical joint and the referencing of ANSI/AWWA C111/A21.11 for details of mechanical-joint bell, plain end, and accessories.

This sixth edition was approved on June 12, 2011.

I.C. *Acceptance*. In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research

Foundation (AwwaRF, now Water Research Foundation*) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.

2. Specific policies of the state or local agency.

3. Two standards developed under the direction of NSF, NSF[‡]/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*, \$ and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C153/A21.53 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.

^{*} Water Research Foundation, 6666 W. Quincy Ave., Denver, CO 80235.

[†] Persons outside the United States should contact the appropriate authority having jurisdiction.

[‡]NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

[§] Both publications available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.

3. Determine current information on product certification.

II. Special Issues.

II.A. *Special Service Application*. The fittings described in this standard are normally used for pressurized water supply systems. Fittings used in other types of service may require special consideration by the user of this standard (see Section III).

II.B. Orientation of Bolt Holes. Although this standard does not specify the orientation of bolt holes in the bell flanges of the mechanical joint, it is at times convenient or necessary to have the bolt holes oriented. The normal, but not universal, practice is to have the bolt holes straddle the vertical centerline of the fittings, valves, and hydrants. (The vertical centerline of a fitting is determined when the fitting is in the position to change the direction of fluid flowing in a horizontal plane.) If orientation is necessary, this requirement should be specified.

II.C. Connecting Mechanical Joint Fittings and Aged Gray-iron Pipe. The following note in the 1998 edition of ANSI/AWWA C110/A21.10 cautioned about using mechanical-joint fittings with aged existing pipe:

NOTE: Mechanical-joint fittings should be connected carefully to aged existing cast-iron pipe. The outside diameter of aged pipe should be measured prior to cutting because some older pipe was manufactured to a larger diameter than is presently specified in AWWA standards. Mechanical-joint sleeves or bell-and-spigot (caulked-joint) sleeves are available to provide transition from existing cast-iron pipe; however, they must be specified by the purchaser. The following standards contain reference dimensions useful in classifying existing cast-iron pipe:

ANSI A21.6-1975 (ANSI/AWWA C106-75)—American National Standard for Cast-Iron Pipe Centrifugally Cast in Metal Molds for Water or Other Liquids; Tables 6.4, 6.5, and 6.6.

ANSI A21.8-1975 (ANSI/AWWA C108-75)—American National Standard for Cast-Iron Pipe Centrifugally Cast in Sand-Lined Molds for Water or Other Liquids; Tables 8.4, 8.5, and 8.6.

ASA A21.2-1953 (AWWA C102-53)—American Standard for Cast-Iron Pit Cast Pipe for Water or Other Liquids; Tables 2.1 and 2.2.

AWWA 7C.1-1908 (AWWA C100-55)—Standard Specifications for Cast-Iron Pressure Fittings; Table 1.

II.D. Advisory Information on Product Testing. The standard acceptance test for static castings is a tensile test from a coupon cast from the same iron. This is

typically done with a separately cast ASTM A536 keel block, a modified keel block, or a Y-block. This standard provides an exception allowing the manufacturer to cut a test coupon from the casting or its runner system as a method of qualifying fittings when separately cast coupons are not available. The mechanical properties of iron castings are influenced by a variety of factors, including the cooling rate, iron chemistry, casting geometry, location of gates and risers, etc. These various factors cause an imprecise relationship between the mechanical properties in various locations of the same casting or between the casting and the separately cast coupon.

II.E. Advisory Information for the Purchaser and Specifier. Purchasers and specifiers should be aware that although products may be available that meet the intent of this standard, they may vary in dimensions, characteristics, material properties, or other features. The purchaser and specifier should become knowledgeable of the details of this standard and carefully evaluate the effect deviations from this standard may have on their project. One example of such a deviation is that some manufacturers may supply fittings with thinner flanges than indicated in the standard. While these fittings may have adequate strength for an application, a standard bolt kit may have insufficient threads on a bolt to adequately compress the gasket to prevent leakage.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C153/A21.53, ANSI Standard for Ductile-Iron Compact Fittings for Water Service, of latest edition.

2. Whether compliance with NSF/ANSI 61, Drinking Water System Components—Health Effects, is required.

- 3. Size and joint type (Sec. 1.1, 4.3, and Tables 1 through 15).
- 4. Details of other federal, state or provincial, and local requirements (Sec. 4.1).
- 5. Joint requirements (Sec. 4.3.1.1 and 4.3.1.2).
- 6. Joint accessories (Sec. 4.3.1.4).
- 7. End combinations (Sec. 4.3.1.5).

8. Standard linings (Sec. 4.4.1). Experience has indicated that petroleum asphaltic inside coating is not complete protection against loss in pipe capacity caused by tuberculation. Cement–mortar or fusion-bonded epoxy linings are recommended for most waters.

- 9. Special coatings and linings (Sec. 4.4.6).
- 10. Special flange bolt-hole orientation (Sec. 4.7.4).

11. Inspection by purchaser (Sec. 5.1.2).

12. Acceptance tests (Sec. 5.2.1).

13. Special tests (Sec. 5.4).

14. Affidavit of Compliance (Sec. 5.8).

III.B. *Modification to Standard*. Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. The major revisions in this edition of ANSI/AWWA C153/A21.53 are as follows:

1. An advisory statement for the purchaser and specifier was added in the foreword (Sec. II.E) regarding possible variations in products that may deviate from requirements in the standard.

2. The title of the standard was revised and the scope and other sections throughout the standard were updated to include wastewater and reclaimed water.

3. Sec. 4.3.1.6 was revised to require hydrostatic design tests of $2\frac{1}{2}$ times the rated working pressure.

4. Sec. 5.2.1.2.1 was revised to include 65-45-12 grade iron

5. Sec. 5.5 was revised to require a minimum safety factor of $2\frac{1}{2}$ times the rated working pressure for pressure tests on bends and crosses to reflect the change to the hydrostatic design pressure change made in Sec. 4.3.1.6.

6. Tables 3, 4, 5, and 6 were updated and additional sizes added to reflect the fittings that are being manufactured and used in the industry.

7. Figure 9 and Table 9 were added to include mechanical-joint tapped tees.

8. Figure 10 and Table 10 were added to include mechanical-joint and flange connecting pieces.

9. Figure 11 and Table 11 were added to include mechanical-joint offsets.

10. Old figures and old tables 9-15 from C153-06 have been renumbered to accommodate the new figures and tables added to the standard for additional mechanical-joint details (figures and tables 9-11).

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.

ANSI/AWWA C153/A21.53-11 (Revision of ANSI/AWWA C153/A21.53-06)



AWWA Standard

Ductile-Iron Compact Fittings

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes 3-in. through 64-in. (80-mm through 1,600-mm)* ductile-iron compact fittings to be used with ductile-iron pipe or pipe made of other materials with similar outside diameters for conveying potable water, wastewater and reclaimed water. Minimum working pressures by size range are as follows: 3 in. through 24 in. (80 mm through 600 mm): 350 psi (2,413 kPa); 30 in. through 48 in. (750 mm through 1,200 mm): 250 psi (1,724 kPa); and 54 in. through 64 in. (1,400 mm through 1,600 mm): 150 psi (1,034 kPa). Fittings are adequate for the rated working pressure plus a surge allowance of 100 psi or a surge allowance of half the rated working pressure, whichever is less.

Fittings with mechanical joints are listed in this standard for the 3-in. through 48-in. (80-mm through 1,200-mm) sizes. The standard also may be used for fittings of these sizes with push-on joints or other joints as agreed on at the time of purchase.

Fittings with push-on joints and flanged joints are listed in this standard for the 54-in. through 64-in. (1,400-mm through 1,600-mm) sizes. Fittings with flange joints are not discussed in this standard for sizes 3 in. through 48 in. (80 mm through

^{*} Metric conversions given in this standard are direct conversions of US customary units and are not those specified in International Organization for Standardization (ISO) standards.