



**American Water Works
Association**

ANSI/AWWA C209-06
(Revision of ANSI/AWWA C209-00)

The Authoritative Resource on Safe Water®

AWWA Standard

Cold-Applied Tape Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines



Effective date: Sept. 1, 2007

First edition approved by AWWA Board of Directors June 20, 1976.

This edition approved: June 11, 2006.

Approved by American National Standards Institute: Feb. 15, 2007.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
► **Science and Technology**
Sections

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 W. 43rd St., Fourth Floor, New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Science and Technology

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Committee Personnel

The Steel Water Pipe Manufacturers Technical Advisory Committee (SWPMTAC) Task Group for AWWA on C209, which developed this standard, had the following personnel at the time:

Don Kathrein, *Chair*

R.M. Buchanan, Canusa CPS, Toronto, Ont.	(AWWA)
B.H. Ellis, Hanson Pipe & Products Inc., Greensboro, N.C.	(AWWA)
R.W. Geary, Tek-Rap Inc., Houston, Texas	(AWWA)
B. Hayes, Tyco Adhesives, Lafayette, Calif.	(AWWA)
D. Kathrein, Tapecoat Company, Evanston, Ill.	(AWWA)
B.D. Keil, Continental Pipe Manufacturing Company, Pleasant Grove, Utah	(SPFA)
L. McKinney, Womble Company Inc., Houston, Texas	(AWWA)
R.D. Mielke, Northwest Pipe Company, Raleigh, N.C.	(AWWA)
S. Scarpone, Reilly Industries Inc., Indianapolis, Ind.	(AWWA)
D.A. Scott, Scapa Tapes North America, Calgary, Alta.	(AWWA)
J.A. Wise, Canus International Sales, Surrey, B.C.	(AWWA)

The AWWA Standards Committee on Steel Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

John H. Bambei Jr., *Chair*
George J. Tupac, *Vice-Chair*
Dennis A. Dechant, *Secretary*

General Interest Members

W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.L. Coffey, HDR Engineering Inc., Omaha, Neb.	(AWWA)
H.E. Dunham, MWH Inc., Bothell, Wash.	(AWWA)
S.N. Foellmi, Black & Veatch Corporation, Irvine, Calif.	(AWWA)
J.W. Green, McDonough Associates Inc., Chicago, Ill.	(AWWA)
M.B. Horsley, * Black & Veatch Corporation, Kansas City, Mo.	(AWWA)

* Alternate

J.K. Jeyapalan, Consultant, New Milford, Conn.	(AWWA)
W.J. Moncrief,* HDR Engineering Inc., San Diego, Calif.	(AWWA)
R. Ortega, Lockwood Andrews & Newnam, Houston, Texas	(AWWA)
A.E. Romer, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
H.R. Stoner, Consultant, North Plainfield, N.J.	(AWWA)
C.C. Sundberg, CH2M Hill Inc., Issaquah, Wash.	(AWWA)
G.J. Tupac, G.J. Tupac & Associates, Inc., Pittsburgh, Pa.	(AWWA)
J.S. Wailes,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
W.R. Whidden, Post Buckley Schuh & Jernigan, Orlando, Fla.	(AWWA)
M.C. Young,† Standards Council Liaison, Bucher Willis & Ratliff Corporation, Kansas City, Mo.	(AWWA)

Producer Members

S.A. Arnaut, Hanson Pipe & Products Inc., Dallas, Texas	(AWWA)
H.H. Bardakjian, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
M. Bauer, Tnemec Company Inc., North Kansas City, Mo.	(AWWA)
R.J. Card, Victaulic Depend-O-Lok Inc., Atlanta, Ga.	(AWWA)
R.R. Carpenter, American Cast Iron Pipe Co., Birmingham, Ala.	(MSS)
D. Dechant, Northwest Pipe Company, Denver, Colo.	(AWWA)
B.D. Keil, Continental Pipe Manufacturing Company, Pleasant Grove, Utah	(SPFA)
J.L. Luka,* American SpiralWeld Pipe Company, Columbia, S.C.	(AWWA)
B. Vanderploeg,* Northwest Pipe Company, Portland, Ore.	(AWWA)
J.A. Wise, Canus International Sales Inc., Surrey, B.C.	(AWWA)

User Members

G.A. Andersen, New York City Bureau of Water Supply, Little Neck, N.Y.	(AWWA)
--	--------

*Alternate

†Liaison, nonvoting

J.H. Bambei Jr., Denver Water Department, Denver, Colo.	(AWWA)
D.W. Coppes, Massachusetts Water Resources Authority, Southborough, Mass.	(NEWWA)
R.V. Frisz, US Bureau of Reclamation, Denver, Colo.	(USBR)
G. George, Tacoma Public Utilities, Tacoma, Wash.	(AWWA)
T.J. Jordan, Metropolitan Water District of Southern California, La Verne, Calif.	(AWWA)
M. McReynolds,* Metropolitan Water District of Southern California, La Mirada, Calif.	(AWWA)
G. Oljaca, Greater Vancouver Regional District, Burnaby, B.C.	(AWWA)
V.B. Soto, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
G.P. Stine, San Diego County Water Authority, Escondido, Calif.	(AWWA)
J.V. Young, City of Richmond, Richmond, B.C.	(AWWA)

*Alternate

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>			
I	ix	4.2	Materials and Workmanship..... 4
I.A	ix	4.3	Material Requirements..... 4
I.B	ix	4.4	Coating Application (Field and Shop)..... 5
II	ix	4.5	Field Procedures..... 8
II.A	ix	5	Verification
		5.1	Inspection 9
II.B	x	5.2	Electrical Inspection for Continuity... 9
II.C	x	5.3	Testing..... 11
II.D	x	5.4	Nonconformance 12
III	xi	6	Delivery
III.A	xi	6.1	Marking..... 12
III.B	xii	6.2	Packaging and Shipping..... 12
IV	xii	6.3	Affidavit of Compliance..... 13
V	xii		
 <i>Standard</i>			
1		<i>Appendixes</i>	
1.1	1	A	Estimating Surface Area of Pipe 13
1.2	2	<i>Tables</i>	
1.3	2	1	Physical Properties of Tape and Coatings..... 5
2	2	A.1	Linear Feet (Linear Meters) of Pipe Coated per 50-ft (15-m) Roll of Tape—Spiral Wrapped..... 16
3	3	A.2	Pipe Coverage Data—Cigarette Wrap 19
4			
4.1	4		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C209.

I. Introduction.

I.A. *Background.* Coatings for corrosion control can be extremely effective and are considered to be the primary line of defense against corrosion of steel pipeline systems. The requirements of a coating vary with the type of construction, the aggressiveness of the environment in which it will serve, and the system operating conditions. Cold-applied tapes provide ease of application without the use of special equipment and can be applied over a broad application temperature range.

I.B. *History.* The first edition of this standard, designated ANSI/AWWA C209-76, Standard for Cold-Applied Tape Coatings for Special Sections, Connections, and Fittings, was approved by the Board of Directors on June 20, 1976. The second edition, designated ANSI/AWWA C209-84, with the same title, was approved on June 10, 1984, and added shop and field blast cleaning to the coating and application section and revised the maximum overlap requirements. The third edition, ANSI/AWWA C209-90, was approved on June 17, 1990, and established new minimum thicknesses for prefabricated tape rolls and included information on new methods of application using wrapping machines. The fourth edition was approved on Jan. 23, 2000, and added information concerning alternative surface preparation application methods. This fifth edition was approved on June 11, 2006.

II. Special Issues.

II.A. *Advisory Information on Product Application.* Currently, tape coatings for special sections, connections, and fittings for underground steel water pipelines generally are used on pipe that has been coated before transportation to the field site. Where allowed by the purchaser, tapes described in ANSI/AWWA C209 can be used in conjunction with pipe coatings described in ANSI/AWWA C203, Standard for Coal-Tar Protective Coatings and Linings for Steel Water Pipelines—Enamel and Tape—Hot-Applied; ANSI/AWWA C210, Standard for Liquid-Epoxy Coating Systems for the Interior and Exterior of Steel Water Pipelines; ANSI/AWWA C213, Standard for Fusion-Bonded Epoxy Coating for the Interior and Exterior of Steel Water Pipelines; ANSI/AWWA C214, Standard for Tape Coating Systems for the Exterior of Steel Water Pipelines; ANSI/AWWA C215, Standard for Extruded

Polyolefin Coatings for the Exterior of Steel Water Pipelines; and ANSI/AWWA C216, Standard for Heat-Shrinkable Cross-Linked Polyolefin Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines. However, the compatibility of coating systems is a concern, and the manufacturer of tape described in this standard should be consulted to establish the degree of compatibility with the pipe-coating system involved.

ANSI/AWWA C209 defines cold-applied tape coating in terms of its performance or its ability to provide long-term protection and corrosion prevention. This standard is intended for use in the exterior coating of steel water pipelines for underground or underwater installation under normal conditions. This standard is based on the best-known experience, but is not intended for unqualified use under all conditions, and the advisability of its use for any installation must be reviewed by the purchaser. If an extended period of aboveground storage of coated pipe is anticipated, the ability of the coating to resist degradation by ultraviolet light and other atmospheric and environmental conditions should be considered.

II.B. *Mechanical Protection.* When construction or soil conditions exist in which mechanical damage to the coating is likely to occur, the use of an extra thickness of tape, suitable overwrap, and reinforcements or special backfills may be required. This will depend on the conditions encountered, but in general, an extra thickness of tape or other wrapping should be used. It should be spiral-wrapped, if possible, and bonded or mechanically held in place. Under these conditions, the tape manufacturer should be consulted for specific recommendations.

II.C. *Pipe Storage.* Because aboveground and environmental conditions for storage sites vary, the manufacturer should be consulted regarding the type of wrap recommended for the specific anticipated storage condition and the necessity for ultraviolet-light protection.

II.D. *Weld-After-Backfill.* Weld-After-Backfill is the sequence of assembling a welded joint, welding the outside joint (if required), applying the exterior coating(s), backfilling the pipe, and then welding the inside joint at a later time (where internal welding is safe and practical). The interior joint may not be welded until the applied exterior joint coating has been backfilled. Weld-After-Backfill is an acceptable practice provided that the requirements of applicable AWWA standards are followed. Consult with the manufacturers and other responsible parties regarding recommended products, installation, and backfill procedures required for the Weld-After-Backfill sequence. At the request of the purchaser, the coating manufacturer will

provide testing or historical information to verify that the exterior joint coating will retain performance requirements in accordance with the applicable standard throughout the heat-affected area.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C209, Cold-Applied Tape Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines, of latest revision.

2. Any required exceptions to the standard.

3. Operating temperature range (Sec. 1.1.1).

4. Descriptions of difficult conditions or aboveground exposure (Sec. 1.1.2).

5. Type of tape (Sec. 4.3.2.1).

6. Tape dimensions (Sec. 4.3.2.3).

7. Tape thickness (Sec. 4.3.2.4).

8. Visual-comparative standards (Sec. 4.4.2.3).

9. Adhesive solvents (Sec. 4.4.3).

10. Step-down areas (Sec. 4.4.4).

11. Tape-coating-system total thickness (Sec. 4.4.5). NOTE: The specific application procedure used for each type of coating system is as described by the tape manufacturer. The total thickness to be used is at the discretion of the purchaser, with consideration of the tape manufacturer's recommendations.

12. Coating repair (Sec. 4.4.6).

13. Pipe bedding and backfills (Sec. 4.5.5).

14. Optional inspection (Sec. 5.1.1).

15. Facilities for inspection (Sec. 5.1.4).

16. Acceptance testing (Sec. 5.3.1). NOTE: When the purchaser specifies that samples of proposed materials shall be submitted for testing by the purchaser, the purchaser should also address the assignment of associated testing costs. Common industry practice in these cases is that the cost of initial testing of coating-material samples originally offered by the constructor is borne by the purchaser. If any initial samples fail to conform to the standard, additional samples can be tested. Costs of testing additional samples are borne by the constructor.

17. Delivering pipe (Sec. 6).
18. Packaging (Sec. 6.2.1).
19. Affidavit of compliance, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. The major changes made to the standard in this edition include the following:

1. Sec. 1.1 was expanded to include use of ANSI/AWWA C209 tapes for repair of ANSI/AWWA C214 machine-applied coatings.
2. Consistent terminology for abrasive blast cleaning, abrasive mix, and visual comparative standards was added to Sec. 4.4.
3. A section on the treatment of step-down areas was added (Sec. 4.4.4).

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.



American Water Works
Association

ANSI/AWWA C209-06
(Revision of ANSI/AWWA C209-00)

AWWA Standard

Cold-Applied Tape Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes protective exterior coatings that consist of cold-applied liquid adhesives and prefabricated tapes and their applications to special sections, connections, and fittings to be used for underground and underwater steel water pipelines protected with organic coatings, such as those described in ANSI*/AWWA C203, ANSI/AWWA C210, ANSI/AWWA C213, ANSI/AWWA C214, ANSI/AWWA C215, and ANSI/AWWA C216. These liquid adhesives and tapes can be used for repair of ANSI/AWWA C214 machine-applied coatings in accordance

*American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.