



**American Water Works  
Association**

ANSI/AWWA C221-12  
(Revision of ANSI/AWWA C221-07)

The Authoritative Resource on Safe Water®

---

---

*AWWA Standard*

---

---

# Fabricated Steel Mechanical Slip-Type Expansion Joints



Effective date: Dec. 1, 2012.

First edition approved by AWWA Board of Directors Feb. 2, 1997.

This edition approved June 10, 2012.

Approved by American National Standards Institute Sept. 5, 2012.

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

Advocacy  
Communications  
Conferences  
Education and Training  
Science and Technology  
Sections

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal - American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal - American Water Works Association* publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or emailing [info@ansi.org](mailto:info@ansi.org).

ISBN-13, print: 978-1-58321-903-4  
ISBN-10, print: 1-58321-903-X

eISBN-13, electronic: 978-1-61300-198-1  
eISBN-10, electronic: 1-61300-198-3

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2012 by American Water Works Association  
Printed in USA

## Committee Personnel

The Steel Water Pipe-Manufacturer's Technical Advisory Committee (SWMPTAC) Task Group for AWWA C221, which reviewed and revised this standard, had the following personnel at the time:

Ram N. Satyarthi, *Chair*

Chris Shelley, *Vice-Chair*

E. Bird, Smith-Blair Inc., Texarkana, Texas	(AWWA)
S. Bradberry, Ford Meter Box Company, Pell City, Ala.	(AWWA)
R.J. Card, Manufacturing Consultant, Houston, Texas	(AWWA)
A. Collins, JCM Industries, Nash, Texas	(AWWA)
T.C. Crail, Straub Coupling, Bonsall, Calif.	(AWWA)
J. Grocki, Splash, Enfield, Conn.	(AWWA)
S. Lamb, Nickel Institute, Huntington, W. Va.	(AWWA)
D. Pointek, Total Piping Solutions Inc., Olean, N.Y.	(AWWA)
R.N. Satyarthi, Baker Coupling Company Inc., Los Angeles, Calif.	(AWWA)
C. Shelley, Victaulic Depend-O-Lok Inc., Atlanta, Ga.	(AWWA)
A. Steffan, Dresser Inc., Bradford, Pa.	(AWWA)
G. Tate, Viking Johnson, Hitchen, UK	(AWWA)
N. Thogersen, Romac Industries Inc., Bothell, Wash.	(AWWA)

The AWWA Standards Committee on Steel Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

John H. Bambei Jr., *Chair*

Dennis Dechant, *Vice-Chair*

John L. Luka, *Secretary*

### *General Interest Members*

W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.J. Card, Lockwood, Andrews & Newnam Inc., Houston, Texas	(AWWA)
R.L. Coffey, HDR Engineering Inc., Omaha, Neb.	(AWWA)
H.E. Dunham, MWH Inc., Snohomish, Wash.	(AWWA)
S.N. Foellmi, Black & Veatch, Irvine, Calif.	(AWWA)

R.L. Gibson, Freese and Nichols Inc., Fort Worth, Texas	(AWWA)
M.B. Horsley,* Horsley Engineering LLC, Overland Park, Kan.	(AWWA)
J.K. Jeyapalan, Dr. Jeyapalan & Associates, New Milford, Conn.	(AWWA)
R.A. Kufaas, Norske Corrosion & Inspection Services Ltd., Surrey, B.C.	(AWWA)
J.L. Mattson, Corrosion Control Technologies, Sandy, Utah	(AWWA)
W.J. Moncrief,* HDR Engineering Inc., San Diego, Calif.	(AWWA)
E.N. Olson,† Standards Council Liaison, Brown and Caldwell, Gold Hill, Ore.	(AWWA)
R. Ortega,* Lockwood Andrews & Newnam, Houston, Texas	(AWWA)
E.S. Ralph,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
A.E. Romer, AECOM, Newport Beach, Calif.	(AWWA)
H.R. Stoner, Henry R. Stoner Associates, North Plainfield, N.J.	(AWWA)
J.R. Snow,* MWH, Denver, Colo.	(AWWA)
C.C. Sundberg, CH2M HILL Inc., Issaquah, Wash.	(AWWA)
W.R. Whidden, Woolpert, Orlando, Fla.	(AWWA)

*Producer Members*

S.A. Arnaout, Hanson Pressure Pipe Inc., Dallas, Texas	(AWWA)
H.R. Bardakjian, Consultant, Glendale, Calif.	(AWWA)
R.R. Carpenter, American SpiralWeld Pipe Company, Birmingham, Ala.	(AWWA)
D. Dechant, Dechant Infrastructure Service, Aurora, Colo.	(AWWA)
W.B. Geyer, Steel Plate Fabricators Associates, Lake Zurich, Ill.	(SFPA)
B.D. Keil, Northwest Pipe Company, Pleasant Grove, Utah	(AWWA)
J.L. Luka,* American SpiralWeld Pipe Company, Columbia, S.C.	(AWWA)
R. Mielke,* Northwest Pipe Company, Raleigh, N.C.	(AWWA)
J. Olmos, Ameron Water Transmission Group, Rancho Cucamonga, Calif.	(AWWA)
G.F. Ruchti,* Consultant, Punta Gorda, Fla.	(SFPA)
D. Walker, Avid Protective Products Ltd/TNEMEC Company, Oakville, Ont.	(AWWA)
J.A. Wise, Canus International Sales Inc., Surrey, B.C.	(AWWA)

*User Members*


G.A. Andersen, New York City Bureau of Water Supply, Little Neck, N.Y.	(AWWA)
J.H. Bambei Jr., Denver Water, Denver, Colo.	(AWWA)
B. Cheng, Metro Vancouver, Vancouver, B.C.	(AWWA)

---

\* Alternate

† Liaison, nonvoting


R.V. Frisz, US Bureau of Reclamation, Denver, Colo.	(USBR)
G. George, Tacoma Public Utilities, Tacoma, Wash.	(AWWA)
T.J. Jordan, Metropolitan Water District of Southern California, La Verne, Calif.	(AWWA)
M. McReynolds,* Metropolitan Water District of Southern California, Oak Park, Calif.	(AWWA)
G. Oljaca,* Metro Vancouver, Burnaby, B.C.	(AWWA)
G.P. Stine, San Diego County Water Authority, Escondido, Calif.	(AWWA)
N.A. Wigner, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
J.V. Young, City of Richmond, Richmond, B.C.	(AWWA)



---

\* Alternate

This page intentionally blank.




# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b>Foreword</b>		4.3	Fabrication ..... 10
I	Introduction..... ix	4.4	Coatings..... 11
I.A	Background..... ix	4.5	Installation Instructions ..... 12
I.B	History..... ix	<b>5</b>	<b>Verification</b>
I.C	Acceptance..... ix	5.1	Inspection ..... 12
II	Special Issues..... x	5.2	Quality Assurance ..... 12
III	Use of This Standard ..... x	5.3	Test Procedures ..... 13
III.A	Purchaser Options and Alternatives ..... x	5.4	Nonconformance ..... 13
III.B	Modification to Standard ..... xi	<b>6</b>	<b>Delivery</b>
IV	Major Revisions..... xi	6.1	Marking..... 14
V	Comments ..... xii	6.2	Packaging and Shipping ..... 14
		6.3	Affidavit of Compliance ..... 14
<b>Standard</b>		<b>Figures</b>	
<b>1</b>	<b>General</b>	1	Typical Expansion Joint With Limit Rods..... 5
1.1	Scope ..... 1	2	Typical Expansion Joint Configurations ..... 5
1.2	Purpose ..... 1		
1.3	Application..... 1		
<b>2</b>	<b>References</b> ..... 2	<b>Tables</b>	
<b>3</b>	<b>Definitions</b> ..... 3	1	Minimum Physical Properties of Elastomeric Packing ..... 7
<b>4</b>	<b>Requirements</b> ..... 6	2	Pipe-end Diameter Tolerance ..... 8
4.1	Materials of Construction ..... 6		
4.2	Design..... 7		

This page intentionally blank.





# Foreword

*This foreword is for information only and is not a part of ANSI\*/AWWA C221.*

## **I. Introduction.**

I.A. *Background.* Fabricated steel mechanical slip-type expansion joints have been used for approximately 80 years to accommodate thermal movement in nonburied, aboveground pipelines, penstocks, and other conduits where expansion and contraction of more than ½ in. (13 mm) needs to be addressed. Though details differ, expansion joints of this type work in the same way and have similar components: a slip pipe, body, gland, packing chamber (with alternate rings of elastomeric material and lubricating rings), and follower ring. The expansion joints may also have a limit ring and limit rods and threaded fasteners (bolts and nuts) that, when tightened, compress the packing in the packing chamber to make a watertight seal while allowing the anticipated axial movement.

I.B. *History.* The first edition of ANSI/AWWA C221 was approved by the AWWA Board of Directors on Feb. 2, 1997. The second edition was approved on Jan. 21, 2001. The third edition was approved on June 24, 2007. This fourth edition was approved on June 10, 2012.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.† Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

---

\* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† Persons outside the United States should contact the appropriate authority having jurisdiction.

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on April 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, NSF\*/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,<sup>†</sup> and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier. ANSI/AWWA C221 does not address additive requirements. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

**II. Special Issues.** This standard has no applicable information for this section.

**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be included by the purchaser:

---

\* NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

† Both publications available from National Academy of Sciences, 500 fifth Street, N.W., Washington, DC 20001.

1. Standard used—that is, ANSI/AWWA C221, Fabricated Steel Mechanical Slip-Type Expansion Joints, of latest revision.
2. Whether compliance with NSF/ANSI 61, Drinking Water System Components—Health Effects, is required.
3. Quantity.
4. Wall thickness, schedule, or class.
5. Actual outside diameter(s) (OD) of pipe ends, including any coatings (Sec. 3[1]).
6. Nominal pipe size(s) (Sec. 3[9]).
7. Rated pressure, transient pressure, and test pressure (Sec. 3[15] and 5.3.1).
8. Details of other federal, state or provincial, and local requirements (Sec. 4.1.1).
9. Slip pipe finish (Sec. 4.1.2).
10. Type of steel (Sec. 4.1.2.1).
11. Bolt, rod, and nut materials (Sec. 4.1.3).
12. Operating temperature range and packing material (Sec. 4.1.4).
13. Tolerances of pipe ends (Sec. 4.1.4.3).
14. Design requirements and length and thickness of body and slip pipe where special performance or installation requirements exist (Sec. 4.2.1).
15. Anticipated axial movement (Sec. 4.2.1 and 4.2.3.3).
16. Special type of bolting (Sec. 4.2.2.5).
17. Type of pipe(s), including specification to which it is made; or specification, tolerance, and preparation of pipe ends (Sec. 4.2.3.2).
18. Shop and optional coatings (Sec. 4.4).
19. Material certifications (Sec. 5.1.1.2).
20. Purchaser's inspection requirements (Sec. 5.1.2).
21. Purchaser shall specify if a certified welding inspector (CWI) is required (Sec. 5.2).
22. Purchaser's proof test requirements (Sec. 5.3.1).
23. Hydrostatic test requirements (Sec. 5.3.2.2).
24. Additional nondestructive weld evaluation (Sec. 5.3.3).
25. Affidavit of compliance (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

**IV. Major Revisions.** The major changes made to the standard in this edition include the following:

1. The definitions for actual outside diameter, body, expansion joint, rated pressure, and transient pressure have been revised for consistency with other steel pipe documents.
2. Corrected the  $D/T_y$  limit in Sec. 4.2.2.1, Slip pipe, and Sec. 4.2.2.2, Body.
3. Clarified the functional requirements for bolts with respect to sealing mechanisms in Sec. 4.2.2.5, Bolting.
4. Old Sec. 4.3.2.4 on weld reinforcement thickness was deleted.
5. Information regarding the installation of an expansion joint based on temperature was deleted from Sec. 4.2.3.3, Expansion joint movement, and added and expanded on in Sec. 4.5, Installation Instructions.
6. Additional guidance on nondestructive testing (NDT) was added to Sec. 5.3.3, Production weld testing.

**V. Comments.** If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098, or email at [standards@awwa.org](mailto:standards@awwa.org).



**American Water Works  
Association**

---

---

*AWWA Standard*

---

---

# Fabricated Steel Mechanical Slip-Type Expansion Joints

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard describes fabricated steel mechanical slip-type expansion joints having packing chambers for use on pipe with plain, flanged, grooved, or shouldered ends in nominal pipe sizes from 3 in. through 144 in. (75 mm through 3,600 mm).<sup>\*</sup> The joints shall be manufactured from steel and are intended for use in systems conveying water. Mechanical expansion joints are not intended for use in buried conditions.

### Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for fabricated steel mechanical slip-type expansion joints, including system components, testing, and marking requirements.

### Sec. 1.3 Application

This standard can be referenced in documents for purchasing and receiving fabricated steel mechanical slip-type expansion joints and can be used as a guide

---

<sup>\*</sup> Metric conversions given in this standard are direct conversions of US customary units and are not those specified in International Organization for Standardization (ISO) standards.