



**American Water Works  
Association**

ANSI/AWWA C304-07  
(Revision of ANSI/AWWA C304-99)

The Authoritative Resource on Safe Water®

---

---

*AWWA Standard*

---

---

# Design of Prestressed Concrete Cylinder Pipe



Effective date: Dec. 1, 2007.

First edition approved by AWWA Board of Directors June 18, 1992.

This edition approved Jan. 21, 2007.

Approved by American National Standards Institute Jan. 11, 2007.

---

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

Advocacy  
Communications  
Conferences  
Education and Training  
► **Science and Technology**  
Sections

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

---

## **Science and Technology**

---

AWWA unites the entire water community by developing and distributing authoritative scientific and technological knowledge. Through its members, AWWA develops industry standards for products and processes that advance public health and safety. AWWA also provides quality improvement programs for water and wastewater utilities.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2007 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA standards subcommittee that revised this standard had the following personnel at the time of approval:

Michael M. Hicks, *Chair*

### *General Interest Members*

M.M. Hicks, MWH Americas Inc., Walnut Creek, Calif.	(AWWA)
A.E. Romer, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
C.C. Sundberg, CH2M Hill, Issaquah, Wash.	(AWWA)
M.S. Zarghamee, Simpson Gumpertz & Heger Inc., Waltham, Mass.	(AWWA)

### *Producer Members*

S.A. Arnaout, Hanson Pipe & Products Inc., Dallas, Texas	(AWWA)
H.H. Bardakjian, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
G. Bizien, Hyprescon Inc., St. Eustache, Que.	(AWWA)
A.W. Tremblay, Price Brothers Company, Dayton, Ohio	(AWWA)

The AWWA Standards Committee on Concrete Pressure Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

Wayne R. Brunzell, *Chair*

David P. Prosser, *Secretary*

### *General Interest Members*

W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.C. Edmunds, Jones Edmunds & Associates, Gainesville, Fla.	(AWWA)
W.D. Ensor, Hampton, Va.	(AWWA)
L.B. Freese, Freese and Nichols Inc., Fort Worth, Texas	(AWWA)
J.K. Haney, HDR Engineering Inc., Austin, Texas	(AWWA)
M.M. Hicks, MWH Americas Inc., Walnut Creek, Calif.	(AWWA)
R.Y. Konyalian, Consultant, Huntington Beach, Calif.	(AWWA)
S.A. McKelvie, Parsons Brinckerhoff Quade & Douglas Inc., Boston, Mass.	(NEWWA)
T. Niemann, Elizabeth Niemann & Associates, Louisville, Ky.	(AWWA)

P.J. Olson,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
J.J. Roller, CTL Group, Skokie, Ill.	(AWWA)
A.E. Romer, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
C.C. Sundberg, CH2M Hill, Issaquah, Wash.	(AWWA)
M.S. Zarghamee, Simpson Gumpertz & Heger Inc., Waltham, Mass.	(AWWA)

*Producer Members*

J.O. Alayon, Atlantic Pipe Corporation, San Juan, Puerto Rico	(AWWA)
S.A. Arnaout, Hanson Pipe & Products Inc., Dallas, Texas	(AWWA)
H.H. Bardakjian, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
G. Bizien, Hyprescon Inc., St. Eustache, Que.	(AWWA)
D. Dechant, Northwest Pipe Company, Denver, Colo.	(AWWA)
S.R. Malcolm, Vianini Pipe Inc., Somerville, N.J.	(AWWA)
D.P. Prosser, American Concrete Pressure Pipe Association, Reston, Va.	(ACPPA)
A.W. Tremblay, Price Brothers Company, Dayton, Ohio	(AWWA)

*User Members*

B.M. Bradish, City of Portsmouth, Portsmouth, Va.	(AWWA)
J. Galleher, San Diego County Water Authority, Escondido, Calif.	(AWWA)
J.W. Keith, Bureau of Reclamation, Denver, Colo. (abstained)	(AWWA)
D. Marshall, Tarrant Regional Water District, Fort Worth, Texas	(AWWA)
V.B. Soto, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
D.A. Wiedyke, Consultant, Clinton Township, Mich.	(AWWA)

---

\*Liaison, nonvoting

# Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.		PAGE	SEC.		PAGE
<b>Foreword</b>			<b>3</b>	<b>Load and Internal-Pressure</b>	
				<b>Combinations</b>	
I	Introduction .....	xi	3.1	Notation.....	8
I.A	Background .....	xi	3.2	Load Factors for Limit-States	
I.B	History .....	xv		Design.....	9
I.C	Acceptance.....	xv	3.3	Minimum Combined Design Loads	
II	Special Issues .....	xvi		and Pressures.....	9
III	Use of This Standard.....	xvii	3.4	Working Loads and Internal	
III.A	Purchaser Options and			Pressures .....	9
	Alternatives .....	xvii	3.5	Working Plus Transient Loads	
III.B	Modification to Standard .....	xviii		and Internal Pressures .....	9
IV	Major Revisions.....	xviii	3.6	Working Loads and Internal	
V	Comments.....	xviii		Field-Test Pressures .....	10
<b>Standard</b>			3.7	Load and Pressure Factors .....	10
<b>1</b>	<b>General</b>		<b>4</b>	<b>Moments and Thrusts</b>	
1.1	Scope.....	1	4.1	Notation.....	12
1.2	References.....	1	4.2	Distribution of Loads .....	13
1.3	Applications.....	3	4.3	Moments and Thrusts .....	13
1.4	Pipe Structure.....	3	<b>5</b>	<b>Design Material Properties</b>	
1.5	Tolerances .....	4	5.1	Notation.....	15
1.6	Definitions .....	4	5.2	Materials and Manufacturing	
1.7	Metric (SI) Equivalents .....	5		Standard.....	16
<b>2</b>	<b>Loads and Internal Pressures</b>		5.3	Properties of Core Concrete.....	16
2.1	Notation.....	5	5.4	Properties of Coating Mortar .....	21
2.2	Design Loads and Internal		5.5	Properties of Steel Cylinder.....	22
	Pressures.....	6	5.6	Properties of Prestressing Wire.....	23
2.3	Loads.....	6	<b>6</b>	<b>Stresses From Prestressing</b>	
2.4	Internal Pressures.....	7	6.1	Notation.....	25
			6.2	Prestress Losses .....	27

SEC.	PAGE	SEC.	PAGE
6.3	State of Stress With a Single Layer of Prestressing ..... 27	<b>9</b>	<b>Design Selection Tables</b>
6.4	State of Stress With Multiple Layers of Prestressing ..... 27	9.1	Design Example 1 ..... 62
6.5	Modular Ratios..... 29	9.2	Design Example 2 ..... 62
6.6	Design Creep Factor and Design Shrinkage Strain for Buried Pipe ..... 29	9.3	Design Example 3 ..... 63
6.7	Wire-Relaxation Factor..... 31	9.4	Lined-Cylinder Pipe Standard Prestress Design Tables ..... 63
<b>7</b>	<b>Criteria for Limit-State Loads and Pressures</b>	<i>Appendixes</i>	
7.1	Notation ..... 33	<b>A</b>	<b>Commentary</b>
7.2	Limit-States Design ..... 34	A.1	Introduction ..... 77
7.3	Serviceability Limit-States Design Criteria ..... 34	A.2	Commentary for Sec. 3.2 of the Standard ..... 77
7.4	Elastic Limit-States Design Criteria..... 36	A.3	Commentary for Sec. 3.5.1 of the Standard ..... 77
7.5	Strength Limit-States Design Criteria..... 36	A.4	Commentary for Sec. 3.5.2 of the Standard ..... 78
<b>8</b>	<b>Calculation of Limit-State Loads and Pressures</b>	A.5	Commentary for Sec. 3.6 of the Standard ..... 78
8.1	Notation ..... 38	A.6	Commentary for Sec. 4.3.2 of the Standard ..... 78
8.2	Limit-States Design Procedures ..... 41	A.7	Commentary for Sec. 4.3.3 of the Standard ..... 79
8.3	Maximum Pressures..... 41	A.8	Commentary for Sec. 5.3.3 and 5.4.2 of the Standard ..... 79
8.4	Maximum Thrust ..... 44	A.9	Commentary for Sec. 5.3.4 and 5.4.3 of the Standard ..... 79
8.5	Burst Pressure ..... 44	A.10	Commentary for Sec. 5.3.5 of the Standard ..... 79
8.6	Radial Tension ..... 44	A.11	Commentary for Sec. 5.5.2 of the Standard ..... 80
8.7	Combined Loads and Internal Pressures at Design Limit States..... 45	A.12	Commentary for Sec. 5.6.4 of the Standard ..... 80
8.8	Lines of Action of Thrusts..... 45	A.13	Commentary for Sec. 6 of the Standard ..... 81
8.9	Conformance With Limit-States Criteria..... 46		

SEC.	PAGE	SEC.	PAGE
A.14	Commentary for Sec. 6.4.1 of the Standard ..... 81	C.4.5	Decompression Pressure ..... 99
A.15	Commentary for Sec. 6.6 of the Standard ..... 81	C.5	Minimum Prestressing-Wire Area Based on Maximum Pressure..... 99
A.16	Commentary for Sec. 7 of the Standard ..... 81	C.6	Stress From Prestressing for Final Design Area ..... 100
A.17	Commentary for Sec. 7.5.5 of the Standard ..... 82	C.7	Serviceability at Full Pipe Circumference..... 102
A.18	Commentary for Sec. 8 of the Standard ..... 82	C.8	Serviceability at Invert/Crown..... 102
A.19	Commentary for Sec. 8.9 of the Standard ..... 82	C.8.1	Constants ..... 103
<b>B</b>	<b>References..... 89</b>	C.8.2	Strains ..... 104
<b>C</b>	<b>Pipe-Design Example</b>	C.8.3	Stresses ..... 105
C.1	Introduction ..... 91	C.8.4	Internal Forces..... 106
C.2	Design Parameters ..... 92	C.8.5	Sum of Forces ..... 107
C.2.1	Moment and Thrust Coefficients..... 94	C.8.6	Internal Moments..... 107
C.3	Maximum and Minimum Wire Areas ..... 95	C.8.7	Sum of Moments ..... 107
C.3.1	Maximum Prestressing-Wire Area Based on Minimum Wire Spacing ..... 95	C.9	Serviceability at Springline ..... 108
C.3.2	Minimum Allowable Prestressing- Wire Area Based on Maximum Wire Spacing ..... 95	C.9.1	Constants ..... 109
C.3.3	Minimum Prestressing-Wire Area Based on Burst Pressure..... 95	C.9.2	Strains ..... 110
C.4	State of Stress Calculations..... 96	C.9.3	Stresses ..... 110
C.4.1	Modular Ratios..... 96	C.9.4	Internal Forces..... 111
C.4.2	Creep, Shrinkage, and Wire Relaxation ..... 96	C.9.5	Sum of Forces ..... 111
C.4.3	Initial Prestress ..... 98	C.9.6	Internal Moments..... 111
C.4.4	Final Prestress..... 98	C.9.7	Sum of Moments About Wire..... 112
		C.10	Elastic Limit at Invert/Crown ..... 113
		C.11	Elastic and Wire-Yield Strength Limits at Springline ..... 114
		C.11.1	Limit State of Wire Yielding at Springline ..... 115
		C.11.2	Critical Thrust at Invert at Cylinder Yield, $N_{yy}$ ..... 115
		C.11.3	Moment Capacity at Invert and Redistributed Moment at Springline ..... 116

SEC.	PAGE	SEC.	PAGE
C.11.4	Critical Thrust at Wire Yield, $N_{y}$ .....	8	Schematic of Strain and Stress Distributions for Computation of $M_1$ -Moment Limit for Ultimate Compressive Strength of Coating.....
	118		59
C.11.5	Moment Capacity at Wire Yield.....		
	119		
C.12	Core Crushing at Springline.....		
	121		
C.12.1	Constants .....	9	Bedding Details for Prestressed Concrete Cylinder Pipe Embankment Condition.....
	121		74
C.12.2	Strains.....		
	121		
C.12.3	Stresses.....		
	122		
C.12.4	Forces .....	A.1	Mean Annual Number of Days Maximum Temperature of 90°F (32°C) and Above, Except 70°F (21°C) and Above in Alaska .....
	123		83
C.12.5	Sum of Forces.....		
	123		
C.12.6	Moments .....		
	123		
<b>Figures</b>		A.2	Mean Relative Humidity (January–March).....
1	Schematic Pipe-Wall Cross Sections for Lined- and Embedded-Cylinder Pipe.....		84
	3	A.3	Mean Relative Humidity (April–June).....
2	Stress–Strain Relationships for Concrete and Mortar in Tension and Compression .....		85
	19	A.4	Mean Relative Humidity (July–September) .....
3	Stress–Strain Relationship for Steel Cylinder in Tension and Compression .....		86
	23	A.5	Mean Relative Humidity (October–December) .....
			87
4	Stress–Strain Relationship for 6-Gauge Prestressing Wire in Tension After Wrapping at $f_{sg}$ .....	<b>Tables</b>	
	24	1	Load and Pressure Factors for Embedded-Cylinder Pipe.....
5	Schematic of Strain and Stress Distributions in Pipe-Wall Cross Section at Invert and Crown.....		11
	48	2	Load and Pressure Factors for Lined-Cylinder Pipe.....
6	Schematic of Strain and Stress Distributions in Pipe-Wall Cross Section at Springline .....		11
	52	3	Design Load Combinations and Calculation References for Embedded-Cylinder Pipe Criteria.....
7	Schematic of Strain and Stress Distributions for Computation of $M_2$ -Moment Limit for Ultimate Compressive Strength of Core Concrete .....		42
	56	4	Design Load Combinations and Calculation References for Lined-Cylinder Pipe Criteria .....
			43
		5	Standard Prestress Design—16 in. (410 mm) Lined-Cylinder Pipe ....
			64



SEC.		PAGE	SEC.		PAGE
6	Standard Prestress Design— 18 in. (460 mm) Lined-Cylinder Pipe.....	65	12	Standard Prestress Design— 48 in. (1,220 mm) Lined-Cylinder Pipe.....	71
7	Standard Prestress Design— 20 in. (510 mm) Lined-Cylinder Pipe.....	66	13	Standard Prestress Design— 54 in. (1,370 mm) Lined-Cylinder Pipe.....	72
8	Standard Prestress Design— 24 in. (610 mm) Lined-Cylinder Pipe.....	67	14	Standard Prestress Design— 60 in. (1,520 mm) Lined-Cylinder Pipe.....	73
9	Standard Prestress Design— 30 in. (760 mm) Lined-Cylinder Pipe.....	68	C.1	Summary of Calculations for Serviceability at Invert/Crown ....	108
10	Standard Prestress Design— 36 in. (910 mm) Lined-Cylinder Pipe.....	69	C.2	Summary of Calculations for Serviceability at Springline.....	113
11	Standard Prestress Design— 42 in. (1,070 mm) Lined-Cylinder Pipe.....	70	C.3	Summary of Calculations for Elastic Limit at Invert/Crown.....	114
			C.4	Summary of Calculations for Elastic Limits and Wire-Yield Limit at Springline.....	120

---

This page intentionally blank

# Foreword

*This foreword is for information only and is not part of ANSI/AWWA C304.*

## I. Introduction.

I.A. *Background.* This standard establishes the mandatory minimum requirements for the structural design of prestressed concrete cylinder pipe (PCCP) and provides procedures that will ensure that the design requirements are satisfied.

There are two types of PCCP: (1) lined-cylinder pipe (LCP), with a core composed of a steel cylinder lined with concrete, which is subsequently prestressed with high-tensile wire wrapped directly around the steel cylinder; and (2) embedded-cylinder pipe (ECP), with a core composed of a steel cylinder encased in concrete, which is subsequently prestressed with high-tensile wire wrapped around the exterior concrete surface. The cores of both types of pipe are coated with portland-cement mortar.

Before the procedures and requirements contained in this document were developed, the design of PCCP was determined by two distinct procedures. These were designated methods A and B described in appendixes A and B of ANSI\*/AWWA C301-84, Prestressed Concrete Pressure Pipe, Steel-Cylinder Type, for Water and Other Liquids.

Method A used a semiempirical approach based on (1)  $W_o$ , which is nine-tenths of the three-edge bearing test load that causes incipient cracking; and (2) the theoretical hydrostatic pressure,  $P_o$ , which relieves the calculated residual compression in the concrete core as a result of prestressing. The allowable combinations of three-edge bearing load and internal pressure were determined by a cubic parabola, passing through  $W_o$  and  $P_o$ , which defined the limits of these combinations. The three-edge bearing loads used in method A were converted to earth loads and transient external loads using bedding factors provided in AWWA Manual M9, *Concrete Pressure Pipe* (1979) and in the ACPA† *Concrete Pipe Design Manual* (1988).

Method B was based on a procedure that limited the maximum combined net tensile stress in pipe under static external load and internal pressure to a value equal to  $7.5\sqrt{f'_c}$ , where  $f'_c$  = the 28-day compressive strength of core concrete in psi ( $0.62\sqrt{f'_c}$ , where  $f'_c$  = the 28-day compressive strength of core concrete in MPa).

---

\*American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

†American Concrete Pipe Association, 1303 West Walnut Hill Lane, Suite 305, Irving, TX 75038.

Both design methods limited the working pressure to  $P_o$  for ECP and to  $0.8P_o$  for LCP, where  $P_o$  was the internal pressure required to overcome all compression in the core concrete excluding external load. Under transient conditions, such as those produced by surge pressures and live loads, both methods permitted increased internal pressure and external load.

Although the two methods of design produced similarly conservative results that served PCCP users well for nearly half a century, a unified method of design, described in this standard, was developed to replace methods A and B.

The following objectives for the unified design procedure were established:

1. It should replace both existing methods, the semiempirical method A and the working stress method B, described in ANSI/AWWA C301-84.
2. It should be based on state-of-the-art procedures for the design and analysis of concrete and prestressed concrete structures.
3. It should account for the state of prestress in the pipe, as well as the combined effects of external loads, pipe and fluid weights, and internal pressures.
4. It should agree with the results of 40 years of experimental data gathered by the American concrete pressure-pipe industry.
5. It should preclude the onset of visible cracking under working plus transient conditions.
6. It should provide adequate safety factors based on elastic and strength limit states.

The method of calculating residual stresses in the concrete core, the steel cylinder, and the prestressing wire was updated to separately account for the effects of elastic deformation, creep, and shrinkage of concrete, and the relaxation of the prestressing wire (Zarghamee, Heger, and Dana 1988a; see appendix B). Intrinsic wire relaxation, creep factors, and shrinkage strains obtained from procedures recommended by ACI\* Committee 209 (1982) (ACI 1982; see appendix B) were used in a step-by-step integration procedure (Zarghamee 1990; see appendix B) to evaluate the time-related variations of stress in the pipe elements. The results of the step-by-step integration procedure, applied to pipe in a buried environment, were used to develop simplified equations for practical design use.

Calculations of the design creep factor and shrinkage strain for buried pipe are based on the procedures recommended by ACI Committee 209. Creep and shrinkage are computed as functions of time, relative humidity, volume-to-surface ratio, age at

---

\*American Concrete Institute, 38800 Country Club Drive, Farmington Hills, MI 48331.

loading, curing duration, concrete composition, and method of placement. Design values for creep factor and shrinkage strain are based on a 50-year exposure of pipe to the environment to which typical pipe will be exposed. The default environment is given in the following scenario:

1. The pipe is initially stored outdoors for 270 days.
2. The pipe is buried and kept empty for 90 days.
3. The pipe is filled with water for the duration of its design life.

The periods of time given in items 1 and 2 above may be extended at the purchaser's discretion.

The design wire-relaxation factor was obtained by measuring the intrinsic loss of prestressing wire, manufactured in accordance with ASTM\* A648, Specification for Steel Wire, Hard Drawn for Prestressing Concrete Pipe, under constant strain and accounting for the reduction in relaxation loss caused by creep and shrinkage.

The simplified procedure, which separately accounts for concrete creep and shrinkage and wire relaxation, complies with test results (Zarghamee, Fok, and Sikiotis 1990; see appendix B) and with prior design practice (Zarghamee, Heger, and Dana 1988b; see appendix B).

The method adopted for determining allowable combinations of internal pressure, external loads, and pipe and fluid weights is based on satisfying certain limit-states design criteria (Heger, Zarghamee, and Dana 1990; see appendix B). The purpose of using limit-states design is to ensure the serviceability of pipe that is subject to working plus transient design loads and pressures. Limit-states design also ensures that the prestress and safety margins for pipe strength will be maintained even if the pipe is subjected to abnormal conditions that may cause visible cracking.

The limit-states design procedure is based on limiting circumferential thrust and bending moment resulting from internal pressure, external loads, and pipe and fluid weights. The procedure specifies that certain limit-states-design criteria are not exceeded when the pipe is subjected to working loads and pressures and to working plus transient loads and pressures.

In the design procedure, three sets of limit-states criteria are used: serviceability, elastic, and strength. To satisfy the three sets of limit-states criteria, combined loads and pressures corresponding to each of these limit states must be calculated. As a result, the combined moments and thrusts in the pipe wall corresponding to the limit states must be calculated, and both uncracked and cracked cross sections must be

---

\*ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428.

considered. For accurate calculation of these combined moments and thrusts, the constitutive properties of concrete and mortar in tension must be expressed correctly. A trilinear model for stress–strain relationships of concrete and mortar was adopted for use in the limit-states design of PCCP.

Serviceability limit-states criteria are intended to preclude microcracking in the core and to control microcracking in the coating under working loads and pressures. These criteria are also intended to preclude visible cracking in the core and the coating under working plus transient loads and pressures. Criteria are provided for the following:

1. Core-crack control.
2. Radial-tension control.
3. Coating-crack control.
4. Core-compression control.
5. Maximum pressure.

Elastic limit states are defined to limit combined working plus transient loads and pressures so that if cracks develop in a prestressed pipe under the transient condition, the pipe will have an elastic response, preventing damage or loss of prestress. Criteria are provided for the following states:

1. Wire-stress control.
2. Steel-cylinder-stress control.

Strength limit states are defined to protect the pipe against yielding of the prestressing wire, crushing of the concrete core under external load, and tensile failure of the wire under internal pressure. Safety factors are applied to loads and pressures that produce the strength limit states. The following criteria are provided:

1. Wire yield-strength control.
2. Core compressive-strength control.
3. Burst-pressure control.
4. Coating bond-strength control.

The limit-states design procedure for PCCP subjected to the combined effects of internal pressure, external loads, and pipe and fluid weights

1. Is a rational procedure based on state-of-the-art structural engineering practice for concrete structures.
2. Uses parameters resulting from many tests of prestressed concrete pipe and its constitutive materials.
3. Is substantiated by the results of combined-load and three-edge bearing verification tests of LCP and ECP.

The standard includes tables of standard designs for prestressed concrete LCP and a design example for ECP.

I.B. *History.* The AWWA Standards Committee on Concrete Pressure Pipe supported a recommendation that a design standard be developed for PCCP to be manufactured in accordance with ANSI/AWWA C301, Prestressed Concrete Pressure Pipe, Steel-Cylinder Type. On June 20, 1989, the C301 Design Subcommittee first met for the purpose of developing the design standard. At its October 1989 meeting, the AWWA Standards Council authorized a separate design standard for PCCP. The first edition of this standard, ANSI/AWWA C304, Design of Prestressed Concrete Cylinder Pipe, was approved by the Board of Directors on June 18, 1992. The second edition was approved on Jan. 24, 1999. This edition was approved on Jan. 21, 2007.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). AWWA and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.\* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed according to NSF, NSF<sup>†</sup>/ANSI<sup>‡</sup> 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

---

\*Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

4. Other references including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,\* and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C304 does not address additive requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additive requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

**II. Special Issues.** The information needed for selection of designs from the tables of standard designs includes:

1. Inside diameter of pipe (in. [mm]).
2. Internal working pressure (psi [kPa]).
3. Type of standard bedding.
4. Height of earth cover over the pipe (ft [m]).

The standard criteria used in the design selection tables are summarized in Sec. 9.4 preceding the design selection tables. If different design criteria are required by the purchaser, they should be specified by the purchaser, stated in the contract documents, and accounted for in the design of the pipe.

---

\*Both publications available from National Academy of Sciences, 500 Fifth Street, N.W., Washington, DC 20001.



**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

**III.A. Purchaser Options and Alternatives.** For LCP designs not included in the standard design tables and for all ECP designs, the design procedures specified in the standard must be implemented. For this purpose, the following information is to be provided by the purchaser:

1. Inside diameter of pipe (in. [mm]).
2. Fluid unit weight (lb/ft<sup>3</sup> [kg/m<sup>3</sup>]) if a fluid other than fresh water is required.
3. Height of earth cover over the pipe (ft [m]) or external dead load (lb/ft [kg/m]).
4. External surcharge load (lb/ft [kg/m]).
5. External transient load (lb/ft [kg/m]) if loading other than AASHTO\* HS20 loading is required.
6. Internal working pressure (psi [kPa]).
7. Internal transient pressure (psi [kPa]).
8. Internal field-test pressure (psi [kPa]).
9. Installation requirements.
10. Time period of exposure to outdoor environment (days) if more than 270 days.
11. Relative humidity of the outdoor environment.
12. Time exposure of pipe to burial environment before water filling (days) if more than 90 days.

**III.A.1. Information to be Provided by the Pipe Manufacturer.** In addition to the information listed above (Sec. III.A), the following information is to be provided by the pipe manufacturer:

1. Outside diameter of the steel cylinder (in. [mm]).
2. Thickness of the steel cylinder (in. [mm]).
3. Diameter of prestressing wire (in. [mm]).
4. Class of prestressing wire (II or III).
5. Number of layers of prestressing wire (one, two, or three).
6. Coating thickness over the prestressing wire (in. [mm]).

---

\*American Association of State Highway and Transportation Officials, 444 North Capitol St., N.W., Washington, DC 20001.

7. Coating thickness between layers of prestressing wire (in. [mm]).
8. Concrete 28-day compressive strength (psi [MPa]).
9. Concrete modulus of elasticity multiplier, if less than 0.9.
10. Concrete creep factor multiplier, if greater than 1.1.
11. Concrete shrinkage strain multiplier, if greater than 1.1.
12. Prestressing wire intrinsic relaxation multiplier, if greater than 1.1.

III.B. *Modification to Standard.* Any modifications to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. **Major Revisions.** The major revisions made to the standard in this edition include the following:

1. Editorial changes have been made throughout the standard to correct errors and to update the standard to AWWA standard style.

V. **Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at [standards@awwa.org](mailto:standards@awwa.org).



American Water Works  
Association

ANSI/AWWA C304-07  
(Revision of ANSI/AWWA C304-99)

---

---

## *AWWA Standard*

---

---

# Design of Prestressed Concrete Cylinder Pipe

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard defines the methods to be used in the structural design of buried prestressed concrete cylinder pipe (PCCP) under internal pressure. These methods are provided for the design of pipe subjected to the effects of working, transient, and field-test load and internal pressure combinations.

The design procedures of this standard are applicable to lined-cylinder pipe (LCP) having inside diameters of 16 in. through 60 in. (410 mm through 1,520 mm) and to embedded-cylinder pipe (ECP) having inside diameters of 24 in. (610 mm) and larger.

The design for longitudinal hydrostatic thrust restraint of prestressed concrete cylinder pipe is not addressed in this standard. See AWWA Manual M9, *Concrete Pressure Pipe*, for information on this topic.

### Sec. 1.2 References

Standard requirements for the manufacture of PCCP are contained in ANSI\*/AWWA C301, *Prestressed Concrete Pressure Pipe, Steel-Cylinder Type*. Procedures

---

\*American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.