



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C509-15
(Revision of ANSI/AWWA C509-09)

AWWA Standard

Resilient-Seated Gate Valves for Water Supply Service

Effective date: Feb. 1, 2016.

First edition approved by AWWA Board of Directors Jan. 28, 1980.

This edition approved June 7, 2015.

Approved by American National Standards Institute Oct. 30, 2015.




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal – American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal – American Water Works Association* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org.



ISBN-13, print: 978-1-62576-136-1

eISBN-13, electronic: 978-1-61300-362-6

DOI: <http://dx.doi.org/10.12999/AWWA.C509.15>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2015 by American Water Works Association
Printed in USA

Committee Personnel

The C509 Subcommittee, which developed this standard, had the following personnel at that time:

T. Chad Harbour, *Chair*

L.R. Dunn, U.S. Pipe & Foundry Company, Birmingham, Ala.	(AWWA)
L.W. Fleury Jr., Mueller Group, Smithfield, R.I.	(AWWA)
T.C. Harbour, Clow Valve Company, Oskaloosa, Iowa	(AWWA)
T.R. Ingalls,* EJ, USA Inc., East Jordan, Mich.	(AWWA)
R.L. Larkin, J and S Valve, Birmingham, Ala.	(AWWA)
R. Looney, American AVK Company, Minden, Nev.	(AWWA)
N.O. Mejia, L.A. Department of Water and Power, Los Angeles, Calif.	(AWWA)
T.J. Mettler, Waterous Company, South St. Paul, Minn.	(AWWA)
K.J. Wright, EJ, USA Inc., East Jordan, Mich.	(AWWA)

The AWWA Standards Committee on Gate Valves and Swing Check Valves, which reviewed and approved this standard, had the following personnel at the time of approval:

Joseph J. Gemin, *Chair*

General Interest Members

J.M. Assouline, CH2M HILL, Englewood, Colo.	(AWWA)
M.D. Bennett, MWH, Cleveland, Ohio	(AWWA)
D. Dieffenbach, Carollo, Phoenix, Ariz.	(AWWA)
J.J. Gemin, AECOM, Kitchener, Ont., Canada	(AWWA)
J. Hebensreit, Underwriters Laboratories Inc., Northbrook, Ill.	(UL)
M.C. Johnson, Utah State University Water Research Laboratory, Logan, Utah	(AWWA)
S.M. Passarelli,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
T.R. Volz, AECOM, Denver, Colo.	(AWWA)
M.P. Yoke, Anniston, Ala.	(AWWA)

* Alternate

† Liaison, nonvoting

Producer Members

J.V. Ballun, Val-Matic Valve & Manufacturing Corporation, Elmhurst, Ill.	(AWWA)
J. Bolender, J and S Valves, Huffman, Texas	(AWWA)
D.E. Burczynski,* Kennedy Valve, Elmira, N.Y.	(AWWA)
L.W. Fleury Jr., Mueller Group, Chattanooga, Tenn.	(AWWA)
T.C. Harbour, Clow Valve Company, Oskaloosa, Iowa	(AWWA)
T.R. Ingalls,* EJ, USA Inc., East Jordan, Mich.	(AWWA)
R.L. Larkin,* J and S Valve, Gardendale, Ala.	(AWWA)
R. Looney, American AVK Company, Minden, Nev.	(AWWA)
T.J. Mettler, Waterous Company, South St. Paul, Minn.	(AWWA)
D.B. Scott,* American Flow Control, Birmingham, Ala.	(AWWA)
J.H. Wilber,* American AVK, Littleton, Colo.	(AWWA)
K.J. Wright, EJ, USA Inc., East Jordan, Mich.	(AWWA)

User Members

R.L. Gardner,† Standards Council Liaison, Wannacomet Water Company, Nantucket, Mass.	(AWWA)
B. Hasanabadi, Colorado Springs Utilities, Colorado Springs, Colo.	(AWWA)
S. Hattan, Tarrant Regional Water District, Fort Worth, Texas	(AWWA)
K.S. Jeng-Bulloch, City of Houston, Houston, Texas	(AWWA)
M. MacConnell, Metro Vancouver, Burnaby, B.C., Canada	(AWWA)
J.S. Olson, Front Range Standard Committee, Littleton, Colo.	(AWWA)
A. Quiniones, US Bureau of Reclamation, Denver, Colo.	(AWWA)
D. Rausch, City of Aurora Water Department, Aurora, Colo.	(AWWA)
P.J. Ries, Denver Water Department, Denver, Colo.	(AWWA)

* Alternate


† Liaison, nonvoting

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4.5	Fabrication 22
I	Introduction..... vii	5	Verification
I.A	Background..... vii	5.1	Testing 22
I.B	History..... vii	5.2	Plant Inspection and Rejection 24
I.C	Acceptance..... vii	6	Delivery
II	Special Issues..... ix	6.1	Marking..... 25
II.A	Chlorine and Chloramine	6.2	Preparation for Shipment..... 25
	Degradation of Elastomers ix	6.3	Affidavit of Compliance 25
III	Use of This Standard..... ix	Appendixes	
III.A	Purchaser Options and	A	Installation, Operation, and
	Alternatives ix		Maintenance of Resilient-Seated
III.B	Modification to Standard xi		Gate Valves
IV	Major Revisions..... xi	A.1	General 27
V	Comments xi	A.2	Unloading 27
		A.3	Receiving Inspection 27
		A.4	Storage 28
		A.5	Installation..... 28
		A.6	Maintenance 31
		A.7	Repairs..... 32
Standard		Tables	
1	General	1	Design Torque..... 11
1.1	Scope 1	2	Minimum Full Waterway Sizes 11
1.2	Purpose..... 2	3	Minimum Thickness of Body
1.3	Application..... 2		and Bonnet 12
2	References 2	4	Minimum Thickness
3	Definitions 5		for Ductile-Iron Connecting
4	Requirements		End Flanges 13
4.1	Data to Be Supplied by the		
	Manufacturer 6		
4.2	Materials 7		
4.3	General Design 10		
4.4	Detailed Design 11		

SEC.		PAGE	SEC.		PAGE
5	Excess Flange Thickness	14	9	Outside Diameter of	
6	Stem Gate, Thrust Collar, and			Handwheels	20
	Stem Nut Copper Alloys	16	10	Gear Ratios	21
7	Stainless-Steel Valve Stem Alloys	17	11	Proof-of-Design Torque	23
8	Minimum Diameter of Stem and				
	Minimum Number of Turns				
	to Open.....	18			



Foreword

This foreword is for information only and is not a part of ANSI/AWWA C509.*

I. Introduction.

I.A. *Background.* This standard describes resilient-seated gate valves with nonrising stems (NRS) and outside screw-and-yoke (OS&Y) rising stems, including tapping gate valves for water supply service. The resilient-seated gate valve has been in service in various water utility applications since 1975.

I.B. *History.* The first edition of ANSI/AWWA C509, Resilient-Seated Gate Valves, was published in 1980. ANSI/AWWA C509 includes body and bonnet parts of either gray or ductile cast iron with shell-wall thicknesses equal to those of the ANSI/AWWA C500, Metal-Seated Gate Valves, which was first issued in 1952 as ANSI/AWWA C500 but had its roots going back to the first AWWA standard for gate valves adopted June 24, 1913.

The Manufacturers Standardization Society of the Valves and Fittings Industry (MSS) has played an important role in developing this standard. Founded in 1924, MSS has had official organizational representation on AWWA standards committees dealing with valve and hydrant products since 1930.

The first edition of ANSI/AWWA C509 was approved by the AWWA Board of Directors on Jan. 28, 1980, with subsequent editions in 1987, 1994, 2001, and 2009. This edition was approved on June 7, 2015.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International[†] (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation[‡] (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[§] Local agencies may choose to impose

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

‡ Water Research Foundation, 6666 West Quincy Avenue, Denver, CO 80235.

§ Persons outside the United States should contact the appropriate authority having jurisdiction.

requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF: NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,* and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C509 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

In an alternative approach to inadvertent drinking water additives, some jurisdictions (including California, Maryland, Vermont, and Louisiana at the time of this writing) are calling for reduced lead limits for materials in contact with potable water. Various third-party certifiers have been assessing products against these

* Both publications are available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

lead content criteria, and a new ANSI-approved national standard, NSF/ANSI 372, Drinking Water System Components—Lead Content, was published in 2010. On Jan. 4, 2011, legislation was signed revising the definition for “lead free” within the Safe Drinking Water Act (SDWA) as it pertains to “pipe, pipe fittings, plumbing fittings, and fixtures.” The changes went into effect on Jan. 4, 2014. In brief, the new provisions to the SDWA require that these products meet a weighted average lead content of not more than 0.25 percent.

II. Special Issues.

II.A. *Chlorine and Chloramine Degradation of Elastomers.* The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with chlorine or chloramines. Documented research has shown that elastomers such as gaskets, seals, valve seats, and encapsulations may be degraded when exposed to chlorine or chloramines. The impact of degradation is a function of the type of elastomeric material, chemical concentration, contact surface area, elastomer cross section, and environmental conditions as well as temperature. Careful selection of and specifications for elastomeric materials and the specifics of their application for each water system component should be considered to provide long-term usefulness and minimum degradation (swelling, loss of elasticity, or softening) of the elastomer specified.

III. **Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C509, Resilient-Seated Gate Valves for Water Supply Service, of latest revision.
2. Whether compliance with NSF/ANSI 372, Drinking Water System Components—Lead Content, or an alternative lead content criterion, is required.
3. Whether or not the purchaser requires that the cast ferrous valve components be made of ductile iron.
4. Quantity required.
5. Special packaging for shipment as may be required for protection of coatings.
6. Whether the pH level of the water is less than 6.5 or greater than 8.5.
7. Size and type of valve, NRS or OS&Y (Sec. 1.1).
8. Whether or not the valve will be used in a corrosive environment (Sec. 1.1.4) determined by methods described in AWWA Manual M27.

9. Catalog data, net weight, and assembly drawings to be provided by the manufacturer (Sec. 4.1), if required.

10. Details of other federal, state, or provincial and local requirements (Sec. 4.2.1).

11. If test records of valve component materials are required (Sec. 4.2.4.2).

12. Whether or not the valve will be subjected to water that reacts chemically with materials used in these valves. Consultation with the manufacturer is advised to determine the suitability in cases of doubt (Sec. 4.2.4.5.5).

13. Other coating requirements (Sec. 4.2.4.11) and whether coating (Sec. 4.5.2) shall be NSF/ANSI 61 approved.

14. Cutter diameter must be specified for tapping valves (Sec. 4.3.3).

NOTE: Tapping machine shell-cutters are made in either full size (outside diameter [OD] is full nominal size) or undersize (OD is less than full nominal size, i.e., usually ½ in. (13 mm) less [MSS SP-113]). The purchaser should specify the size of the shell-cutter that the valve must accept.

15. Left blank intentionally to match AWWA C515 Purchaser Options and Alternatives.

16. Type of valve ends—flanged, including dimensions (Sec. 4.4.1.4.1-2), spot facing (Sec. 4.4.1.4.1-3), straddled bolt holes (Sec. 4.4.1.4.1-5), mechanical joint (Sec. 4.4.1.4.2), push-on joint (Sec. 4.4.1.4.3), tapping valve flange (Sec. 4.4.1.4.4), and end flange requirements for tapping valves (Sec. 4.4.1.4.4-3).

17. Whether bolting material with physical and chemical properties other than ASTM A307 is required (Sec. 4.4.4). It is recommended that the purchaser verify with the supplier the appropriateness of any alternative bolting materials required. What alternative, if any, is desired in the type of rustproofing for bolts and nuts (Sec. 4.4.4.1).

18. Type of stem seal for NRS valves (Sec. 4.4.6.1) and for OS&Y valves (Sec. 4.4.6.2).

19. Packing material requirements (Sec. 4.4.6.2.1).

20. Whether the valve is handwheel or wrench-nut operated and the direction in which the handwheel or wrench nut shall turn to open (Sec. 4.4.7).

21. Detailed description of wrench nut, if not in accordance with Sec. 4.4.7.1.

22. Whether gearing is required (Sec. 4.4.8).

23. Gear material requirements (Sec. 4.4.8.1).

24. If gear casing is required (Sec. 4.4.8.2).

25. If position indicators are required (Sec. 4.4.8.3).

26. Whether or not records of tests specified in Section 5 are to be provided.

27. Special markings (Sec. 6.1.1.1.1), if required.

28. Affidavit of compliance (Sec. 6.3), if required.

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major changes made to the standard in this revision include the following:

1. Changed “if required by the purchaser” to “when required in the purchase documents.” User needs to call out options in its purchase document.

2. Format was updated to comply with the Style Guide for AWWA standards and harmonized with AWWA C515.

3. Updated Applicability to address considerations regarding valve’s suitability for wastewater applications.

4. Updated definition for Nominal Pipe Size and added definition for Nominal Valve Size.

5. Added new definition for Full Waterway and added new table for Minimum Waterway Sizes.


6. Added minimum yield strength and minimum elongation requirements for ductile iron.

7. Updated requirements for Coatings to include minimum average thickness.

8. Added requirements for Permeation.

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.

This page intentionally blank.





**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C509-15
(Revision of ANSI/AWWA C509-09)

AWWA Standard

Resilient-Seated Gate Valves for Water Supply Service

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes iron-body resilient-seated gate valves with nonrising stems (NRS) and outside screw-and-yoke (OS&Y) rising stems, including tapping gate valves, for water supply service having a temperature range of 33° to 125°F (0.6° to 52°C).

1.1.1 *Velocity.* These valves are intended for applications where fluid velocity does not exceed 16 ft/sec (4.9 m/sec) when the valve is in the full-open position.

1.1.2 *Sizes.* Gate valves described by this standard are 3-in. (75-mm) through 36-in. (900-mm) nominal pipe size (NPS).

1.1.3 *Valve pressure rating.* The minimum design working water pressure shall be 200 psig (1,380 kPa [gauge]) for 3- through 12-in. (75- through 300-mm) sizes and 150 psig (1,034 kPa [gauge]) for 14- through 36-in. (350- through 900-mm) sizes.

1.1.4 *Conditions and materials not covered.* This standard is not intended to describe special conditions of gate valve installation or operation, such as built-in power drive, installation in unusually corrosive soil, conveyance of unusually corrosive water, excessive water hammer, frequent operation (as in filter service), or