



**American Water Works
Association**

The Authoritative Resource for Safe Water®

ANSI/AWWA C510-07
(Revision of ANSI/AWWA C510-97)

AWWA Standard

Double Check Valve Backflow Prevention Assembly



Effective date: Oct. 1, 2008.

This first edition approved by AWWA Board of Directors Jan 27, 1969.

This edition approved June 24, 2007.

Approved by American National Standards Institute July 24, 2008.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2008 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Backflow Preventers, which reviewed and approved this standard, had the following personnel at the time of approval:

James T. Cowgill, *Chair*

Richard A. Coates, *Secretary*

General Interest Members

| | |
|--|---------|
| S.F. Asay, Drinking Water & Backflow Protection, Westminster, Colo. | (AWWA) |
| P.F. Barron,* Standards Council Liaison, Birmingham Water Works and Sewer Board, Birmingham, Ala. | (AWWA) |
| J.T. Cowgill, Hazen & Sawyer, Hollywood, Fla. | (AWWA) |
| K.J. Kelly, National Fire Sprinkler Association Inc., Patterson, N.Y. | (AWWA) |
| F.E. Kenney Jr., New England Water Works Association, Medway, Mass. | (NEWWA) |
| P.J. Olson,* Standards Engineer Liaison, AWWA, Denver, Colo. | (AWWA) |
| K.B. Patterson, Missouri Department of Natural Resources, Jefferson City, Mo. | (AWWA) |
| J.W. Poole, Poole Consulting Services Inc., Olathe, Kan. | (AWWA) |
| R.W. Rivard, State of Connecticut, Lebanon, Conn. | (AWWA) |
| L.J. Ruffin, L.J. Ruffin & Associates, Orlando, Fla. | (AWWA) |
| P.H. Schwartz, University of Southern California, Los Angeles, Calif. | (AWWA) |
| R.C. Williams, United States Public Health Service, Norcross, Ga. | (CDC) |

Producer Members

| | |
|--|--------|
| R.H. Ackroyd, Rand Engineering Inc., Newburyport, Mass. | (AWWA) |
| J.L. Brewer, FEBCO/SPX Process Equipment, Fresno, Calif. | (AWWA) |
| P. Chapman, Wilkins Inc., Fresno, Calif. | (AWWA) |
| L.W. Fleury Jr., Mueller Group, Smithfield, R.I. | (AWWA) |
| J.W. Furrer,† Hersey Meters, Fresno, Calif. | (AWWA) |
| J.F. Higdon, Conbraco Industries Inc., Pageland, N.C. | (AWWA) |
| G.H. Swenson, G.H. Swenson Enterprises, Clifton Park, N.Y. | (AWWA) |
| D. Whitelaw,† FEBCO/SPX Process Equipment, Fresno, Calif. | (AWWA) |

* Liaison, nonvoting

† Alternate

User Members

| | |
|--|--------|
| L. Aguiar,* Miami–Dade Water & Sewer Department, Miami, Fla. | (AWWA) |
| P.J. Brady, Construction Dynamics Group Inc., Richmond, Va. | (AWWA) |
| J.F. Caldwell, Coweta County Water & Sewer Department, Newnan, Ga. | (AWWA) |
| R.A. Coates, Miami–Dade Water & Sewer Department, Miami, Fla. | (AWWA) |
| E.J. Havlina, Los Angeles Department of Water and Power, Los Angeles, Calif. | (AWWA) |
| O.J. Jones, OTCO, Columbus, Ohio | (AWWA) |
| S.Y. Tung, City of Houston, Houston, Texas | (AWWA) |
| R. Werley, City of Bryan Water Services, Bryan, Texas | (AWWA) |

*Alternate

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

| SEC. | PAGE | SEC. | PAGE |
|-----------------|---|---------------|---|
| Foreword | | 3 | Definitions 3 |
| I | Introduction..... vii | 4 | Requirements |
| I.A | Background..... vii | 4.1 | Materials 4 |
| I.B | History..... vii | 4.2 | General Design 5 |
| I.C | Acceptance viii | 4.3 | Detailed Design 7 |
| II | Special Issues..... ix | 4.4 | Workmanship 9 |
| III | Use of This Standard..... x | 5 | Verification |
| III.A | Purchaser Options and Alternatives x | 5.1 | Testing and Uniformity..... 10 |
| III.B | Modification to Standard..... x | 6 | Delivery |
| IV | Major Revisions x | 6.1 | Marking..... 10 |
| V | Comments xi | 6.2 | Preparation for Shipment 11 |
| | | 6.3 | Affidavit of Compliance..... 11 |
| Standard | | Tables | |
| 1 | General | 1 | Parameters for Double Check Valve Backflow Prevention Assembly..... 6 |
| 1.1 | Scope 1 | 2 | Thermal Test Minimum Flow Rates 9 |
| 1.2 | Purpose 2 | | |
| 1.3 | Application 2 | | |
| 2 | References 2 | | |

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C510.

I. Introduction.

I.A. *Background.* The production and preservation of safe potable water is the objective of greatest priority for public water utilities and other agencies having jurisdiction. When safe water has been produced and put into the public distribution system, precautions must be taken to be certain that it is not contaminated with water or liquids from other sources.

Most water-using premises may have actual or potential cross-connection hazards. The water distribution systems of some premises served by public water systems, such as hotels, hospitals, and industrial plants, can be quite complex. On these premises, contaminated backflow into the public system can be a result of backpressure or backsiphonage from appliances and equipment or from cross-connection with other supply sources. Cross-connection control programs usually require that backflow prevention assemblies be installed at the water service connections to premises where potentially hazardous conditions exist.

Water users (utility customers) have a clearly implied responsibility to protect the safety of water in the public supply system. Water users must also protect the integrity of the water supply on their own premises. Protection of a building's piping system must be done in accordance with the requirements of the local authority having jurisdiction.

Cross-connections vary widely in degree of hazard. Generally, the degree of protection against backflow resulting from a cross-connection should be commensurate with the degree of hazard. Two types of backflow prevention assemblies are commonly used: the double check valve assembly and the reduced-pressure principle assembly. If local regulations or ordinances do not specify the type to use or the conditions under which one or the other may be used, recommendations may be found in the second edition of AWWA Manual M14, *Recommended Practice for Backflow Prevention and Cross-Connection Control*.

I.B. *History.* The Conference of State Sanitary Engineers (CSSE) and the American Water Works Association (AWWA) appointed the Joint Committee on Backflow Preventers and Cross-Connection Control in September 1959 to carry out the recommendations of an earlier joint committee. These recommendations were included in the joint committee's final report published in the December 1958 edition

of *Journal AWWA*. The first chair, Ray L. Derby, then with the Los Angeles Department of Water and Power, served until April 1964. From April 1964 until March 1972, Gustave J. Angele Sr., plant sanitary engineer, Union Carbide Nuclear Division, served as chair. From March 1972 until April 1983, Ernest J. Havlina, Los Angeles Department of Water and Power, served as chair. From April 1983 until April 1993, Patrick J. Brady, Department of Public Utilities, County of Henrico, Richmond, Va., served as chair. Since then, the work has been completed under the direction of the present chair, James T. Cowgill, Hazen & Sawyer Engineers, Hollywood, Fla.

The first work of the committee resulted in the first edition of AWWA Manual M14, which was published in the April 1966 edition of *Journal AWWA*.

After publication of AWWA Manual M14, the committee produced a standard that received final approval from the AWWA Board of Directors on Jan. 27, 1969, and was designated as AWWA C506-69, Standard for Backflow Prevention Devices—Reduced Pressure Principle and Double Check Valve Types. Revision of ANSI/ AWWA C506 was approved in 1978. The 1978 edition was subsequently reaffirmed without revision in 1983.

In 1989, ANSI/AWWA C506-78 was separated into two standards: ANSI/ AWWA C510 covers the double check valve backflow prevention assembly, and ANSI/AWWA C511 covers the reduced-pressure principle backflow prevention assembly. The second revision to ANSI/AWWA C510 was approved by the AWWA Board of Directors on June 15, 1997. This edition was approved June 24, 2007.

I.C. Acceptance. In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health

*Persons outside the United States should contact the appropriate authority having jurisdiction.

effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, NSF*/ANSI[†] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[‡] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C510 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues. This standard has no applicable information for this section.

*NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

†American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

‡Both publications available from National Academy of Sciences, 500 Fifth Street, N.W., Washington, DC 20001.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be covered by the purchaser:

1. Standard used—that is, ANSI/AWWA C510, Double Check Valve Backflow Prevention Assembly, of latest revision.
2. Whether compliance with NSF/ANSI 61 Drinking Water System Components—Health Effects, is to be required, in addition to the requirements of the Safe Drinking Water Act.
3. Whether for hot or cold water (Sec. 1.1).
4. Materials if other than those specified in Sec. 4.1.
5. Details of other federal, state or provincial, and local requirements (Sec. 4.1.)
6. Size, flow, and pressure loss (Sec. 4.2.1), and number of assemblies required.
7. Type of end connection—flanged, threaded, or grooved and shouldered (Sec. 4.3.1.2).
8. Affidavit of compliance (Sec. 6.3), if required.
9. Certificate of approval (Sec. 6.3), if required.

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this revision include the following:

1. AWWA standard materials statement has been added (Sec. III.A.2 and Sec. 4.1).
2. Synthetic coating of ferrous bodies has been removed (Sec. 4.1.2).
3. The material callouts have been updated (Sec. 4.1.3).
4. The identification of nominal size of the assembly has been revised (4.2.1.1).
5. The requirements for structural capability and operational capability have been revised (Sec. 4.2.2.1 and Sec. 4.2.2.2).
6. The sections on area of waterways, clearance of moving parts, facing rings for poppet-type valves, facing rings for swing-type valves, and bushings have been removed (former Sec. 4.3.1.2 through Sec. 4.3.1.6).
7. The requirements for shutoff valves have been updated (Sec. 4.3.1.6).
8. Requirements for operational cycle testing have been added (Sec. 4.3.2.3).
9. Requirements for replacement parts have been added (Sec. 4.3.4).

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.

This page intentionally blank.



American Water Works
Association

ANSI/AWWA C510-07
(Revision of ANSI/AWWA C510-97)

AWWA Standard

Double Check Valve Backflow Prevention Assembly

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes the double check valve backflow prevention assembly. The assembly shall be for operation on hot or cold water lines and capable of withstanding a working water pressure of at least 150 psi (1,034 kPa) without damage to working parts or impairment of function.

This standard describes hot- and cold-water double check valve backflow prevention assemblies. Assemblies shall be designed to operate at a minimum temperature range of 33°F to 140°F (1°C to 60°C). Hot water assemblies shall be designed to operate, at a minimum, in water at a temperature range of 33°F to 180°F (1°C to 82°C).

A complete assembly consists of two internally loaded, independently operating check valves, located between two tightly closing resilient-seated shutoff valves, with four properly placed resilient-seated test cocks (see Sec. 4.3.1.3).