



**American Water Works  
Association**

ANSI/AWWA C518-08  
(First Edition)

The Authoritative Resource on Safe Water®

---

---

*AWWA Standard*

---

---

# Dual-Disc Swing- Check Valves for Waterworks Service



Effective date: October 1, 2008.

First edition approved by AWWA Board of Directors Jan. 27, 2008.

Approved by American National Standards Institute April 18, 2008.

---

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

Advocacy  
Communications  
Conferences  
Education and Training  
Science and Technology  
Sections

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of Journal AWWA. The action becomes effective on the first day of the month following the month of Journal AWWA publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

## Committee Personnel

The AWWA Standards Committee on Gate Valves and Swing-Check Valves, which reviewed and approved this standard, had the following personnel at the time of approval:

Joseph J. Gemin, *Chair*

Thomas M. Bowen, *Vice-Chair*

Roland L. Larkin, *Secretary*

### *General Interest Members*

J.M. Assouline,* CH2M Hill, Englewood, Colo.	(AWWA)
R.L. Claudy Jr., Orlando, Fla.	(AWWA)
K.G. Clegg, CH2M Hill, Corvallis, Ore.	(AWWA)
J.J. Gemin, EarthTech (Canada), Kitchener, Ont.	(AWWA)
M.C. Johnson, Utah State University, Logan, Utah	(AWWA)
G.E. Laverick, Underwriters Laboratories Inc., Northbrook, Ill.	(UL)
T.J. McCandless,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
P.I. McGrath Jr., Birmingham, Ala.	(AWWA)
T.R. Volz, URS Corporation, Denver, Colo.	(AWWA)
K. Zastrow,* Underwriters Laboratories Inc., Northbrook, Ill.	(AWWA)

### *Producer Members*

J.V. Ballun, Val-Matic Valve & Manufacturing Corporation, Elmhurst, Ill.	(AWWA)
J. Bottenfield, Clow Valve Company, Oskaloosa, Iowa	(MSS)
T.R. Ingalls,* East Jordan Iron Works Inc., Chicago, Ill.	(AWWA)
L.W. Fleury Jr., Mueller Group, Smithfield, R.I.	(AWWA)
S. Flora,* M&H Valve Company, Anniston, Ala.	(AWWA)
R.L. Larkin, American Flow Control, Birmingham, Ala.	(AWWA)
R. Looney, American AVK Company, Fresno, Calif.	(AWWA)
T.J. Mettler,* Waterous Company, South St. Paul, Minn.	(AWWA)
J.H. Wilber,* American AVK, Littleton, Colo.	(AWWA)
K.J. Wright, East Jordan Iron Works Inc., East Jordan, Mich.	(AWWA)

---

\* Alternate

† Liaison, nonvoting

*User Members*

T.M. Bowen, Manchester Water Works, Manchester, N.H.	(AWWA)
R.L. Gardner,* Standards Council Liaison, Wannacomet Water Company, Nantucket, Mass.	(AWWA)
K.W. Gruber, East Bay Municipal Utility District, Oakland, Calif.	(AWWA)
K.S. Jeng-Bullock, City of Houston, Houston, Texas	(AWWA)
J.S. Olson, Denver Water, Denver, Colo.	(AWWA)
S.D. Tucker, Los Angeles Water and Power, Los Angeles, Calif.	(AWWA)

---

\* Liaison, nonvoting

## Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b><i>Foreword</i></b>		4.5	Workmanship and Painting . . . . . 9
I	Introduction . . . . . vii	<b>5</b>	<b>Verification</b>
I.A	Background. . . . . vii	5.1	Inspection . . . . . 9
I.B	History . . . . . vii	5.2	Testing . . . . . 9
I.C	Acceptance . . . . . vii	5.3	Notice of Nonconformance . . . . . 10
II	Special Issues . . . . . viii	<b>6</b>	<b>Delivery</b>
II.A	General . . . . . viii	6.1	Marking . . . . . 11
II.B	Advisory Information on Product Application . . . . . ix	6.2	Shipping . . . . . 11
III	Use of This Standard . . . . . ix	6.3	Affidavit of Compliance. . . . . 11
III.A	Purchaser Options and Alternatives ix	<b><i>Appendix</i></b>	
III.B	Modification to Standard. . . . . x	<b>A</b>	<b>Installation, Operation, and Maintenance of Dual-Disc Swing-Check Valves</b>
IV	Major Revisions. . . . . xi	A.1	General . . . . . 13
V	Comments. . . . . xi	A.2	Unloading . . . . . 13
<b><i>Standard</i></b>		A.3	Storage. . . . . 13
<b>1</b>	<b>General</b>	A.4	Inspection Prior to Installation . . . 13
1.1	Scope. . . . . 1	A.5	Installation . . . . . 14
1.2	Purpose . . . . . 2	A.6	Field Testing . . . . . 14
1.3	Application . . . . . 2	A.7	Owner's Records . . . . . 15
<b>2</b>	<b>References . . . . . 2</b>	A.8	Operation . . . . . 15
<b>3</b>	<b>Definitions . . . . . 3</b>	A.9	Maintenance . . . . . 15
<b>4</b>	<b>Requirements</b>	<b><i>Tables</i></b>	
4.1	Permeation . . . . . 4	1	End-to-End Dimensions for Wafer and Threaded-Lug Valves . . . . . 7
4.2	Data to Be Provided by the Manufacturer or Supplier . . . . . 4	2	Valve Test Cycles Required . . . . . 10
4.3	Materials . . . . . 5		
4.4	General Design . . . . . 6		

This page intentionally blank.

## Foreword

*This foreword is for information only and is not a part of ANSI/AWWA C518.*

### I. Introduction

I.A. *Background.* Dual-disc swing-check valves have been commonly used on pump discharge applications in the waterworks industry for more than half a century. These check valves are designed to prevent backflow by automatically closing rapidly on flow-reversal. They provide tight shutoff while requiring relatively little space for installation.

I.B. *History.* The need for standardization of dual-disc swing-check valves was recognized by the American Water Works Association (AWWA) in 1992. The AWWA Gate and Check Valve Committee worked to publish this first edition of ANSI/AWWA C518 beginning in 2003. It was approved by the AWWA Board of Directors on Jan. 27, 2008.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.\* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, NSF<sup>†</sup>/ANSI<sup>‡</sup> 60,

---

\* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,\* and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C518 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

## **II. Special Issues.**

II.A. *General.* Conditions under which a valve is to be operated must be evaluated carefully by the purchaser. The evaluations must include the determination of the hydraulic characteristics of the system in which the valve will be installed and the operation of the valve including (1) the maximum transient and static differential pressure across the valve disc and (2) minimum and maximum flow through the valve under the most adverse operating conditions.

Hydraulic testing, flow capacities, and valve characteristics are based on the flow upstream of a valve being uniform and undisturbed, like the flow produced by a constant-diameter, straight pipe of at least six diameters. Piping configurations that

---

\* Both publications available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

produce a nonuniform or turbulent flow pattern upstream of the valve can create damaging vibrations, increase head loss, and increase stresses in valve components.

**II.B. *Advisory Information on Product Application.*** This standard does not describe all possible applications or manufacturing technologies. The purchaser should identify special requirements and required deviations from this standard and include appropriate language in purchase documents. Refer to Sec. III.A in this foreword. Other advisory information is provided below.

1. Check valves may be subject to excessive wear if there is insufficient flow to open the valve fully. Manufacturers can supply information during the valve sizing process to prevent this from occurring.

2. These valves are designed for use with clean water and installation in horizontal pipelines with the hinge pin oriented in the vertical or vertical lines with flow upward. If installed in a flow-down application, the valves may not have sufficient spring torque to close.

3. These valves are sometimes used for air blower discharge service and therefore are subject to unusual temperature and flow conditions. Air service should be considered a special application for this valve and warrants a review of the operating parameters with the supplier or manufacturer.

4. When open, the valve discs extend a significant distance into the downstream piping and may strike or interfere with downstream valves or flow elements. A sufficient distance of open pipe downstream of the valve should be planned for every installation.

**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

**III.A. *Purchaser Options and Alternatives.*** The following items should be provided by the purchaser:

1. Standard to be used—that is, ANSI/AWWA C518, Dual-Disc Swing-Check Valves for Waterworks Service, of latest edition.

2. Whether compliance with NSF/ANSI 61 Drinking Water System Components—Health Effects is required.

3. Size of check valves.

4. Quantity required.

5. Maximum line pressure.

6. Required flow rate through valve.

a. Under minimum conditions.

b. Under maximum-flow conditions.

7. Description of connecting piping: material, outside diameter (OD) and inside diameter (ID), and end connection.

8. Valve arrangement and position (horizontal or vertical flow-up pipe installation).

9. Maximum transient pressure and characteristics, if known.

10. Water temperature range.

11. A drawing or description of the piping arrangement sufficient to describe significant turbulent line flow conditions to which the valve disc may be subjected.

12. Considerations relating to anticipated problems with rubber components exposed to line content containing chlorine, chloramines, or other chemicals. If these problems are anticipated, the purchaser should identify the maximum expected concentrations of these chemicals and other factors, such as pH and temperature ranges, which may affect the corrosivity of these chemicals. The purchaser should consult with the manufacturers and, if appropriate, specify special requirements for these components.

13. Details of other federal, state or provincial, and local requirements (Sec. 4.3.1).

14. Data to be provided by the manufacturer or supplier. Sec. 4.2 describes the minimum data to be provided by the supplier. Additional requirements should be clearly defined in the purchase documents.

15. If certified drawings are to be provided by the manufacturer (Sec. 4.2).

16. Laying length if other than specified in Sec. 4.2.

17. Whether the valve will be subjected to water that promotes galvanic corrosion or that reacts chemically with materials used in these valves and requires the use of alternate disc materials as described in Sec. 4.4.4.1.

18. Protective coatings if other than specified in Sec. 4.5.2 of this standard.

19. If shop inspection of tests by the purchaser is required (Sec. 5.1).

20. The providing of test records that are specified according to Sec. 5.2.1, 5.2.2, and 5.2.3 of this standard. The purchaser may require all records or may stipulate a breakdown of production test records.

21. If an affidavit of compliance is to be provided (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

**IV. Major Revisions.** This is the first edition of the standard.

**V. Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at [standards@awwa.org](mailto:standards@awwa.org).

This page intentionally blank.



**American Water Works  
Association**

ANSI/AWWA C518-08  
(First Edition)

---

---

*AWWA Standard*

---

---

# Dual-Disc Swing-Check Valves for Waterworks Service

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard establishes minimum requirements for dual-disc swing-check valves, 2-in. (50-mm) through 48-in. (1,200-mm) NPS for clean water having a pH range from 6 to 10 and a temperature range of 33°–125°F (0.6°–52°C).

1.1.1 *Body types.* Valves described in this standard are provided with wafer or threaded-lug ends for installation between ANSI Class 125 flanges or grooved ends for use with IPS pressure pipe.

1.1.2 *Gray-iron pressure ratings.* The minimum design working water pressure for gray-iron valves shall be 200 psig (1,380 kPa) for 2-in. through 12-in. (50-mm through 300-mm) sizes and 150 psig (1,030 kPa) for 14-in. through 48-in. (350-mm through 1,200-mm) sizes.

1.1.3 *Ductile-iron pressure ratings.* The minimum design working water pressure for ductile-iron valves shall be 250 psig (1,380 kPa) for 2-in. through 48-in. (50-mm through 1,200-mm) sizes.

1.1.4 *Fluid velocity rating.* The maximum fluid velocity shall be 16 ft/sec (4.9 m/sec).

1.1.5 *Installations.* Dual-disc swing-check valves are designed for