



**American Water Works  
Association**

ANSI/AWWA C670-09  
(First Edition)

The Authoritative Resource on Safe Water®

---

---

*AWWA Standard*

---

---

# Online Chlorine Analyzer Operation and Maintenance



Effective date: June 1, 2010.

First edition approved by AWWA Board of Directors June 14, 2009.

Approved by American National Standards Institute April 28, 2010.

---

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

*Advocacy  
Communications  
Conferences  
Education and Training  
Science and Technology  
Sections*

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing [info@ansi.org](mailto:info@ansi.org).

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA Standards Committee on Online Monitoring, which reviewed and approved this standard, had the following personnel at the time of approval:

Darryl Green, *Chair*

### *General Interest Members*

R.C. Cheng,* Standards Council Liaison, Long Beach Water Department, Long Beach, Calif.	(AWWA)
P.L. Kline,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
T.A. Pajor, City of Wichita, Wichita, Kan.	(AWWA)
D. Shehee, Kentucky American Water, Lexington, Ky.	(AWWA)
W.J. Soucie, Central Lake Company Water Agency, Lake Bluff, Ill.	(AWWA)
C.D. Tona, Zone 7 Alameda County, Livermore, Calif.	(AWWA)

### *Producer Members*

J. Evans, Chemtrac Systems Inc., Norcross, Ga.	(AWWA)
B.G. LaBelle, GF Piping Systems, Tustin, Calif.	(AWWA)
V. Malkov, Hach Company, Loveland, Colo.	(AWWA)
D. Page, PDA Security Solutions Inc., Greer, S.C.	(AWWA)

### *User Members*

E. Elma, MAWC Indian Creek WTP, Connellsville, Pa.	(AWWA)
D. Green, Jackson Energy Authority, Jackson, Tenn.	(AWWA)
R.L. Higgins, American Water, Monroe, Wash.	(AWWA)
M.E. Richardson, City of Wilmington, Wilmington, N.C.	(AWWA)
T.M. Scribner, City of Westminster, Broomfield, Colo.	(AWWA)
R. Sparks, Springfield City Utilities, Springfield, Mo.	(AWWA)

---

\* Liaison, nonvoting

This page intentionally blank.

## Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b><i>Foreword</i></b>		<b>2</b>	<b>References</b> ..... 2
I	vii	<b>3</b>	<b>Definitions</b> ..... 3
I.A	vii	<b>4</b>	<b>Requirements</b>
I.B	vii	4.1	Principles of Operation ..... 6
I.C	vii	4.2	Sensor Systems ..... 7
II	ix	4.3	Reagents and Electrolytes ..... 7
II.A	ix	4.4	Sample Collection System ..... 8
Information on the Application of This Standard		4.5	Electrical System ..... 9
III	ix	4.6	Sampling Techniques ..... 10
III.A	ix	4.7	Analyzer Performance ..... 11
Purchaser Options and Alternatives		4.8	Calibration Techniques ..... 12
III.B	ix	<b>5</b>	<b>Verification</b>
IV	ix	5.1	Instrument Verification ..... 14
V	ix	5.2	Record Keeping ..... 14
<b><i>Standard</i></b>		<b>6</b>	<b>Delivery</b> ..... 15
<b>1</b>	<b>General</b>		
1.1	1		
Scope			
1.2	1		
Purpose			
1.3	2		
Application			

This page intentionally blank.

## Foreword

*This foreword is for information only and is not a part of ANSI/AWWA C670.*

### **I. Introduction.**

I.A. *Background.* This standard describes online chlorine analyzer operation and maintenance when the online chlorine analyzer is used in the treatment and monitoring of municipal water supplies, or in the treatment of municipal wastewater.

I.B. *History.* The first scientific approach to the use of chlorine in water treatment was conducted between 1917 and 1920 by Wolman and Enslow. Their determination of chlorine absorption in water demonstrated the use of the orthotolidine test for chlorine residuals. The chlorination breakpoint phenomenon was discovered in 1939 and revealed the speciation of free available and combined chlorine residuals. The amperometric method of measuring total chlorine residuals was introduced in 1942 and was followed by an amperometric method of measuring free chlorine, monochloramine, and dichloramine in 1951. Colorimetric methods of determining chlorine residuals were established in 1949.

The AWWA Standards Council approved the formation of a committee to create a standard for online chlorine analyzer operation and maintenance during its March 2006 meeting. A chair for the new Online Monitoring Committee was selected in August 2006, and the committee held its first meeting at the Water Quality and Technology Conference in Denver, Colorado, in November 2006.

This is the first edition of ANSI/AWWA Standard C670. It was approved by the AWWA Board of Directors on June 14, 2009.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF<sup>†</sup>) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

---

\* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.\* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state, provincial, and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state, provincial, or local agency.
3. Two standards developed under the direction of NSF, NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,<sup>†</sup> and other standards considered appropriate by the state, provincial, or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C670 does not address additives requirements. Users of this standard should consult the appropriate state, provincial, or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

---

\* Persons outside the United States should contact the appropriate authority having jurisdiction.

† Both publications available from National Academy of Sciences, 500 Fifth Street NW, Washington, DC 20001.



## **II. Special Issues.**

II.A. *Information on the Application of This Standard.* The online chlorine analyzer chosen for a particular application depends most upon the water characteristics at the point of sampling and the reason for sampling (regulatory compliance, process control, or other). The initial selection and purchasing of an online chlorine analyzer is beyond the scope of this standard. However, as an analyzer is operated and maintained, attention should be paid to whether the water characteristics are within the range of water temperature, pH, and other parameters in which the analyzer is designed to operate.

**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C670, Online Chlorine Analyzer Operation and Maintenance, of latest revision.

2. Whether compliance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, is required.

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

**IV. Major Revisions.** This is the first edition of this standard.

**V. Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail [standards@awwa.org](mailto:standards@awwa.org).

This page intentionally blank.



**American Water Works  
Association**

---

---

*AWWA Standard*

---

---

# Online Chlorine Analyzer Operation and Maintenance

---

## SECTION 1: GENERAL

---

### Sec. 1.1 Scope

This standard describes online chlorine analyzer operation and maintenance (O&M) when the online chlorine analyzer is used in the treatment and monitoring of potable water, reclaimed water, or wastewater.

### Sec. 1.2 Purpose

Continuous chlorine residual monitoring is used for two primary purposes: process control and regulatory compliance. Process control implies that the reason for testing the chlorine content of water is primarily to determine how well a process is working (e.g., how consistent the chlorine residual is in effluent from a flash mixer, how much chlorine is removed from disinfected water, etc.), to control chlorine feed equipment, and to ensure appropriate chlorination of the final product. The rate of ammonia application may be controlled by the residual from the chlorine analyzer to maintain an acceptable chloramine speciation. Process control may also imply analyzing residual chlorine content in distribution or transmission systems. A sudden decrease in measured chlorine residual may be indicative of malfunctioning equipment, system failure, groundwater intrusion, or introduction of some chlorine-consuming contaminants.