



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA C702-10
(Revision of ANSI/AWWA C702-01)

AWWA Standard

Cold-Water Meters— Compound Type



Effective date: June 1, 2010.

First edition approved by AWWA Board of Directors May 24, 1923.

This edition approved Jan. 17, 2010.

Approved by American National Standards Institute April 20, 2010.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Subcommittee on Compound and Fire-Service Meters, which developed this standard, had the following personnel at the time:

Joe Alongi, *Chair*

J. Alongi, Kansas City Water Services Dept., Kansas City, Mo.	(AWWA)
S. Bartram, Elster AMCO Water Inc., Ocala, Fla.	(AWWA)
T. Butler, Itron, Greenwood, S.C.	(AWWA)
M. Cole, Infinity Metering Company Inc., Ocala, Fla.	(AWWA)
G.H. De Jarlais, Badger Meter Inc., Milwaukee, Wis.	(AWWA)
L.W. Fleury Jr., Mueller Group, Smithfield, R.I.	(AWWA)
G. Gomez, Badger Meter Inc., Milwaukee, Wis.	(AWWA)
J.R. Grabinski, Dallas Water Utilities, Dallas, Texas	(AWWA)
A. Hendey Sr., Performance Meter Inc., Beaumont, Calif.	(AWWA)
J. Jackson, Sensus Metering Systems, Texarkana, Texas	(AWWA)
M. Patience, Elster AMCO, Ocala, Fla.	(AWWA)

The AWWA Standards Committee on Water Meters, which reviewed and approved this standard, had the following personnel at the time of approval:

Michael J. Kebles, *Chair*

Thomas Gwynn, *Secretary*

User Members

M.L. Aigen, Boston Water and Sewer Commission, Roxbury, Mass.	(NEWWA)
J. Alongi, Kansas City Water Services Dept., Kansas City, Mo.	(AWWA)
W. Dunnill, Consolidated Utility District of Rutherford County, Murfreesboro, Tenn.	(AWWA)
W.M. Garfield, Arizona Water Company, Phoenix, Ariz.	(AWWA)
J.R. Grabinski, Dallas Water Utilities, Dallas, Texas	(AWWA)
D. Griffin, City of Winnipeg Water & Waste Dept., Winnipeg, Man.	(AWWA)
N.D. Kaufman, Truckee Donner Public Utility District, Truckee, Calif.	(AWWA)
M.J. Kebles, Las Vegas Valley Water District, Las Vegas, Nev.	(AWWA)
T.A. Kelly, Washington Suburban Sanitary Commission, Laurel, Md.	(AWWA)

M.S. Krause, Desert Water Agency, Palm Springs, Calif.	(AWWA)
J.A. Novak, Milwaukee Water Works, Milwaukee, Wis.	(AWWA)
G.E. Raymond, Water Distribution–Meter Services, Los Angeles, Calif.	(AWWA)
S. Solotoff, Miami–Dade Water & Sewer, Miami, Fla.	(AWWA)
J. H. Standi Jr., Golden State Water Company, Fontana, Calif.	(AWWA)

General Interest Members

R.C. Graff, Poway, Calif.	(AWWA)
T. Gwynn,* Mars Company, Ocala, Fla.	(AWWA)
M.C. Johnson, Utah State University, Logan, Utah	(AWWA)
F.S. Kurtz,† Staff Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
E.N. Olson,† Standards Council Liaison, Brown and Caldwell, Gold Hill, Ore.	(AWWA)
F.S. Salser Jr., Floyd S. Salser Jr. & Assoc. Mars Co., Ocala, Fla.	(AWWA)
R. San Giacomo, R & D Engineering P.C., Orchard Park, N.Y.	(AWWA)
J.A. Welsh, Measurement Canada, Ottawa, Ont.	(AWWA)

Producer Members

S. Bartram,* Elster AMCO Water Inc., Ocala, Fla.	(AWWA)
G.H. De Jarlais,* Badger Meter Inc., Milwaukee, Wis.	(AWWA)
L.W. Fleury Jr., Mueller Group, Smithfield, R.I.	(AWWA)
G. Gomez, Badger Meter Inc., Milwaukee, Wis.	(AWWA)
A. Hendey Sr., Performance Meter Inc., Beaumont, Calif.	(AWWA)
R.N. Koch, Master Meter Inc., Pittsburgh, Pa.	(AWWA)
D.J. Kullmann, Neptune Technology Group Inc., Marietta, Ga.	(AWWA)
M. Laird,* Metron–Farnier, Boulder, Colo.	(AWWA)
J. Panek Jr.,* McCrometer Inc., Rowley, Iowa	(AWWA)
D. Pinney, Sensus Technologies Inc., Uniontown, Pa.	(AWWA)
J. Potter,* Master Meter Inc., Mansfield, Texas	(AWWA)
M. Shamley, Metron–Farnier, Boulder, Colo.	(AWWA)
T. Swinson,* Neptune Technology Group Inc., Tallassee, Ala.	(AWWA)
M.A. Thomas,* Hersey Meters, Cleveland, N.C.	(AWWA)
G.M. Voss, McCrometer Inc., Hemet, Calif.	(AWWA)
A. Watson, Elster AMCO Water Inc., Ocala, Fla.	(AWWA)

* Alternate

† Liaison, nonvoting

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword			
I	vii	6.2	Packaging and Shipping 15
I.A	Background.....vii	6.3	Affidavit of Compliance 15
I.B	History.....vii	Appendix	
I.C	Acceptance.....vii	A Supplemental Information	
II	Special Issues.....ix	A.1	Units of Measurement 17
III	Use of This Standard.....ix	A.2	Register Types 17
III.A	Purchaser Options and Alternatives.....ix	A.3	Tests..... 17
III.B	Modification to Standard.....x	A.4	Testing Equipment..... 19
IV	Major Revisions.....x	A.5	Registration Accuracy 19
V	Comments.....x	A.6	Periodic Tests 21
Standard			
1 General			
1.1	Scope 1	A.7	Meter Storage..... 22
1.2	Purpose 1	A.8	Installation..... 22
1.3	Application..... 1	A.9	Service Bypass Around Meter..... 23
2 References 2			
3 Definitions 4			
4 Requirements			
4.1	Materials 4	Tables	
4.2	General Design 7	1	Operating Characteristics Class I 9
4.3	Detailed Design 11	1.1	Operating Characteristics Class II 9
5 Verification			
5.1	Basis for Rejection 15	2	Meter Dimensions 9
6 Delivery			
6.1	Markings..... 15	3	Span of Changeover Flow Rates Class I..... 10
		3.1	Span of Changeover Flow Rates Class II 10
		4	Physical Characteristics of Companion Flanges 10
		5	Maximum Indication on Test Circle and Minimum Register Capacity..... 13
		A.1	Average Recommended Interval Between Meter Tests 21

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C702.

I. Introduction.

I.A. *Background.* The first compound-type water meter was developed in 1914, when it became evident that there was a need for a measuring device combining a valve with a small displacement-type bypass meter. The new meter would, by design, divert and register water at flow rates below the minimum flow-rate capability of the main water-line meter, which was usually of the turbine type.

Initially, standard meters of the turbine type and displacement type were assembled into units with suitable valves. Mainline meter cases were first made of cast iron, but after five or six years, some were made of bronze. In the field, meters were also converted to the compound type by the attachment of bypass meters and diversion valves.

Currently, some compound-type meters are made almost entirely of bronze in single mainline cases. Others continue to be constructed with cast-iron cases. Some compound-type meters are assembled units, particularly those in large sizes. Compound-type meters have applications in commercial, industrial, and institutional services where wide ranges of flow rates are encountered.

I.B. *History.* The first standard that covered compound-type meters was adopted by the New England Water Works Association (NEWWA) in March 1923, and by the American Water Works Association (AWWA) on May 24, 1923. On Jan. 14, 1946, the standard was approved as tentative as AWWA 7M.3-T. On July 25, 1947, the standard was approved under the designation 7M.3-1947/C702-47. Subsequent editions of the standard were approved by the AWWA Board of Directors on Jan. 26, 1970, Jan. 28, 1978, June 22, 1986, June 18, 1992, and Jan. 21, 2001. This edition was approved on Jan. 17, 2010.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now Water Research Foundation) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, NSF[†]/ANSI[‡] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[§] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C702 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

§ Both publications available from National Academy of Sciences, 500 Fifth Street, N.W., Washington, DC 20001.

II. Special Issues. This standard has no applicable information for this section.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. Purchaser Options and Alternatives. The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C702, Cold-Water Meters—Compound Type, of latest edition.
2. Whether compliance with NSF/ANSI 61 Drinking Water System Components—Health Effects, is required.
3. If specific warranty provisions will be required.
4. Limitations on acceptable materials, if any, as referenced throughout Sec. 4.1.
5. Details of other federal, state or provincial, and local requirements (Sec. 4.1).
6. Restrictions on corrosion-resistance treatment process (Sec. 4.1.8), if any.
7. Sizes of meters (Sec. 4.2.1) and quantity required.
8. Length of filler piece (Sec. 4.2.3) if required.
9. Modifications to test specifications (Sec. 4.2.6) if operating water temperatures will exceed 80°F (27°C) (Sec. A.5.2).
10. Round or oval flanges on 2-in. (50-mm) meters (Sec. 4.3.3.1).
11. If companion flanges, gaskets, bolts, and nuts (Sec. 4.3.4) are to be provided, and designation of flange material (Sec. 4.1.9) if other than cast iron is desired.
12. If main casing is to be provided with tapped boss for field-testing purposes (Sec. 4.3.5).
13. Details of register to be provided: US gallons, cubic feet, or cubic meters; with or without center-sweep test hand; open, sealed, or permanently sealed (Sec. 4.3.6).
14. If an encoder-type register, direct-reading remote register, or an adapter (Sec. 4.3.7) is required.
15. If meters are to be provided with strainers (Sec. 4.3.14). If strainers are requested, specify whether they are internal or external and whether the strainer shall be removable without removing the meter from the service line.
16. Whether the meter serial number is to be imprinted on the main case (Sec. 6.1).
17. If an affidavit of compliance (Sec. 6.3), a certificate of testing accuracy (Sec. A.3.3), or both, are to be provided.

18. Special materials required, if any, to resist corrosion if water is highly aggressive (Sec. A.5.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. The major revisions to the standard in this edition include the following:

1. Definitions for Class I and Class II meters were added to Section 3.
2. Changes in language describing meter registers were added to Sec. 4.3.6.
3. The AWWA Policy Statement on electrical grounding of pipes was added to Sec. A8.

V. Comments. If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at standards@awwa.org.



**American Water Works
Association**

AWWA Standard

Cold-Water Meters—Compound Type

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes the various types and classes of cold-water compound-type meters in sizes 2 in. (50 mm) through 8 in. (200 mm), and the materials and workmanship used in their fabrication. Compound meters shall consist of a combination of a turbine-type, mainline meter for measuring high rates of flow and a bypass meter of an appropriate size for measuring low rates of flow. The compound meter shall have an automatic valve mechanism for diverting low rates of flow through the bypass meter.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for compound-type cold-water meters, including materials and design.

Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving compound-type cold-water meters. This standard can be used as a guide for manufacturing this type of meter. The stipulations of this standard apply when this document has been referenced, and then only to compound-type cold-water meters.