



**American Water Works  
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA C750-10  
(Revision of ANSI/AWWA C750-03)

---

---

*AWWA Standard*

---

---

# Transit-Time Flowmeters in Full Closed Conduits



Effective date: May 1, 2010.

First edition approved by AWWA Board of Directors June 19, 2003.

This edition approved Jan. 17, 2010.

Approved by American National Standards Institute March 24, 2010.

---

---

6666 West Quincy Avenue  
Denver, CO 80235-3098  
T 800.926.7337  
www.awwa.org

Advocacy  
Communications  
Conferences  
Education and Training  
Science and Technology  
Sections

## **AWWA Standard**

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

## **American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing [info@ansi.org](mailto:info@ansi.org).

---

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association  
Printed in USA

## Committee Personnel

The AWWA Subcommittee on Ultrasonic Devices, which developed this standard, had the following personnel at the time:

Bahram Safa, *Chair*

J.J. Gemin, AECOM, Kitchener, Ont.	(AWWA)
M.J. Keilty, Endress and Hauser Flowtec AG, Lyons, Colo.	(AWWA)
M.D. Kyser, Professional Engineering Consultants P.A., Tulsa, Okla.	(AWWA)
B. Safa, Irvine, Calif.	(AWWA)
J.S. Trofatter, Accusonic Technologies, West Wareham, Mass.	(AWWA)

The AWWA Committee on Rate Type Flowmeters, which reviewed and approved this standard, had the following personnel at the time:

Joseph J. Gemin, *Chair*

*General Interest Members*

J.A. Casados, Instituto Mexicano de Tecnología del Agua, Progreso, Mor.	(AWWA)
J.J. Gemin, AECOM, Kitchener, Ont.	(AWWA)
F.S. Kurtz,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
M.D. Kyser, Professional Engineering Consultants P.A., Tulsa, Okla.	(AWWA)
E.N. Olson,* Standards Council Liaison, Brown and Caldwell, Gold Hill, Ore.	(AWWA)
P.W. Moorman, Black & Veatch, Kansas City, Mo.	(AWWA)
B. Safa, Irvine, Calif.	(AWWA)
D.C. Wyatt, Wyatt Engineering, Lincoln, R.I.	(AWWA)

*Producer Members*

G.H. De Jarlais, Badger Meter Inc., Milwaukee, Wis.	(AWWA)
G. Gomez,† Badger Meter Inc., Milwaukee, Wis.	(AWWA)
M.J. Keilty, Endress and Hauser Flowtec AG, Lyons, Colo.	(AWWA)
M.A. Metcalf, Teledyne ISCO Inc., Poway, Calif.	(AWWA)
J. Panek, McCrometer Inc., Rowley, Iowa	(AWWA)
J.S. Trofatter, Accusonic Technologies, West Wareham, Mass.	(AWWA)

---

\* Liaison, nonvoting

† Alternate

*User Members*

J.N. Hernandez, Cleveland Division of Water, Cleveland, Ohio	(AWWA)
S.F. Sarrouh, Brown and Caldwell, Cleveland, Ohio	(AWWA)
S.Y. Tung, City of Houston, Houston, Texas	(AWWA)
K. Whitaker, San Diego County Water Authority, San Diego, Calif.	(AWWA)

## Contents

*All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.*

SEC.	PAGE	SEC.	PAGE
<b>Foreword</b>		<b>5 Verification</b>	
I	vii	5.1	11
I.A	vii	5.2	13
I.B	vii	5.3	14
I.C	viii		14
II	ix	5.4	15
III	ix	<b>6 Delivery</b>	
III.A	ix	6.1	15
	ix	6.2	15
III.B	x	6.3	15
IV	x	<b>Appendixes</b>	
V	x	A	17
		B	19
<b>Standard</b>		<b>Figures</b>	
<b>1 General</b>		1	4
1.1	1	2	5
1.2	1		5
1.3	1	3	6
<b>2 References</b>	<b>2</b>		
<b>3 Definitions</b>	<b>2</b>	<b>Tables</b>	
<b>4 Requirements</b>		1	7
4.1	3	A.1	17
4.2	3		
4.3	4		
4.4	5		
4.5	6		
4.6	8		

This page intentionally blank.

## Foreword

*This foreword is for information only and is not a part of ANSI/AWWA C750.*

### **I. Introduction.**

I.A. *Background.* The first water meter that was produced in the United States was thought to be a positive displacement meter that was fabricated in 1857. Since then, a number of other technologies and designs have been introduced to the water industry, each with its special characteristics. The ultrasonic flowmeter is one of the latest additions to the industry. The use of ultrasonic flowmeters has received wide commercial acceptance since the 1970s. There are currently two distinct types of ultrasonic flowmeters available: Doppler Effect and Transit-Time. While the Doppler Effect meter is used extensively for water and other liquids containing solid particles, the transit-time ultrasonic flowmeter is receiving increased acceptance in the water industry.

I.B. *History.* In 1985, the American Society of Mechanical Engineers published the first standard for the transit-time ultrasonic (transit-time) flowmeters. The needs of the water industry differ, in some respects, from other industries, therefore necessitating the development of an AWWA standard for transit-time flowmeters.

In 1990, the AWWA Standards Committee on Rate Type Flowmeters was formed to develop standards for transit-time meters. The Subcommittee on Ultrasonic Meters was later developed for this purpose. The Subcommittee prepared a first draft of the transit-time flowmeter standard in 1992. The first draft was reviewed and commented on by the Subcommittee members as well as members of the Rate Type Flowmeter Committee. Subsequent drafts were sent out to a number of transit-time flowmeter manufacturers in 1994 for their review and comments. A 1995 draft addressed these comments, where possible, and was distributed to all who had previously commented on the drafts. A revised draft was presented to the Subcommittee in 1995. The Subcommittee met in January 1996 to finalize the standard. However, the Subcommittee decided that leaving the draft open to the general public for review and comment, prior to finalizing the standard, would produce a more thorough standard. The *AWWA Journal* was considered a suitable medium for reaching the water industry. The Subcommittee changed the format of the standard into an *AWWA Journal* article that was published in the July 1997 edition of the *Journal* as a Committee Report. The article encouraged the public to comment on the contents of the Committee Report. A few written comments were received and were addressed in developing the final draft of

the standard. On Jan. 19, 2003, the standard was approved by the AWWA Board of Directors. This second edition of ANSI/AWWA C750 was approved on Jan. 17, 2010.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now Water Research Foundation) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.\* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, NSF<sup>†</sup>/ANSI<sup>‡</sup> 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,<sup>§</sup> and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, "Toxicology Review and Evaluation Procedures," to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not

---

\* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

§ Both publications available from National Academy of Sciences, 500 Fifth Street, N.W., Washington, DC 20001.



regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C750 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

**II. Special Issues.** This standard is different in format from other AWWA standards that contain specific requirements for material, dimensions, workmanship, and other physical requirements. Different transit-time flowmeters employ different materials and technologies. The software and the electronic components of transit-time flowmeters are generally designed to work with the physical characteristics of each make of the equipment.

**III. Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

**III.A. Purchaser Options and Alternatives.** This standard provides for several options and alternatives that purchasers must designate if they wish to exercise the options or if they have a preference among the alternatives. Also, several items must be specified by the purchasers to describe completely the type, size, and quantity of the transit-time flowmeters required. The following list provides these items. Purchasers should review this list and Appendix A of this standard to make the appropriate provisions in their specifications to describe specific requirements.

1. Standard used—that is, ANSI/AWWA C750, Transit-Time Flowmeters in Full Closed Conduits, of latest revision.
2. Whether compliance with NSF/ANSI 61, Drinking Water System Components—Health Effects, is required, in addition to the requirements of the Safe Drinking Water Act.
3. Details of other federal, state or provincial, and local requirements (Sec. 4.1)
4. Size of the conduit (Sec. 4.2).
5. Type of transducer (Sec. 4.3.2).
6. Single path or multipath (Sec. 4.4).

7. Performance requirements (Sec. 4.5).
8. Required accuracy (Sec. 4.5.1).
9. Installation issues (Sec. 4.6.1.4).
10. Affidavit of compliance, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

**IV. Major Revisions.** Major revisions made to the standard in this edition include the following:

1. A new Sec. 4.1, Materials, has been added.
2. Sec. 4.5 and Sec. 4.6 have been modified to include provisions for wetted-type transit-time flowmeters.
3. Sec. 4.6.1 has been modified to include information on multipath designs.
4. Section 5, Verification, has been greatly expanded to include various calibration and field verification methods. These include electronic calibration, dry calibration, volumetric method, gravimetric method, master meter method, and other methods.

**V. Comments.** If you have any comments or questions about this standard, please call the AWWA Volunteer and Technical Support Group at 303.794.7711, FAX at 303.795.7603, write to the group at 6666 West Quincy Avenue, Denver, CO 80235-3098, or e-mail at [standards@awwa.org](mailto:standards@awwa.org).



**American Water Works  
Association**

---

---

*AWWA Standard*

---

---

# **Transit-Time Flowmeters in Full Closed Conduits**

---

## **SECTION 1: GENERAL**

---

### **Sec. 1.1 Scope**

This standard describes transit-time ultrasonic flowmeters for water supply service application in pipes running full. An ultrasonic flowmeter is a meter that uses acoustic energy signals to measure liquid velocity. There are currently two distinct types of ultrasonic flowmeters available: Doppler-effect and transit-time. The Doppler-effect meter is used exclusively for liquids containing solid particles or gases, and the transit-time flowmeter is used in a wide variety of applications in the water industry.

### **Sec. 1.2 Purpose**

The purpose of this standard is to provide purchasers, manufacturers, and suppliers with the minimum requirements for transit-time flowmeters, including components, performance, calibration, and verification.

### **Sec. 1.3 Application**

Transit-time flowmeters are used in a wide variety of applications, including raw water, treated water, and in different stages of the treatment process, such as settled water, supernatant, backwash, and chemical lines. These meters are also used in large-diameter transmission pipelines.