



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA D107-16
(Revision of ANSI/AWWA D107-10)

AWWA Standard

Composite Elevated Tanks for Water Storage

Effective date: Jan. 1, 2017.

First edition approved by AWWA Board of Directors Jan. 17, 2010.

This edition approved Jan. 16, 2016.

Approved by American National Standards Institute Dec. 21, 2015.

Errata incorporated Feb. 7, 2019




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal – American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal – American Water Works Association* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org.



ISBN-13, print: 978-1-62576-187-3

eISBN-13, electronic: 978-1-61300-396-1

DOI: <http://dx.doi.org/10.12999/AWWA.D107.16>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2016 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Composite Elevated Tanks, which reviewed and approved this standard, had the following personnel at the time of approval:

Edwin A. Smith, *Chair*

General Interest Members

J.W. Birkhoff, Birkhoff, Hendricks, & Carter LLP, Dallas, Texas	(AWWA)
M.M. Coleman,* Standards Council Liaison, Wade Trim Associates Inc., Detroit, Mich.	(AWWA)
W.J. Dixon, Dixon Engineering Inc., Lake Odessa, Mich.	(AWWA)
R.E. Gell, O'Brien & Gere Engineers Inc., Syracuse, N.Y.	(AWWA)
F.S. Kurtz,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
S.W. Meier, Tank Industry Consultants Inc., Indianapolis, Ind.	(AWWA)
E.A. Smith, Jacobs, Dallas, Texas	(AWWA)

Producer Members

G.A. Burke, Caldwell Tanks Inc., Louisville, Ky.	(AWWA)
W.J. Czaska, CB&I, Plainfield, Ill.	(AWWA)
R. Pawski, Landmark Structures Inc., Wheaton, Ill.	(AWWA)
D.L. Stilger,† Caldwell Tanks Inc., Louisville, Ky.	(AWWA)

User Members

R.E. McCuller, City of Grand Prairie, Grand Prairie, Texas	(AWWA)
R.B. Potts, Louisville Water Company, Louisville, Ky.	(AWWA)
G. Terrell, Birmingham Water Works Board, Birmingham, Ala.	(AWWA)

* Liaison, nonvoting

† Alternate

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword			
I	Introduction.....	ix	
I.A	Background.....	ix	
I.B	History.....	ix	
I.C	Acceptance.....	ix	
II	Special Issues.....	x	
II.A	Applicable Building Codes.....	x	
II.B	Personnel Safety Standards.....	xi	
II.C	Special Loading Conditions.....	xi	
II.D	Professional Engineer (PE) Certification.....	xi	
II.E	Inspection and Maintenance.....	xi	
II.F	Cold Climates.....	xi	
II.G	Use of Interior Space.....	xi	
II.H	Aesthetics.....	xi	
II.I	Structural Evaluation.....	xi	
III	Use of This Standard.....	xii	
III.A	General.....	xii	
III.B	Specifying ANSI/AWWA D107.....	xiii	
III.C	Modification of Standard.....	xiii	
IV	Major Revisions.....	xiii	
V	Comments.....	xiv	
Standard			
1	General		
1.1	Scope.....	1	
1.2	Purpose.....	1	
1.3	Application.....	1	
1.4	Drawings, Calculations, and Instructions.....	2	
1.5	Quality Assurance.....	2	
1.6	Equivalence Between US Customary Units and SI-Metric Units of Nonhomogeneous Equations.....	2	
2	References.....	4	
3	Definitions.....	7	
4	General Requirements for Analysis and Design		
4.1	General.....	9	
4.2	Design Loads.....	11	
4.3	Analysis and Design.....	21	
5	Steel Tank		
5.1	General.....	23	
5.2	Material Requirements.....	24	
5.3	Analysis and Design.....	24	
5.4	Fabrication and Construction Requirements.....	31	
6	Concrete Support Structure		
6.1	General.....	34	
6.2	Material Requirements.....	36	
6.3	Analysis and Design.....	36	
6.4	Fabrication and Construction Requirements.....	41	

SEC.	PAGE	SEC.	PAGE
7		<i>Appendixes</i>	
		A	Commentary on Selected Sections of the Standard
7.1	44	A.1	General69
7.2	45	A.2	References69
7.3	45	A.4	General Requirements for Analysis and Design.....70
7.4	48	A.5	Steel Tank83
		A.6	Concrete Support Structure.....92
8		A.7	Foundations97
		A.8	Accessories99
8.1	50	A.9	Inspection and Testing..... 105
8.2	51	B	Information Provided by Purchaser
8.3	51	B.1	Required Information..... 113
8.4	52	B.2	Purchaser Options..... 113
8.5	53	C	Recommendations for Geotechnical Investigation
8.6	53	C.1	General 117
8.7	53	C.2	Design Criteria..... 118
8.8	55	C.3	Field Investigation 118
8.9	55	C.4	Laboratory Testing 119
8.10	57	C.5	Engineering Analysis and Recommendations.....120
8.11	58		
9		<i>Figures</i>	
		1	Extreme Frost Penetration (depth in inches based on state averages) 47
9.1	59	2	Minimum Pipe Cover (cover above top of pipe in feet) by Geographic Area 56
9.2	60		
9.3	61		
9.4	63		
9.5	63		
9.6	68		
9.7	68		

SEC.	PAGE	SEC.	PAGE
A1	75	13a	60
A2	78	13b	60
A3	89	14	65
A4	94	A.1a	72
Tables			
1	14	A.1b	72
2a	15	A.2	74
2b	15	A.3	84
3	20	A.4	91
4	25	A.5	98
5	26	A.6	101
6	27	A.7	108
7	29	A.8	109
8	31	A.9	110
9	34	B.1	113
10	34	C.1	118
11	37		
12	45		

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA D107.*

I. Introduction.

I.A. *Background.* A composite elevated water tank is composed of a welded steel tank for watertight containment, a single pedestal concrete support structure, a foundation, and accessories.

The AWWA Standards Committee on Composite Elevated Tanks was formed to prepare a standard for the design, construction, inspection, and testing of composite elevated tanks. ACI 371R, Guide for the Analysis, Design, and Construction of Elevated Concrete and Composite Steel-Concrete Water Storage Tanks,[†] and ANSI/AWWA D100, Welded Carbon Steel Tanks for Water Storage, are used as source documents.

Work covered by this standard is usually procured under a design-build contract. It is intended that ANSI/AWWA D107 be used as a reference standard in project documents prepared by purchasers and engineers specifying composite elevated water tanks.

I.B. *History.* The AWWA Standards Committee on Composite Elevated Tanks was formed in 1992 to prepare a standard for these structures. The first edition of ANSI/AWWA D107 was approved by the AWWA Board of Directors on Jan. 17, 2010. This edition was approved on Jan. 16, 2016.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[‡] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† American Concrete Institute (ACI), 38800 Country Club Drive, Farmington Hills, MI 48331.

‡ Persons outside the United States should contact the appropriate authority having jurisdiction.

1. Specific policies of the state or local agency.
2. Two standards developed under the direction of NSF*: NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.
3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[†] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA D107 does not address additives requirements. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Applicable Building Codes.* Building codes may not have specific provisions for nonbuilding structures such as composite elevated tanks. The purchaser should make a determination as to the intent of the requirements of the applicable building codes and should specify the extent to which such building codes apply to a project. It is intended that specified building codes govern where they have more stringent requirements than this standard.

II.B. *Personnel Safety Standards.* The personnel safety requirements in this standard are based on OSHA 29 CFR, Part 1910, Occupational Safety and Health Standards, and industry practice. The user in specifying safety-related equipment,

* NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

† Both publications available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

details, and design criteria should make a determination that the requirements of this standard are in compliance with current OSHA requirements and applicable building code requirements.

II.C. *Special Loading Conditions.* The purchaser should specify design requirements for service not covered by this standard, such as loads associated with surge or process tanks, or local environmental conditions more severe than those required by this standard.

II.D. *Professional Engineer (PE) Certification.* It is recommended that the engineer responsible for design be licensed in the jurisdiction where the composite elevated tank is to be constructed. The design and construction drawings should be sealed.

II.E. *Inspection and Maintenance.* Composite elevated tanks designed and constructed in accordance with the requirements of this standard can be expected to be durable structures. Steel tank construction has a satisfactory history when properly maintained, and concrete that conforms to this standard will meet the requirements for durable concrete as defined in ACI 201.2R, Guide to Durable Concrete.

An inspection of the structure and accessories is recommended approximately one year after completion. Thereafter, periodic inspection and maintenance should be performed.

II.F. *Cold Climates.* The formation of ice in the tank may result in damage to the tank or components such as piping or interior ladders. Design for this condition is beyond the scope of this standard. Reference to ice damage is to improper operation rather than an endorsement of an icing condition. The tank should be heated, insulated, or operated in a manner to prevent this condition. Water replacement, circulation, or wasting of water are operational techniques that may be used.

II.G. *Use of Interior Space.* The interior of the support structure is frequently used for mechanical rooms, storage, and parking. This space may be occupied when constructed in accordance with local building code requirements. Typical uses include fire stations and offices. Intermediate floors may be constructed to provide additional space.

II.H. *Aesthetics.* Aesthetics should be considered when planning a composite elevated tank. Minimum architectural features and finishing of exterior concrete surfaces are provided for in this standard. Painting decorative logos or color schemes on the steel tank may enhance the appearance of the structure.

II.I. *Structural Evaluation.* If construction does not meet tolerance, material, or other structural requirements of this standard, an evaluation may be performed

by the responsible design professional. When structural capacity is not compromised, repair or replacement may not be required unless other factors, such as lack-of-fit, aesthetics, or durability, require remedial action.

III. Use of This Standard.

III.A. General.

III.A.1 Disclaimer. AWWA has no responsibility for the suitability or compatibility of the provisions of this standard to any intended application by any user. Accordingly, it is the responsibility of the user of this AWWA standard to determine that the provisions described in this standard are suitable for use in the particular application being considered.

III.A.2 Minimum Requirements. ANSI/AWWA D107 is based on the collective knowledge of purchasers, consulting engineers, and constructors of composite elevated tanks. A composite elevated tank is considered to be in compliance with ANSI/AWWA D107 when the minimum requirements of this standard have been met. The purchaser may specify more stringent requirements.

III.A.3 Contract Responsibility. Procurement of composite elevated tanks is usually by design-build contracts using proprietary designs and methods of construction. The purchaser should provide project documents that describe the work to be performed.

The purchaser typically is responsible for the following:

1. A site on which the composite elevated tank is to be constructed, which should be of sufficient size to permit construction using customary methods.
2. A suitable right-of-way from the nearest public road to the construction site.
3. A geotechnical investigation, including recommendations for foundation type and associated design criteria.
4. A Federal Aviation Administration (FAA) determination with regard to siting, height, marking, and lighting requirements.
5. Water at sufficient pressure for testing and facilities for disposal after testing.
6. Purchaser-furnished materials that are to be installed by the constructor.

The constructor typically is responsible for the following:

1. Designs, drawings, and specifications for the composite elevated tank.
2. All labor, materials, equipment, supplies, and testing as required by this standard.
3. Warranting the structure against defects in material and workmanship for a period of one year from date of completion.
4. Any additional work specified in the project documents.

III.B. *Specifying ANSI/AWWA D107.*

III.B.1 Reference Standard. ANSI/AWWA D107 is a reference standard that a purchaser may cite in project documents, together with supplementary requirements for a specific project. A statement such as the following may be used to incorporate ANSI/AWWA D107 into the project documents:

“Design and construction of the composite elevated tank shall comply with the requirements of ANSI/AWWA D107, Composite Elevated Tanks for Water Storage, published by the American Water Works Association, Denver, Colorado, except as modified by the requirements of these contract documents.”

III.B.2 Information Required From Purchaser. Incorporating this standard by reference in a project specification requires that the purchaser provide the information listed in Sec. 1.3. ANSI/AWWA D107 has options that the purchaser may specify, and Section B.2 of appendix B, Table B.1, contains a comprehensive list of these options and corresponding defaults.

III.C. *Modification of Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided in the project specifications.

IV. Major Revisions. The major revisions in this edition of the standard include the following:

1. The notation and definition for maximum considered earthquake MCE_R have been revised to conform to the latest edition of ASCE* 7.
2. Seismic maps are now cited by reference to ASCE 7-10 rather than being incorporated into the standard.
3. Former Table 3, Site Classifications, has been moved to appendix A and has been renumbered as Table A.2.
4. Standard Sec. 4.2.7.8, Seismic Design Category, and appendix Sec. A.4.2.7.8, Seismic Load, have been added.
5. ASCE 7-10 wind provisions have been incorporated into the standard.
6. The gust effect factor G_f has been revised.
7. The wind map (Figure 2 of the 2010 edition) has been deleted and is now incorporated by reference to ASCE 7-10.
8. Former Tables 2a and 2b on design wind pressure have been revised and moved to appendix A as Tables A.1a and A.1b.
9. Former Table 14, Minimum Safety Factors (now Table 12), has been revised; ASTM D4945 has been added to the dynamic testing provisions.

* American Society of Civil Engineers, 1801 Alexander Bell Drive, Reston, VA 20191.

10. Standard Sec. 6.3.3.8.1 and appendix Sec. A.6.3.3.8.1 have been updated to reflect current practice, similar to the provisions described in ACI 371R-08.

11. Standard Sec. 7.3.3.2 and appendix Sec. A.7.3.3 have been updated, whereby allowable compression stress values are now referenced to IBC 2012 rather than being provided in the standard.

12. Appendix Section A.2 has been added to identify specific revision years for ASCE 7 and ACI 318.

13. Determination of meridional compression strength F_L by method 2 (ANSI/AWWA D107-10, Sec. 5.3.5.3) has been eliminated. Method 3 in ANSI/AWWA D107-10 has been renamed as method 2 in this edition. Section numbers have been revised accordingly.

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA D107-16
(Revision of ANSI/AWWA D107-10)

AWWA Standard

Composite Elevated Tanks for Water Storage

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes the design, construction, inspection, and testing of composite elevated tanks that use a welded steel tank for watertight containment and a single pedestal concrete support structure. Requirements for the steel tank, concrete support structure, foundation, and accessories are included. Site selection and procurement; tank sizing; postcommissioning inspection and maintenance; and the design, operation, and control of the water distribution system that connects to the composite elevated tank are beyond the scope of this standard.

Sec. 1.2 Purpose

The purpose of this standard is to provide minimum requirements for the design, construction, inspection, and testing of composite elevated tanks used for water storage in a water distribution system.

Sec. 1.3 Application

This standard may be referenced in project documents that address the design, construction, inspection, and testing of composite elevated tanks used for water storage. The following information is required to use this standard to specify a composite elevated tank: