

ANSI/BHMA A156.15-2015

Revision of BHMA A156.15-2011



AMERICAN NATIONAL STANDARD

FOR

**RELEASE DEVICES – CLOSER HOLDER, ELECTROMAGNETIC AND
ELECTROMECHANICAL**



SPONSOR

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION, INC.

AMERICAN NATIONAL STANDARDS INSTITUTE

Approved December 23, 2015

AMERICAN NATIONAL STANDARD

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the Standard or not, from manufacturing, marketing, purchasing, or using products, processes or procedures not conforming to the Standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this Standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all Standards by calling or writing the American National Standards Institute.

Published by
BUILDERS HARDWARE MANUFACTURERS ASSOCIATION, INC.
355 Lexington Avenue, New York, New York 10017
www.buildershardware.com

© Copyright 2015 by the
Builders Hardware Manufacturers Association, Inc.

Not to be reproduced without specific authorization from BHMA

Printed in the USA

This Standard was approved by ANSI under the Canvass Method. BHMA was accredited on 21 March 1983 by ANSI as a sponsor using the Canvass Method.

FOREWORD (This Foreword is not a part of ANSI A156.15)

The general classification of builders hardware includes a wide variety of items which are divided into several categories. To recognize this diversity, a sectional classification system has been established. Closer Holder Release Devices is one such section and this Standard is the result of the collective efforts of members of the Builders Hardware Manufacturers Association, Inc., who manufacture these products. The total Product Standards effort is, therefore, a collection of sections, each covering a specific category of items.

The BHMA recognizes that errors will be found, items will become obsolete, and new products, methods and materials will be developed. With this in mind, the Association plans to update, correct and revise these Standards on a regular basis.

The BHMA numbers which indicate type of hardware do not identify size, finish or design and are not intended to be used without necessary supplementary information. Users of this Standard who require a specific design for a product type describe it using generic terms or the manufacturer's name and description desired.

TABLE OF CONTENTS

1.	SCOPE	5
2.	DEFINITIONS	5
3.	GENERAL	5
4.	PREPARATION FOR PERFORMANCE TESTS	6
5.	PERFORMANCE TEST REQUIREMENTS	7
6.	FINISH PERFORMANCE REQUIREMENTS	10
7.	DOOR CLOSER FUNCTIONS AND IDENTIFYING NUMBERS	11
8.	EXPLANATION OF IDENTIFYING NUMBERS	14
	APPENDIX A (not a part of ANSI/BHMA A156.15)	15

1. SCOPE

1.1 This Standard establishes requirements for door closers combined with hold-open devices or free-swinging door closers combined with releasing devices and includes performance tests covering operational, cyclical and finish criteria.

1.2 Tests described in this Standard are performed under laboratory conditions. In actual usage, results vary because of installation, maintenance and environmental conditions.

1.3 Instructions shall be included with the product requiring the end users to, (1) test the product after installation in accordance with the manufacturer's criteria, (2) periodically test the products in conjunction with the fire alarm system and, (3) maintain the door closing system in working order.

2. DEFINITIONS

2.1 **Adjustable Backcheck** A cushioning feature of a door closer becoming effective between 60 and 85 degrees of door opening.

2.2 **Closer Holder Release Device** A floor, door or header mounted closing device connected with separate or integral releasing and fire or smoke detecting devices.

2.3 **Electro-Magnetic or Electro-Mechanical Release Device** A wall, floor or door mounted appliance that releases doors from an open position for simultaneous closing upon signal from a smoke detector or other source.

2.4 **Free Swinging Release** A function where the opening and closing control of a door closer is de-energized until a signal is received from a smoke detector or other source when the closer then performs its normal function and closes the door.

2.5 **Hold-Open** In this Standard, a device used in connection with a door closing device holding the door in an open position against the closing force.

2.6 **Multiple-Point Hold-Open** A hold-open device holding the door in more than one hold-open position without manual adjustment. (Consult manufacturer's catalogs for ranges of hold-open points available.)

2.7 **Single-Point Hold-Open** A hold-open device holding the door open in one selective position.

3. GENERAL

3.1 These products shall allow swinging doors to close upon receiving a signal in fire or smoke emergencies.

3.2 Upon activation by a signal to the hold-open or free swinging release device, the door shall become self-closing.

3.3 These products shall have been tested and listed for use on fire door assemblies by a Nationally Recognized Testing Laboratory (NRTL) and shall be under a follow-up in-plant inspection service.

3.4 These products with electrical components shall have been tested and listed by a NRTL and shall be under a follow-up in-plant inspection service. Holders are available in 115 volts AC, 24 volts AC or DC and 12 volts AC or DC. Consult manufacturer's catalogs.

3.5 Electrical wiring of these products shall be in accordance with the National Electrical Code (ANSI/NFPA 70) for the appropriate class of circuit.