

ANSI/BHMA A156.8-2010
Revision of ANSI/BHMA A156.8-2005

AMERICAN NATIONAL STANDARD
FOR
DOOR CONTROLS - OVERHEAD STOPS AND HOLDERS

SPONSOR

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION, INC.



APPROVED by the **AMERICAN NATIONAL STANDARDS INSTITUTE**
September 29, 2010



AMERICAN NATIONAL STANDARD

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

CAUTION NOTICE: This American National Standard is permitted to be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards receive current information on all Standards by calling or writing the American National Standards Institute.

Published by

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION, INC.
355 Lexington Avenue, New York, NY 10017
www.buildershardware.com

Copyright © 2010 by the Builders Hardware Manufacturers Association, Inc.

Not to be reproduced without specific authorization from B.H.M.A.

Printed in the USA

This standard was first published June 1970 by the Builders Hardware Manufacturers Association, Inc. It was entitled "Standard 311 BHMA Product Standards Section C, Door Controls - Overhead Holders." ANSI approval was secured under the Canvass Method. BHMA was accredited on 21 March 1983 by ANSI as a sponsor using the Canvass Method.

FOREWORD (This foreword is not a part of ANSI A156.8).

The general classification of builders hardware includes a wide variety of items which are divided into several categories. To recognize this diversity, a sectional classification system has been established. Overhead Holders is one such section and this Standard is the result of the collective efforts of members of the Builders Hardware Manufacturers Association who manufacture this product. The total Product Standards effort is, therefore, a collection of sections, each covering a specific category of items.

Performance tests have been established to insure safety, security and stability to which the public is entitled. There are no restrictions on design except as required to suit the type of product desired.

The BHMA recognizes that errors will be found, items will become obsolete, and new products, methods and material will be developed. With this in mind, the Association plans to update, correct and revise these Standards on a regular basis.

In most cases products have been described in grade levels related to performance. Grade classifications indicate levels only within their own product category. Choice of grade and specific product should be made on the basis of utility, aesthetics, security objectives and end use desired.

The BHMA numbers, which indicate types of hardware do not identify size or finish and are not intended to be used without necessary supplementary information. Individual manufacturers' catalogs should be consulted.

TABLE OF CONTENTS

1.	GENERAL	5
2.	PERFORMANCE REQUIREMENTS	5
3.	FINISH TESTS	7
4.	TYPICAL FUNCTIONS AND IDENTIFYING NUMBERS.....	8
5.	EXPLANATION OF NUMBERING SYSTEM	10
	APPENDIX A	11

1. GENERAL

1.1 Scope

1.1.1 This Standard establishes requirements for overhead door stops and holders, and includes performance tests covering operational, cyclical, strength and finish criteria.

1.1.2 Tests described in this Standard are performed under laboratory conditions. In actual usage, results vary because of installation, maintenance and environmental conditions.

1.2 Definitions

1.2.1 **Overhead Holder** A device surface mounted or concealed at the top of a door with a connecting arm attached to the door frame. It holds a door in a predetermined open position or positions and also limits the opening up to 110 degrees.

1.2.2 **Overhead Stops** A device surface mounted or concealed at the top of a door with a connecting arm attached to the door frame which only limits the opening travel of a door.

1.3 General Requirements

1.3.1 **SI Units** All dimensions are expressed first in US units with SI unit (metric) equivalents given in parentheses. SI units are approximate.

1.3.2 **Tolerances** All values which do not carry specific tolerances or are not marked maximum or minimum shall have the following tolerances: Number of cycles shall be minimum. Linear dimensions shall be $\pm 1/16$ in. (1.6 mm). Pounds or pound force shall be $\pm 2\%$. A tolerance of ± 2 degrees F shall be applied to temperature call outs.

1.3.3 **Reference to ANSI Standards** ANSI Standards are available from the American National Standards Institute, www.ansi.org, or the Builders Hardware Manufacturers Association www.buildershardware.com.

1.3.4 **Tests Required** All Grades of stops and overhead holders are required to meet functional tests described in Section 2. All grades of overhead holders and stops are required to meet the applicable finish tests described in Section 3.

2. PERFORMANCE REQUIREMENTS

2.1 Test Procedures

2.1.1 All tests shall be performed on a door weighing 150-lbs (68-kg) with the center of gravity 18 in. from the hinge or pivot centerline of rotation. The door must accommodate a load application point 30 in. from the hinge or pivot centerline of rotation.