

This is a preview of "BS EN 60669-2-6:2012". Click here to purchase the full version from the ANSI store.

**BS EN 60669-2-6:2012**



BSI Standards Publication

# Switches for household and similar fixed electrical installations

Part 2-6: Particular requirements —  
Fireman's switches for exterior and  
interior signs and luminaires

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

*raising standards worldwide™*



This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN 60669-2-6:2012. It was derived from IEC 60669-2-6:2012. It supersedes BS EN 50425:2008, which will be withdrawn on 22 February 2015.

The UK participation in its preparation was entrusted to Technical Committee PEL/23, Electrical accessories.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012

Published by BSI Standards Limited 2012

ISBN 978 0 580 68696 2

ICS 29.120.40

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 April 2012.

#### **Amendments issued since publication**

<b>Amd. No.</b>	<b>Date</b>	<b>Text affected</b>
-----------------	-------------	----------------------

---

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

NORME EUROPÉENNE  
EUROPÄISCHE NORM

March 2012

ICS 29.120.40

Supersedes EN 50425:2008

English version

**Switches for household and similar fixed electrical installations -  
Part 2-6: Particular requirements -  
Fireman's switches for exterior and interior signs and luminaires  
(IEC 60669-2-6:2012, modified)**

Interrupteurs pour installations électriques  
fixes domestiques et analogues -  
Partie 2-6: Prescriptions particulières -  
Interrupteurs pompiers pour enseignes  
lumineuses et luminaires extérieurs et  
intérieurs  
(CEI 60669-2-6:2012, modifiée)

Schalter für Haushalt und ähnliche  
ortsfeste elektrische Installationen -  
Teil 2-6: Besondere Anforderungen -  
Feuerwehrscharter für äußere und innere  
Anzeigen und Leuchten  
(IEC 60669-2-6:2012, modifiziert)

This European Standard was approved by CENELEC on 2012-02-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

The text of document 23B/990/CDV, future edition 1 of IEC 60669-2-6, prepared by SC 23B, "Plugs, socket-outlets and switches", of IEC TC 23, "Electrical accessories" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60669-2-6:2012.

A draft amendment, which covers common modifications to IEC 60669-2-6, was prepared by CLC/TC 23BX, "D.C. plugs and socket-outlets and switches for household and similar fixed electrical installations" and approved by CENELEC.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-02-22
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2015-02-22

This document supersedes EN 50425:2008.

EN 60669-2-6:2012 is to be used in conjunction with EN 60669-1:1999 + A1:2002 + A2:2008. It lists the changes necessary to convert that standard into a specific standard for fireman's switches.

In this publication, the following print types are used:

– requirements proper: in roman type;

– *test specifications: in italic type;*

– notes: in smaller roman type.

Subclauses, figures, tables or notes which are additional to those in part 1 are numbered starting from 101.

Clauses, subclauses, notes, tables, figures and annexes which are additional to those in IEC 60669-2-6:2012 are prefixed "Z".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

The text of the international standard IEC 60669-2-6:2012 was approved by CENELEC as a European Standard with agreed common modifications.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60669-2-4           NOTE Harmonized as EN 60669-2-4.

IEC 60364-5-51         NOTE Harmonized as HD 60364-5-51.

## COMMON MODIFICATIONS

### 1 Scope

**Replace the text of NOTE 101 by:**

NOTE 101 The working voltage for the signs and luminous-discharge-tube installations is higher than 1 kV but lower than 10 kV and these should be in accordance with EN 50107.

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

### **Normative references to international publications with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

#### ***Addition to Annex ZA of EN 60669-1:1999:***

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60669-1 (mod)	1998	Switches for household and similar fixed- electrical installations - Part 1: General requirements	EN 60669-1	1999
+ A1 (mod)	1999		+ A1	2002
+ A2 (mod)	2006		+ A2	2008
IEC 62262	-	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	-

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

## Special national conditions

**Special national condition:** National characteristic or practice that cannot be changed even over a long period, e.g. climatic conditions, electrical earthing conditions.

NOTE If it affects harmonization, it forms part of the European Standard / Harmonization Document.

For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.

Clause            Special national condition

**Foreword**        **United Kingdom**

Add an additional paragraph:

"Fireman's switches which cover applications suited to light industrial units, retail units and petrol station forecourts fall under the scope of EN 60947-3."

since the scope of EN 60669-1 only covers household and similar fixed electrical installations.

**13.108**            **France**

The enclosure of the fireman's switch and of the actuating handle could be of an other colour than red if it is equipped with an red illuminated indicator according to 13.107.

The colours yellow, green and blue are not allowed (according to NF X 08-003-1).

**13.108**            **Portugal**

Fireman's switches may have colours different from red for the enclosure and different from black for the actuating handle, if they are equipped with a red illuminated indicator, according to 13.107.

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

## A-deviations

**A-deviation:** National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC national member.

This European Standard falls under Directive 2006/95/EC.

NOTE (from CEN/CENELEC IR Part 2:2011, 2.17) Where standards fall under EU Directives, it is the view of the Commission of the European Communities (OJ No C 59, 1982-03-09) that the effect of the decision of the Court of Justice in case 815/79 Cremonini/Vrankovich (European Court Reports 1980, p. 3583) is that compliance with A-deviations is no longer mandatory and that the free movement of products complying with such a standard should not be restricted except under the safeguard procedure provided for in the relevant Directive.

In the relevant CENELEC countries these A-deviations are valid instead of the provisions of the European Standard/Harmonization Document until they have been removed.

### Clause      Deviation

#### 1            Italy (Installation Rules)

The Italian installation rules may require different protection switching devices in order to comply with the function given in the scope of this standard. The installation practice shall be in accordance with the requirements of the following Italian legislative decrees, applicable to the various types of installations.

Decree	Title
DPR 27/04/55 No. 547	Norme per la prevenzione degli infortuni sul lavoro
DPR 09/04/59 No. 128	Norme di polizia delle miniere e delle cave
DM 12/01/71 No. 208	Norme di sicurezza per gli impianti di distribuzione stradale di gas di petrolio liquefatto per autotrazione
DM 08/03/85	Direttive sulle misure più urgenti ed essenziali di prevenzione incendi ai fini del rilascio del nullaosta provvisorio di cui alla legge 7 dicembre 1984, n. 818
DM 11/01/88	Norme prevenzioni incendi nelle metropolitane
DM 20/05/92 No. 569	Regolamento contenente norme di sicurezza antincendio per gli edifici storici e artistici destinati a musei, gallerie, esposizioni e mostre
DM 26/08/92	Norme di prevenzione incendi per l'edilizia scolastica
DM 09/04/94	Approvazione della regola tecnica di prevenzione incendi per la costruzione e l'esercizio delle attività ricettive turistico-alberghiere.
DPR 30/06/95 No. 418	Regolamento concernente norme di sicurezza antincendio per gli edifici di interesse storico-artistico destinati a biblioteche ed archivi
DM 12/04/96	Approvazione della regola tecnica di prevenzione incendi per la progettazione, la costruzione e l'esercizio degli impianti termici alimentati da combustibili gassosi
DM 19/08/96	Approvazione della regola tecnica di prevenzione incendi per la progettazione, costruzione ed esercizio dei locali di intrattenimento e di pubblico spettacolo
DM 18/09/02	Approvazione della regola tecnica di prevenzione incendi per la progettazione, la costruzione e l'esercizio delle strutture sanitarie pubbliche e private
DM 28/04/05	Approvazione della regola tecnica di prevenzione incendi per la progettazione, la costruzione e l'esercizio degli impianti termici alimentati da combustibili liquidi
DM 18/03/96 DM 16/05/05	Norme di sicurezza per la costruzione e l'esercizio degli impianti sportivi
DM 22/02/06	Approvazione della regola tecnica di prevenzione incendi per la progettazione, la costruzione e l'esercizio di edifici e/o locali destinati ad uffici
DM 31/08/06	Approvazione della regola tecnica di prevenzione incendi per la progettazione, costruzione ed esercizio degli impianti di distribuzione di idrogeno per autotrazione



This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

The Portuguese Electrical Installation Rules and the Safety Code on Fire in Buildings also cover fireman's switches, for which the applicable requirements must follow the Portuguese legislation.

Decree	Title
Decreto-Lei N° 226/2005 Portaria N° 949-A/2006	Regras Técnicas das Instalações Eléctricas de Baixa Tensão  Clauses: 64- Exploração das instalações 536.4 -Dispositivos de corte de emergência 802- Instalações de alta tensão alimentadas a partir de instalações de baixa tensão
Decreto-Lei N° 220/2008 Portaria N°1532/2008	Regulamento Técnico de Segurança contra Incêndio em Edifícios (SCIE)

### 8.3 United kingdom

(UK wiring rules) Building and Buildings, England and Wales - The Building (Amendment) Regulations 2003 {Statutory Instrument 2003 No. 2692} which require compliance with UK Wiring Rules BS 7671:2001 (incl. Amendment 2), Clause 537-04-06.

The following information shall be distinctly and durably marked on the fireman's switch in a position where it can be clearly seen from a person standing on the ground at the intended site, without opening the enclosure and when the switch is installed:

- "ON" and "OFF" positions, in letters not less than 10 mm high;
- letters reading "FIREMAN'S SWITCH" or "FIRE SWITCH" in letters not less than 10 mm high.

### 13.101 United kingdom

(UK wiring rules) Building and Buildings, England and Wales - The Building (Amendment) Regulations 2003 {Statutory Instrument 2003 No. 2692} which require compliance with UK Wiring Rules BS 7671:2001 (incl. Amendment 2), Clause 537-04-06.

Once installed, the handle **off** position shall be up.

NOTE The **on** position means powered and the **off** position means unpowered.

Compliance is checked by inspection.

### 13.107 United kingdom

(UK wiring rules) Building and Buildings, England and Wales - The Building (Amendment) Regulations 2003 {Statutory Instrument 2003 No. 2692} which require compliance with UK Wiring Rules BS 7671:2001 (incl. Amendment 2), Clause 537-04-06.

This subclause does not apply.

In the UK, indication must be 'clearly indicated' as required by BS 7671 which means that use of an illuminated indicator is considered unsafe since a false indication will occur if there is a failure of the illumination indicator or circuit.

This is a preview of "BS EN 60669-2-6:2012". [Click here to purchase the full version from the ANSI store.](#)

November)

All the tests shall be carried out at a temperature of 850 °C.

This is a preview of "BS EN 60669-2-6:2012". Click here to purchase the full version from the ANSI store.

## CONTENTS

1	Scope.....	6
2	Normative references .....	6
3	Definitions .....	6
4	General requirements .....	7
5	General notes on tests .....	7
6	Ratings.....	7
7	Classification.....	7
8	Marking .....	8
9	Checking of dimensions.....	8
10	Protection against electric shock .....	8
11	Provision for earthing .....	8
12	Terminals .....	8
13	Constructional requirements.....	12
14	Mechanism.....	14
15	Resistance to ageing, protection provided by enclosures of switches and resistance to humidity.....	15
16	Insulation resistance and electric strength.....	15
17	Temperature rise .....	16
18	Making and breaking capacity .....	16
19	Normal operation.....	16
20	Mechanical strength .....	17
21	Resistance to heat.....	17
22	Screws, current-carrying parts and connections.....	18
23	Creepage distances, clearances and distances through sealing compound .....	18
24	Resistance of insulating material to abnormal heat, to fire and to tracking .....	18
25	Resistance to rusting.....	18
26	EMC requirements.....	18
	Bibliography.....	20
	Figure 101 – Minimum area of visibility .....	14
	Figure 102 – Sketches showing the application of blows .....	19
	Table 2 – Relationship between rated currents and connectable cross-sectional areas of copper conductors for screw type terminals .....	9
	Table 3 – Tightening torque for verification of the mechanical strength of screw-type terminals.....	10
	Table 4 – Test values for flexion and pull-out for copper conductors .....	11
	Table 5 – Test values for pull-out test.....	11
	Table 6 – Composition of conductors .....	11
	Table 7 – Relationship between rated currents and connectable cross-sectional areas of copper conductors for screwless terminals.....	12