

This is a preview of "BS EN ISO 15874-2:20...". Click here to purchase the full version from the ANSI store.

BS EN ISO 15874-2:2013



BSI Standards Publication

Plastics piping systems for hot and cold water installations — Polypropylene (PP)

Part 2: Pipes

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide™



This is a preview of "BS EN ISO 15874-2:20...". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN ISO 15874-2:2013. It supersedes BS EN ISO 15874-2:2003 which is withdrawn.

The UK participation in its preparation was entrusted by Technical Committee PRI/88, Plastics piping systems, to Subcommittee PRI/88/2, Plastics piping for pressure applications.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013

Published by BSI Standards Limited 2013

ISBN 978 0 580 71668 3

ICS 23.040.01; 91.140.60

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 March 2013.

Amendments issued since publication

Amd. No.	Date	Text affected
-----------------	-------------	----------------------

This is a preview of "BS EN ISO 15874-2:20...". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

February 2013

ICS 23.040.20; 91.140.60

Supersedes EN ISO 15874-2:2003

English Version

Plastics piping systems for hot and cold water installations - Polypropylene (PP) - Part 2: Pipes (ISO 15874-2:2013)

Systèmes de canalisations en plastique pour les
installations d'eau chaude et froide - Polypropylène (PP) -
Partie 2: Tubes (ISO 15874-2:2013)

Kunststoff-Rohrleitungssysteme für die Warm- und
Kaltwasserinstallation - Polypropylen (PP) - Teil 2: Rohre
(ISO 15874-2:2013)

This European Standard was approved by CEN on 5 January 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "BS EN ISO 15874-2:20...". [Click here to purchase the full version from the ANSI store.](#)

Contents

Page

Foreword.....	3
---------------	---

This is a preview of "BS EN ISO 15874-2:20...". [Click here to purchase the full version from the ANSI store.](#)

Foreword

This document (EN ISO 15874-2:2013) has been prepared by Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems" the secretariat of which is held by NEN, in collaboration with Technical Committee ISO/TC 138 "Plastics pipes, fittings and valves for the transport of fluids".

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2013, and conflicting national standards shall be withdrawn at the latest by August 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 15874-2:2003.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN ISO 15874-2:20...". Click here to purchase the full version from the ANSI store.

Contents		Page
Introduction		v
1	Scope	1
2	Normative references	1
3	Terms and definitions, symbols and abbreviated terms	2
4	Material	2
4.1	Pipe material	2
4.2	Evaluation of σ_{LPL}-values	2
4.3	Influence on water intended for human consumption	7
5	General characteristics	8
5.1	Appearance	8
5.2	Opacity	8
6	Geometrical characteristics	8
6.1	General	8
6.2	Dimensions of pipes	9
7	Mechanical characteristics	12
8	Physical and chemical characteristics	13
9	Performance requirements	14
10	Marking	14
10.1	General requirements	14
10.2	Minimum required marking	14
Annex A (informative) Derivation of $S_{calc,max}$		15
Bibliography		18

This is a preview of "BS EN ISO 15874-2:20...". Click here to purchase the full version from the ANSI store.

Introduction

This part of ISO 15874 specifies the requirements for a piping system when made from polypropylene (PP). The piping system is intended to be used for hot and cold water installations.

Regarding potential adverse effects on the quality of water intended for human consumption, caused by the product covered by ISO 15874

- no information is provided as to whether the product can be used without restriction;
- existing national regulations concerning the use and/or the characteristics of this product remain in force.

Requirements and test methods for material and components, other than pipes, are specified in ISO 15874-1 and ISO 15874-3. Characteristics for fitness for purpose (mainly for joints) are covered in ISO 15874-5. ISO/TS 15874-7 gives guidance for the assessment of conformity.

This part of ISO 15874 specifies the characteristics of pipes.

At the date of publication of this part of ISO 15874, the following system International Standards for piping systems of other plastics materials used for the same application are

- ISO 15875, *Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X)*
- ISO 15876, *Plastics piping systems for hot and cold water installations — Polybutylene (PB)*
- ISO 15877, *Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C)*
- ISO 22391, *Plastics piping systems for hot and cold water installations — Polyethylene of raised temperature resistance (PE-RT)*

The International Organization for Standardization (ISO) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent.

ISO takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured ISO that they are willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with ISO. Information may be obtained from:

Borealis AG

Wagramerstrasse 17-19, A-1220,

Vienna, Austria

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. ISO shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line databases of patents relevant to their standards. Users are encouraged to consult the databases for the most up to date information concerning patents.

This is a preview of "BS EN ISO 15874-2:20...". Click here to purchase the full version from the ANSI store.

Plastics piping systems for hot and cold water installations — Polypropylene (PP) —

Part 2: Pipes

1 Scope

This part ISO 15874 specifies the requirements of pipes made from polypropylene (PP) for piping systems intended to be used for hot and cold water installations within buildings for the conveyance of water whether or not intended for human consumption (domestic systems) and for heating systems under operating pressures and temperatures appropriate to the class of application (see ISO 15874-1:2013, Table 1).

This part of ISO 15874 covers a range of service conditions (application classes), design pressures and pipe dimension classes. For values of T_D , T_{max} and T_{maj} in excess of those in Table 1 of ISO 15874-1:2013 do not apply.

NOTE 1 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

It also specifies the test parameters for the test methods referred to in this part of ISO 15874.

In conjunction with the other parts of ISO 15874, this part of ISO 15874 is applicable to PP pipes, their joints and to joints with components of PP, other plastics and non-plastics materials intended to be used for hot and cold water installations.

It is applicable to pipes with or without (a) barrier layer(s).

NOTE 2 In the case of plastics pipes provided with a thin barrier layer, e.g. to prevent or greatly diminish the diffusion of gases and the transmission of light into or through the pipe wall, the design stress requirements are totally met by the base polymer (PP).

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1133-1, *Plastics — Determination of the melt mass-flow rate (MFR) and the melt volume-flow rate (MVR) of thermoplastics — Part 1: Standard method*

ISO 1167-1 *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method*

ISO 1167-2 *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 2: Preparation of pipe test pieces*

ISO 2505 *Thermoplastics pipes — Longitudinal reversion — Test methods and parameters*

ISO 3126 *Plastics piping systems — Plastics components — Determination of dimensions*

ISO 4065:1996, *Thermoplastics pipes — Universal wall thickness table*

ISO 7686 *Plastics pipes and fittings — Determination of opacity*

ISO 9080 *Plastics piping and ducting systems — Determination of the long-term hydrostatic strength of thermoplastics materials in pipe form by extrapolation*