

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

**BS EN 15091:2013**



**BSI Standards Publication**

# **Sanitary tapware — Electronic opening and closing sanitary tapware**

**bsi.**

...making excellence a habit.™

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN 15091:2013. It supersedes BS EN 15091:2006 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee B/504, Water supply.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013. Published by BSI Standards Limited 2013

ISBN 978 0 580 78256 5

ICS 91.140.70

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 December 2013.

**Amendments issued since publication**

Date	Text affected
------	---------------

---

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

## EUROPÄISCHE NORM

December 2013

ICS 91.140.70

Supersedes EN 15091:2006

English Version

## Sanitary tapware - Electronic opening and closing sanitary tapware

Robinetterie sanitaire - Robinet sanitaire à ouverture et fermeture électroniques

Sanitärarmaturen - Sanitärarmaturen mit elektronischer Öffnungs- und Schließfunktion

This European Standard was approved by CEN on 26 October 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

## Contents

Page

Foreword.....	5
Introduction .....	6
1 Scope .....	7
2 Normative references .....	9
3 Terms and definitions .....	10
4 General requirements and testing .....	11
4.1 Marking .....	11
4.2 Materials .....	11
4.2.1 Chemical and hygienic requirements .....	11
4.2.2 Exposed surface conditions .....	11
4.3 Functions .....	11
4.4 Protection against pollution .....	11
4.5 Electric characteristics and requirements .....	11
4.5.1 General.....	11
4.5.2 Electrical safety.....	11
4.5.3 Electrical operation of solenoid valves .....	12
4.5.4 Electric strength and insulation resistance of the solenoid valve .....	12
4.5.5 Operational safety.....	12
4.6 Leaktightness characteristics .....	13
4.6.1 General.....	13
4.6.2 Principle.....	13
4.6.3 Apparatus .....	14
4.6.4 Leaktightness of tapware upstream of the obturator .....	14
4.6.5 Leaktightness of tapware downstream of the obturator with the obturator open .....	14
4.6.6 Leaktightness tests - Summary table .....	14
4.7 Pressure resistance characteristics - mechanical performance under pressure .....	15
4.7.1 General.....	15
4.7.2 Principle.....	15
4.7.3 Apparatus .....	15
4.7.4 Procedure .....	15
4.7.5 Requirements .....	15
5 Requirements and testing for tapware .....	15
5.1 Scope .....	15
5.2 Dimensional characteristics .....	15
5.2.1 General.....	15
5.2.2 Tap with visible body for horizontal surfaces .....	15
5.2.3 Taps with visible body for mounting on vertical surfaces .....	17
5.2.4 In-line tapware with threaded inlet and outlet .....	17
5.2.5 Concealed tapware for vertical surfaces.....	18
5.2.6 Mixing valves for horizontal surface.....	18
5.2.7 Mixing valves with visible body for mounting on vertical surfaces with captive nuts and eccentric unions .....	20
5.2.8 Mixing valves with opposed inlets.....	20
5.2.9 Nozzle outlets for use with flow rate regulators .....	22
5.2.10 Special cases .....	22
5.3 Hydraulic characteristics .....	22
5.3.1 General.....	22
5.3.2 Test apparatus for tapware intended for Type 1 water supply systems.....	23

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

5.3.3	Principle of the flow test .....	26
5.3.4	Requirements .....	27
5.3.5	Cross flow between hot and cold water .....	27
5.4	Water hammer .....	27
5.4.1	Principle of water hammer test .....	27
5.4.2	Test apparatus .....	28
5.4.3	Procedure .....	28
5.4.4	Requirements .....	29
5.5	Endurance .....	29
5.5.1	General.....	29
5.5.2	Principle.....	29
5.5.3	Procedure for single taps .....	29
5.5.4	Procedure for mixers.....	30
5.5.5	Requirements .....	30
5.6	Acoustic characteristics .....	30
5.6.1	General.....	30
5.6.2	Procedure .....	31
5.6.3	Requirements .....	31
6	Requirements and testing for flushing valves for urinals .....	32
6.1	Scope .....	32
6.2	Definitions .....	32
6.2.1	Single flush urinal valves.....	32
6.2.2	Siphon action flushing urinal valves .....	32
6.2.3	Isolating valves for flushing urinal valves .....	32
6.3	Classification of flushing urinal valves .....	32
6.4	Designation .....	33
6.5	Dimensional characteristics .....	33
6.6	Hydraulic characteristics .....	34
6.6.1	General.....	34
6.6.2	Test method .....	34
6.7	Measurement of water hammer for urinal flushing valves .....	35
6.7.1	Principle of water hammer test .....	35
6.7.2	Test apparatus .....	35
6.7.3	Procedure .....	35
6.7.4	Requirements .....	36
6.8	Mechanical endurance .....	36
6.8.1	General.....	36
6.8.2	Apparatus .....	36
6.8.3	Procedure .....	36
6.8.4	Requirements .....	37
7	Requirements and testing for flushing valves for WCs .....	37
7.1	Scope .....	37
7.2	Definitions .....	37
7.3	Classification .....	38
7.3.1	General.....	38
7.3.2	6 l and 6 to 9 l valves .....	38
7.3.3	9 l valves .....	38
7.4	Dimensional characteristics .....	38
7.5	Hydraulic characteristics .....	39
7.5.1	General.....	39
7.5.2	Test method .....	39
7.5.3	Testing of the flow rate / Impact force at lower dynamic pressure .....	43
7.5.4	Testing of the flow rate / Volume at lower dynamic pressure.....	44
7.5.5	Testing of flush flow rate / impact force at upper dynamic pressure .....	45
7.5.6	Measurement of water hammer.....	46
7.6	Principle and verification of atmospheric pipe interrupters of WC flushing valves .....	46
7.7	Mechanical endurance .....	47

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

7.7.1	General.....	47
7.7.2	Procedure .....	47
7.7.3	Minimum requirements .....	47
7.8	Acoustic characteristics .....	47
<b>Annex A (normative) Design of pressure take-off tees .....</b>		<b>48</b>
<b>Annex B (informative) Potential consequences of use outside the recommended operating limits .....</b>		<b>50</b>
<b>Bibliography .....</b>		<b>51</b>

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

## Foreword

This document (EN 15091:2013) has been prepared by Technical Committee CEN/TC 164 "Water Supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2014, and conflicting national standards shall be withdrawn at the latest by June 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15091:2006.

Significant technical differences between this edition and EN 15091:2006 are as follows:

- the introduction of a maximum voltage;
- the change of dimensional characteristics (see 5.2);
- the change in minimum flow rates and hammer test (5.3.5 and 5.3.3).

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 15091:2013". [Click here to purchase the full version from the ANSI store.](#)

## Introduction

This standard is relevant for electrically operated (opening and closing) sanitary tapware used with sanitary appliances, with a maximum voltage of 42 V AC / 72 V DC, in the enclosure of the tap.

Such tapware can be operated by any electrical source e.g. mains with a transformer, battery, etc.

Flow and temperature regulation devices installed either upstream or downstream of the tapware are not covered by this specification.

The purpose of this standard is to define requirements for the:

- 1) marking, identification, leak-tightness, electrical and operational safety, mechanical performance and limitation of water hammer for electrical opening and closing tapware;
- 2) dimensional, hydraulic, endurance and acoustic characteristics;
- 3) procedure of tests in order to verify these characteristics.

As for possible unfavourable effects of the product to which this standard applies, on the quality of water intended for human consumption:

- 4) no information is provided by this standard on possible use restrictions of the product in any of the member states of the EU or EFTA;
- 5) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or characteristics of this product remain in force.

Requirements for different products are defined in different clauses of this standard as illustrated in Table 1.

**Table 1 — Identification of the clauses of this standard**

	MARKING	DIMENSIONAL CHARACTERISTICS	ENDURANCE	ACOUSTIC	ELECTRICAL SAFETY	OPERATIONAL SAFETY	LEAKTIGHTNESS	MECHANICAL RESISTANCE	HYDRAULIC CHARACTERISTICS	WATER HAMMER	WATER HAMMER FOLLOWING PRODUCT STANDARD
Clause 4. General requirements and testing	X				X	X	X	X			
Clause 5. Requirements and testing for tapware		X	X	X					X	X	
Clause 6. Requirements and testing for flushing valves for urinals		X	X						X	X	
Clause 7. Requirements and testing for flushing valves for WCs		X	X	X					X		X



This is a preview of "BS EN 15091:2013". Click here to purchase the full version from the ANSI store.

## 1 Scope

The purpose of this European Standard is to define requirements for marking, identification, leaktightness, electrical and operational safety and mechanical resistance for sanitary tapware with opening and closing controlled electronically.

The conditions of use for the supply system type are specified in Table 2:

**Table 2 — Conditions of use**

Water supply system		Limits of use		Recommended limits of operation	
		Tapware with normally open or normally closed (monostable) solenoid valves	Tapware with latching (bistable) solenoid valves	Tapware with normally open or normally closed (monostable) solenoid valves	Tapware with latching (bistable) solenoid valves
Type 1 (see Figure 1)	Minimum pressure dynamic	0,05 MPa (0,5 bar)	0,05 MPa (0,5 bar)	(0,1 to 0,5) MPa [(1 to 5) bar]	(0,1 to 0,5) MPa [(1 to 5) bar]
	Maximum pressure static	1 MPa (10 bar)	1 MPa (10 bar)	1 MPa (10 bar)	0.8 MPa (8 bar)
Type 2 <sup>a</sup> (see Figure 2)	Minimum pressure dynamic	0,01 MPa (0,1 bar)	0,01 MPa (0,1 bar)	(0,01 to 0,2) MPa [(0,1 to 2) bar]	(0,01 to 0,2) MPa [(0,1 to 2) bar]
	Maximum pressure static	1 MPa (10 bar)	1 MPa (10 bar)	0.8 MPa (8 bar)	0.6 MPa (6 bar)
Temperature of the water		≤ 75 °C	≤ 75 °C	≤ 65 °C	≤ 65 °C
<p><sup>a</sup> For Type 2, the manufacturer is to declare the minimum operating pressure at which opening, closing and the specified flow rate can be obtained.</p> <p>There is usually no acoustic classification for tapware used in supply systems of Type 2 and no specifications governing the level of noise emissions from these water installations. If supply pressures are such that excessive noise is generated it is recommended that pressure or flow regulators are fitted in the system. Or where practicable, tapware conforming to the appropriate acoustic classification are used.</p>					

Annex B lists possible consequences of using a product outside its recommended operating range.