

This is a preview of "BS EN 488:2011+A1:20...". Click here to purchase the full version from the ANSI store.

BS EN 488:2011+A1:2014



BSI Standards Publication

**District heating pipes —
Preinsulated bonded pipe
systems for directly buried
hot water networks — Steel
valve assembly for steel service
pipes, polyurethane thermal
insulation and outer casing of
polyethylene**

bsi.

...making excellence a habit.™

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN 488:2011+A1:2014. It supersedes BS EN 488:2011 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/9, Insulated underground pipelines.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.
Published by BSI Standards Limited 2014

ISBN 978 0 580 79489 6
ICS 23.060.01; 91.140.60

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 April 2011.

Amendments/corrigenda issued since publication

Date	Text affected
31 March 2014	Implementation of CEN amendment A1:2014

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

February 2014

ICS 23.060.01

English Version

District heating pipes - Preinsulated bonded pipe systems for directly buried hot water networks - Steel valve assembly for steel service pipes, polyurethane thermal insulation and outer casing of polyethylene

Tuyaux de chauffage urbain - Systèmes bloqués de tuyaux préisolés pour les réseaux d'eau chaude enterrés directement - Robinets préisolés pour tubes de service en acier, isolation thermique en polyuréthane et tube de protection en polyéthylène

Fernwärmerohre - Werkmäßig gedämmte Verbundmantelrohrsysteme für direkt erdverlegte Fernwärmenetze - Vorgeämmte Absperrarmaturen für Stahlmediumrohre mit Polyurethan-Wärmedämmung und Außenmantel aus Polyethylen

This European Standard was approved by CEN on 19 February 2011 and includes Amendment 1 approved by CEN on 30 November 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	9
4.1 Pressure ratings for valves.....	9
4.1.1 General.....	9
4.1.2 Valves without indicated flow direction	10
4.2 Service temperatures for valves	10
4.3 Steel parts.....	10
4.3.1 General.....	10
4.3.2 Valve.....	10
4.3.3 Valve extension pipe	10
4.3.4 Welding ends.....	10
4.3.5 Welding of steel parts	10
4.4 Casing	10
4.4.1 General.....	10
4.4.2 Requirements for polyethylene welding	10
4.4.3 Diameter and wall thickness of the casing	11
4.5 Polyurethane rigid foam insulation (PUR)	11
4.5.1 General.....	11
4.5.2 Minimum insulation thickness	11
4.6 Valve assembly	11
4.6.1 Ends of valve assembly	11
4.6.2 End of stem construction	11
4.6.3 Main dimensions of the valve assembly	12
4.6.4 Installation of measuring elements.....	13
4.7 Requirements for effective operation and maintenance	13
4.8 Resistance to axial forces and bending moments	13
5 Testing, test methods and test requirements	13
5.1 General.....	13
5.2 Test specimens	13
5.2.1 General.....	13
5.2.2 Test specimens for type testing steel parts of valve	14
5.2.3 Test specimens from casings and polyurethane foam.....	14
5.3 Steel parts.....	14
5.3.1 General.....	14
5.3.2 Type test of the steel parts	14
5.3.3 Production testing of valves.....	16
5.4 Casing	17
5.4.1 General.....	17
5.4.2 Leak-tightness of the welded casing	17
5.5 Polyurethane rigid foam insulation.....	17
5.6 Valve assembly	17
5.7 Surveillance system	17
6 Marking	17
6.1 General.....	17

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

6.2	Steel valve	17
6.3	Casing	17
6.4	Valve assembly	18
7	Installation and maintenance	18
Annex A	(informative) Guidelines for inspection and testing	19
A.1	General	19
A.2	Manufacturer's type test	19
A.3	Manufacturer's quality control	19
A.4	External inspection	19
A.5	Extent of inspection	19
A.6	Manufacturer's responsibility	19
Annex B	(normative) Resistance to axial force and bending moment	22
B.1	Axial strength test	22
B.2	Bending test	22
Annex C	(normative) Resistance to bending forces	24
C.1	Resistance to bending forces	24
	Bibliography	30

Foreword

This document (EN 488:2011+A1:2014) has been prepared by Technical Committee CEN/TC 107 "Prefabricated district heating pipe systems", the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2014, and conflicting national standards shall be withdrawn at the latest by August 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1, approved by CEN on 2013-11-30.

A1 This document includes Amendment A1 to EN 488:2011, that comprises technical changes to:

- Sub-Clause 4.6.2, End of stem construction. **A1**

This document supersedes **A1** EN 488:2011 **A1**.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** **A1**.

Annex A is informative, Annexes B and C are normative.

This document includes a Bibliography.

The first edition of EN 488 was approved in 1994. The first revised standard was published in 2003. In this second revision, in general the whole standard has been edited to make it more readable. Requirements and test methods have been separated; therefore, clause numbers have changed and some clauses have been split up in several clauses. Exact references for changes are not always possible. The main areas of the current revision are:

- a) The scope has been amended. The standard applies no longer only to insulated valve assemblies for continuous operation with hot water at various temperatures in accordance with EN 253:2009, Clause 1 but also to the valve assemblies with a maximum operation pressure of 25 bar. For higher pressure, additional demands apply. It is also explained that the calculation rules of loads and stresses are not included. They depend on the configuration of the system as it is installed. The design and installation rules are given in EN 13941:2009+A1:2010.
- b) In Clause 3, "terms and definitions", definitions for the nominal pressure (PN), nominal size (DN) and maximum operation pressure have been added. A figure "Example valve assembly components" of a valve assembly, its components and definitions has been added.
- c) Clause 4, "requirements"
 - 1) material of the steel parts in the pressurized parts of the valve shall be certified in accordance with EN 10204, the 3.1 certificate (4.3.1);
 - 2) it is added that flanged or screwed connections, except sealing system at the stem, shall not be used except in the non-pressurized area e.g. for the stem extensions (4.3.2);
 - 3) the requirements for the use of stop devices are amended (4.7);
 - 4) the minimum water temperature has been adjusted to 4 °C (4.2);

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

- 5) 4.3.5 "Welding of steel parts" has been changed and adjusted to EN 13941:2009+A1:2010 and the text in EN 448;
 - 6) 4.1.6 has become 4.8 "resistance to axial forces bending moments" and has been rewritten in Annex B;
 - 7) additions have been made to the requirements to the corrosion protection of the stem (see 4.6);
 - 8) the Clause "increase in diameter" has been changed to "diameter and wall thickness of the casing" (see 4.4.3);
 - 9) a table with the tolerances of the main dimensions has been added together with a figure to explain the dimensions (see 4.6.3);
 - 10) a clause was added about the installation of measuring elements for surveillance (see 4.6.4).
- d) Clause 5, "test methods"
- 1) the clause "Testing, test methods and test requirements" has been adjusted to make the order of test clearer;
 - 2) a test for the surveillance system is added (see 5.7).
- e) Clause 6, "marking"
- 1) for the steel valve pressure and temperature and marking with closed and open position;
 - 2) for the casing the date of manufacture has been changed to year and week of manufacture (see 6.3);
 - 3) for the valve assembly, the type of blowing agent and diffusion barrier has been added (see 6.4).
- f) Annex A, "guidelines for inspection and testing"
- 1) the clause about quality surveillance had been changed in quality control (see A.3);
 - 2) a table for the valve assembly inspection had been added.
- g) Former Annex B, the guidelines for installation of the valves has been deleted. New Annexes B and C have been added, in which the actual testing is included.
- h) The former Table 1, "Service pipe dimensions and test forces" has been changed due to cold laying conditions. Therefore, the compressive forces have been adapted. In this table the maximum allowable bending moments have been included and the table has been moved to Annex B.
- i) A description of the test method for bending forces has been added in Annex C.

In general, references were changed where needed. If possible references to European standards were used.

For information on the minimum expected thermal life with operation at various temperatures with respect to PUR foam performance see EN 253.

The other standards from CEN/TC 107 covering this subject are:

- EN 253, *District heating pipes — Preinsulated bonded pipe systems for directly buried hot water networks — Pipe assembly of steel service pipe, polyurethane thermal insulation and outer casing of polyethylene;*

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

- EN 448, *District heating pipes — Preinsulated bonded pipe systems for directly buried hot water networks — Fitting assemblies of steel service pipes, polyurethane thermal insulation and outer casing of polyethylene;*
- EN 489, *District heating pipes — Preinsulated bonded pipe systems for directly buried hot water networks — Joint assembly for steel service pipes, polyurethane thermal insulation and outer casing of polyethylene;*
- EN 13941:2009+A1:2010, *Design and installation of preinsulated bonded pipe systems for district heating;*
- EN 14419, *District heating pipes — Preinsulated bonded pipe systems for directly buried hot water networks — Surveillance systems;*
- EN 15632 (all parts), *District heating pipes — Pre-insulated flexible pipe systems;*
- EN 15698-1, *District heating pipes — Preinsulated bonded twin pipe systems for directly buried hot water networks — Part 1: Twin pipe assembly of steel service pipe, polyurethane thermal insulation and outer casing of polyethylene.*

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 488:2011+A1:20...". [Click here to purchase the full version from the ANSI store.](#)

1 Scope

This European Standard specifies requirements and test methods for valves of prefabricated thermally insulated valve assemblies comprising a steel valve, rigid polyurethane foam insulation and an outer casing of polyethylene for use in directly buried hot water networks with pre-insulated pipe assemblies in accordance with EN 253.

This European Standard applies only to insulated valve assemblies for continuous operation with hot water at various temperatures in accordance with EN 253:2009, Clause 1 and the valve assemblies with a maximum operation pressure of 25 bar. For higher pressures, additional demands apply.

Guidelines for quality inspection are given in Annex A of this European Standard.

NOTE For this application, the following valve types are commonly used: ball valves, gate valves, and butterfly valves.

This European Standard does not include calculation rules for loads and stresses. These depend on the configuration of the system as it is installed. The design and installation rules are given in EN 13941:2009+A1:2010.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 19, *Industrial valves - Marking of metallic valves*

EN 253:2009, *District heating pipes — Preinsulated bonded pipe systems for directly buried hot water networks — Pipe assembly of steel service pipe, polyurethane thermal insulation and outer casing of polyethylene*

EN 448:2009, *District heating pipes - Preinsulated bonded pipe systems for directly buried hot water networks - Fitting assemblies of steel service pipes, polyurethane thermal insulation and outer casing of polyethylene*

EN 736-1:1995, *Valves - Terminology - Part 1: Definition of types of valves*

EN 10088-1:2005, *Stainless steels - Part 1: List of stainless steels*

EN 10204:2004, *Metallic products - Types of inspection documents*

EN 12266-1:2003, *Industrial valves — Testing of valves — Part 1: Pressure tests, test procedures and acceptance criteria — Mandatory requirements*

EN 13941:2009+A1:2010, *Design and installation of preinsulated bonded pipe systems for district heating*

EN 14419, *District heating pipes - Preinsulated bonded pipe systems for directly buried hot water networks - Surveillance systems*

EN ISO 12944-2, *Paints and varnishes — Corrosion protection of steel structures by protective paint systems — Part 2: Classification of environments (ISO 12944-2)*

EN ISO 12944-5, *Paints and varnishes — Corrosion protection of steel structures by protective paint systems — Part 5: Protective paint systems (ISO 12944-5)*