

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

BS EN 1434-1:2015



BSI Standards Publication

Heat meters

Part 1: General requirements

bsi.

...making excellence a habit.™

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN 1434-1:2015. It supersedes BS EN 1434-1:2007 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee CPI/30, Measurement of fluid flow in closed conduits.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.
Published by BSI Standards Limited 2015

ISBN 978 0 580 84658 8

ICS 17.200.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2015.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

November 2015

ICS 17.200.10

Supersedes EN 1434-1:2007

English Version

Heat meters - Part 1: General requirements

Compteurs d'énergie thermique - Partie 1:
Prescriptions générales

Wärmezähler - Teil 1: Allgemeine Anforderungen

This European Standard was approved by CEN on 5 September 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

Contents	Page
European foreword.....	4
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions.....	6
4 Types of instruments.....	11
4.1 General.....	11
4.2 Complete instrument.....	11
4.3 Combined instrument.....	11
4.4 Hybrid instrument.....	11
4.5 Sub-assemblies of a heat meter, which is a combined instrument.....	11
4.5.1 General.....	11
4.5.2 Flow sensor.....	12
4.5.3 Temperature sensor pair.....	12
4.5.4 Calculator.....	12
4.6 Equipment under test (EUT).....	12
5 Rated operating conditions.....	12
5.1 Limits of temperature range.....	12
5.2 Limits of temperature differences.....	12
5.3 Limits of flow rate.....	12
5.4 Limit of thermal power.....	13
5.5 Limits of working pressure (P_S and P_{min}).....	13
5.6 Nominal pressure (PN).....	13
5.7 Limits in ambient temperature.....	13
5.8 Limits in deviations in supply voltage.....	13
5.9 Maximum pressure loss.....	13
5.10 Specific requirements on registration devices.....	13
5.10.1 General.....	13
5.10.2 Suitability.....	13
5.10.3 Rated operated conditions.....	14
5.10.4 Indication.....	14
5.10.5 MPE.....	15
6 Technical characteristics.....	15
6.1 Materials and construction.....	15
6.2 Requirements outside the limiting values of the flow rate.....	16
6.3 Display.....	16
6.4 Protection against fraud.....	16
6.5 Supply voltage.....	17
6.6 Qualifying immersion depth of a temperature sensor.....	17
6.7 The influence on a temperature sensor pair caused by mounting in pockets.....	17
6.8 Reproducibility.....	17
6.9 Repeatability.....	17
6.10 Software.....	18
7 Specified working range.....	18
7.1 General.....	18

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

7.2	Temperature difference	18
7.3	Flow rate	18
8	Heat transmission formula	18
9	Metrological characteristics (Maximum Permissible Error, MPE)	19
9.1	General	19
9.2	Values of maximum permissible errors	19
9.2.1	Maximum permissible relative errors of complete heat meters.....	19
9.2.2	Maximum permissible relative error of sub-assemblies	19
9.3	Application of maximum permissible errors	20
10	Environmental classification.....	20
10.1	General	20
10.2	Environmental class A (Domestic use, indoor installations).....	21
10.3	Environmental class B (Domestic use, outdoor installations)	21
10.4	Environmental class C (Industrial installations)	21
10.5	Mechanical classes M1 to M3	21
11	Heat meter specification	21
11.1	General	21
11.2	Flow sensor	21
11.3	Temperature sensor pair.....	23
11.4	Calculator.....	23
11.5	Complete meters.....	25
12	Information to be made available by the manufacturer or supplier	26
12.1	Installation instructions.....	26
12.2	Parameter setting instructions.....	27
12.3	Adjustment instructions	28
12.4	Maintenance instructions.....	28
12.5	Hints for disposal instructions	29
Annex A (normative) Heat coefficient equations		30
Annex B (normative) Flow conditioner package.....		32
Annex C (normative) Fast response meters.....		34
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2004/22/EC, MID.....		35
Bibliography		37

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

European foreword

This document (EN 1434-1:2015) has been prepared by Technical Committee CEN/TC 176 "Heat meters", the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2016, and conflicting national standards shall be withdrawn at the latest by May 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1434-1:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For relationship with EU Directive, see informative Annex ZA, which is an integral part of this document.

EN 1434, *Heat meters* consists of the following parts:

- *Part 1: General requirements*
- *Part 2: Constructional requirements*
- *Part 3: Data exchange and interfaces¹⁾*
- *Part 4: Pattern approval tests*
- *Part 5: Initial verification tests*
- *Part 6: Installation, commissioning, operational monitoring and maintenance*

In comparison to EN 1434-1:2007, the following changes have been made:

- special cases for combined cooling and heating meters are added;
- additional functionality for smart metering applications are added;
- metrological requirements for smart metering applications are added;
- definitions and requirements for the cooling meter are added;
- tariff meters are added;
- terms and definitions, requirements for registration devices and cooling meters are added;
- requirements for fast response meters are added (informative Annex C).

¹⁾ EN 1434-3 is maintained by CEN/TC 294.

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 1434-1:2015". [Click here to purchase the full version from the ANSI store.](#)

1 Scope

This European Standard specifies the general requirements for heat meters. Heat meters are instruments intended for measuring the energy which in a heat-exchange circuit is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The heat meter indicates the quantity of heat in legal units.

Electrical safety requirements are not covered by this European Standard.

Pressure safety requirements are not covered by this European Standard.

Surface mounted temperature sensors are not covered by this European Standard.

This standard covers meters for closed systems only, where the differential pressure over the thermal load is limited.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1434-2:2015, *Heat meters — Part 2: Constructional requirements*

EN 1434-4:2015, *Heat meters — Part 4: Pattern approval test*

EN 60751, *Industrial platinum resistance thermometers and platinum temperature sensors (IEC 60751)*

EN 61010-1, *Safety requirements for electrical equipment for measurement, control and laboratory use — Part 1: General requirements (IEC 61010-1)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 response time

$\tau_{0,5}$
time interval between the instant when flow or temperature difference is subjected to a specified abrupt change and the instant when the response reaches 50 % of the step value

3.2 fast response meter

meter suitable for heat exchanging circuits with rapid dynamic variations in the exchanged heat

Note 1 to entry: See also Annex C.

3.3 rated voltage

U_n
voltage of the external power supply required to operate the heat meter, conventionally the voltage of the AC mains supply

3.4 rated operating conditions

conditions of use, giving the range of values of influence quantities, for which the metrological characteristics of the instrument are within the specified maximum permissible errors