



BSI Standards Publication

Energy performance of buildings - Ventilation for buildings

Part 3: For non-residential buildings - Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

National foreword

This British Standard is the UK implementation of EN 16798-3:2017. It supersedes BS EN 13779:2007, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/2, Ventilation for buildings, heating and hot water services.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017
Published by BSI Standards Limited 2017

ISBN 978 0 580 85866 6

ICS 91.140.30; 91.120.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 August 2017.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

August 2017

ICS 91.120.10; 91.140.30

Supersedes EN 13779:2007

English Version

**Energy performance of buildings - Ventilation for buildings
- Part 3: For non-residential buildings - Performance
requirements for ventilation and room-conditioning
systems (Modules M5-1, M5-4)**

Performance énergétique des bâtiments - Ventilation
des bâtiments - Partie 3: Pour bâtiments non
résidentiels - Exigences de performances pour les
systèmes de ventilation et de climatisation (Modules
M5-1, M5-4)

Energetische Bewertung von Gebäuden - Lüftung von
Gebäuden - Teil 3: Lüftung von Nichtwohngebäuden -
Leistungsanforderungen an Lüftungs- und
Klimaanlagen und Raumkühlssysteme (Module M5-1,
M5-4)

This European Standard was approved by CEN on 11 May 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword	4
Introduction	7
1 Scope	9
2 Normative references	11
3 Terms and definitions	12
4 Symbols and subscripts	13
4.1 Symbols.....	13
4.2 Subscripts.....	15
5 Brief description of the method and routing	15
5.1 Output of the method.....	15
5.2 General description of the method.....	15
6 Output data for energy calculation	16
7 Indoor environment	17
7.1 General.....	17
7.2 Occupied zone	18
8 Agreement of design criteria	20
8.1 General.....	20
8.2 Principles	20
8.3 General building characteristics	20
8.4 Construction data.....	21
8.5 Geometrical description.....	21
8.6 Use of the rooms	21
8.7 Requirements in the rooms.....	22
8.8 System requirements.....	22
8.9 Heat transmission of surfaces of ventilation systems	23
8.10 General requirements for control, adjustment and monitoring.....	23
8.11 General requirements for maintenance and safety of operation	23
8.12 Process from project initiation to operation	24
8.13 Supply air humidity.....	24
9 Classification	25
9.1 Specification of types of air.....	25
9.2 Classification of air	27
9.3 System functions and basic system types.....	29
9.4 Design air flow balance	32
9.5 Specific fan power	33
9.6 Heat recovery section.....	37
9.7 Filtration	39
9.8 Leakages in ventilation systems	40
10 Calculation and energy rating	43
10.1 Ventilation effectiveness and air diffusion.....	43

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

10.2	Calculation of air volume flows	44
10.3	Energy rating of ventilation systems.....	45
	Annex A (normative) Input and method selection data sheet — Template	47
A.1	General	47
A.2	References.....	47
A.3	Design data for energy calculation - Typical range for SFP categories	48
A.4	Design data.....	48
	Annex B (informative) Input and method selection data sheet — Default choices	50
B.1	General	50
B.2	References.....	50
B.3	Default design data for energy calculation.....	52
B.4	Default design data	52
	Bibliography	55

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

European foreword

This document (EN 16798-3:2017) has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2018, and conflicting national standards shall be withdrawn at the latest by February 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This standard has been produced to meet the requirements of Directive 2010/31/EU 19 May 2010 on the energy performance of buildings (recast), referred to as "recast EPBD".

This document supersedes EN 13779:2007, which was produced to meet the requirements of Directive 2002/91/EC 16 December 2002 on energy performance of buildings referred to as "EPBD".

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

For the convenience of Standards users CEN/TC 156, together with responsible Working Group Conveners, have prepared a simple table below relating, where appropriate, the relationship between the 'EPBD' and 'recast EPBD' standard numbers prepared by Technical Committee CEN/TC 156 "Ventilation for buildings".

EPBD EN Number	Recast EPBD EN Number	Title
EN 15251	EN 16798-1	Energy performance of buildings – Ventilation for buildings - Part 1: Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics (Module M1-6)
N/A	CEN/TR 16798-2	Energy performance of buildings – Ventilation for buildings - Part 2: Interpretation of the requirements in EN 16798-1 — Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics (Module M1-6)
EN 13779	EN 16798-3	Energy performance of buildings – Ventilation for buildings - Part 3: For non-residential buildings – Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)
N/A	CEN/TR 16798-4	Energy performance of buildings – Ventilation for buildings - Part 4: Interpretation of the requirements in EN 16798-3 — For non-residential buildings – Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

EN 15241	EN 16798-5-1	Energy performance of buildings — Ventilation for buildings – Part 5-1: Calculation methods for energy requirements of ventilation and air conditioning systems (Modules M5-6, M5-8, M6-5, M6-8, M7-5, M7-8) — Method 1: Distribution and generation
EN 15241	EN 16798-5-2	Energy performance of buildings – Ventilation for buildings - Part 5-2: Calculation methods for energy requirements of ventilation systems (Modules M5-6.2, M5-8.2) - Method 2: Distribution and generation
N/A	CEN/TR 16798-6	Energy performance of buildings - Ventilation for buildings – Part 6: Interpretation of the requirements in EN 16798-5-1 and EN 16798-5-2 — Calculation methods for energy requirements of ventilation and air conditioning systems (Modules M5-6, M5-8, M 6-5, M6-8 , M7-5, M7-8)
EN 15242	EN 16798-7	Energy performance of buildings - Ventilation for buildings - Part 7: Calculation methods for the determination of air flow rates in buildings including infiltration (Module M5-5)
N/A	CEN/TR 16798-8	Energy performance of buildings – Ventilation for buildings – Part 8: Interpretation of the requirements in EN 16798-7 — Calculation methods for the determination of air flow rates in buildings including infiltration – (Module M5-5)
EN 15243	EN 16798-9	Energy performance of buildings – Ventilation for buildings - Part 9: Calculation methods for energy requirements of cooling systems (Modules M4-1, M4-4, M4-9) - General
N/A	CEN/TR 16798-10	Energy performance of buildings – Ventilation for buildings – Part 10: Interpretation of the requirements in EN 16798-9 — Calculation methods for energy requirements of cooling systems (Module M4-1,M4-4, M4-9) – General
EN 15243	EN 16798-13	Energy performance of buildings – Ventilation for buildings - Part 13: - Calculation of cooling systems (Module M4-8) – Generation
EN 15243	CEN/TR 16798-14	Energy performance of buildings – Ventilation for buildings - Part 14: Interpretation of the requirements in EN 16798-13 — Calculation of cooling systems (Module M4-8) – Generation
N/A	EN 16798-15	Energy performance of buildings – Ventilation for buildings – Part 15: Calculation of cooling systems (Module M4-7) – Storage
N/A	CEN/TR 16798-16	Energy performance of buildings – Ventilation for buildings – Part 16: Interpretation of the requirements in EN 16798-15 — Calculation of cooling systems (Module M4-7) – Storage

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

EN 15239 and EN 15240	EN 16798-17	Energy performance of buildings – Ventilation for buildings - Part 17: Guidelines for inspection of ventilation and air-conditioning systems (Module M4-11, M5-11, M6-11, M7-11)
N/A	CEN/TR 16798-18	Energy performance of buildings – Ventilation for buildings – Part 18: Interpretation of the requirements in EN 16798-17 — Guidelines for inspection of ventilation and air-conditioning systems (Module M4-11, M5-11, M6-11, M7-11)

The revision concerns mainly the following aspects:

- New structure to clarify designing and calculation aspects;
- Update of filtration aspects;
- Update of heat recovery aspects and leakages in these systems;
- Clear coordination with prEN 16798-1:2015, outdoor air volume flows have been shifted to prEN 16798-1:2015;
- All indoor air quality aspects have been deleted, supply air quality have been introduced;
- Aspects of energy performance have been updated;
- Update of definitions of systems;
- Update of SPF definitions and links to EU 327/2014 regulation;
- The document was split in a normative part, containing all the normative aspects and a supplementary technical report containing additional information and informative annexes;
- The standard allows a normative national annex;
- The standard was updated to cover hourly/monthly/seasonal time-step.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called "set of EPB standards".

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this European Standard a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

The main target groups of this European Standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE So in this case:

- the regulators will specify the choices;
- the individual user will apply the standard to assess the energy performance of a building, and thereby use the choices made by the regulators.

Topics addressed in this European Standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B of this standard. Public regulation on the same topics can even, for certain applications, override the use of this European Standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

- national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case the national annex (e.g. NA) refers to this text;
- or, by default, the national standards body will consider the possibility to add or include a national annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 16798-4).

This European Standard also provides requirements especially for designers, installers, manufacturers, building owners and users, on ventilation, air-conditioning and room-conditioning systems in order to achieve a comfortable and healthy indoor environment in all seasons with acceptable installation and running costs. This European Standard focuses on the system-aspects for typical applications and covers the following:

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

- Aspects important to achieve and maintain a good energy performance in the systems without any negative impact on the quality of the indoor environment.
- Definitions of design and performances data.

This is a preview of "BS EN 16798-3:2017". [Click here to purchase the full version from the ANSI store.](#)

1 Scope

This European Standard applies to the design, energy performance of buildings and implementation of ventilation, air conditioning and room conditioning systems for non-residential buildings subject to human occupancy, excluding applications like industrial processes. It focuses on the definitions of the various parameters that are relevant for such systems.

The guidance for design given in this European Standard and accompanying CEN/TR 16798-4 are mainly applicable to mechanical supply and/or exhaust ventilation systems. Natural ventilation systems or natural parts of hybrid ventilation systems are not covered by this European Standard. Reference is made to the Technical Report for informative guidance on the design of such systems.

Applications for residential ventilation are not dealt with in this European Standard. Performance of ventilation systems in residential buildings are dealt with in EN 15665 and CEN/TR 14788.

The classification uses different categories. For some values, examples are given and, for requirements, typical ranges with default values are presented. The default values given in this European Standard are not normative as such, and should be used where no other values are specified. Classification should always be appropriate to the type of building and its intended use, and the basis of the classification should be explained if the examples given in the European Standard are not to be used.

NOTE 1 Different standards may express the categories for the same parameters in a different way, and also the category symbols may be different.

Table 1 shows the relative position of this European Standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 2 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 3 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.