

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

BS EN 1364-1:2015



BSI Standards Publication

Fire resistance tests for non-loadbearing elements

Part 1: Walls

bsi.

...making excellence a habit.™

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

This British Standard is the UK implementation of EN 1364-1:2015. It supersedes BS EN 1364-1:1999 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee FSH/22/-/7, Non loadbearing separating elements.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015. Published by BSI Standards Limited 2015

ISBN 978 0 580 86704 0

ICS 13.220.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2015.

Amendments issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

July 2015

ICS 13.220.50; 91.060.10

Supersedes EN 1364-1:1999

English Version

Fire resistance tests for non-loadbearing elements - Part 1: Walls

Essais de résistance au feu des éléments non porteurs -
Partie 1 : Murs

Feuerwiderstandsprüfungen für nichttragende Bauteile -
Teil 1: Wände

This European Standard was approved by CEN on 30 April 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

European foreword.....	5
Introduction	6
1 Scope	7
2 Normative references.....	7
3 Terms and definitions.....	7
4 Test equipment	9
5 Test conditions.....	9
6 Test specimen	9
6.1 Size	9
6.2 Number.....	9
6.3 Design	9
6.3.1 General.....	9
6.3.2 Vertical joints	10
6.3.3 Horizontal joints.....	10
6.3.4 Restraint.....	10
6.4 Construction	11
6.5 Verification.....	11
7 Installation of test specimen.....	11
7.1 General.....	11
7.2 Supporting construction	11
8 Conditioning	11
9 Application of instrumentation.....	12
9.1 Thermocouples.....	12
9.1.1 Furnace thermocouples (plate thermometers).....	12
9.1.2 Unexposed face thermocouples.....	12
9.2 Pressure	13
9.3 Deflection	13
9.4 Radiation	13
9.5 Impact.....	13
10 Test procedure	13
11 Performance criteria	13
12 Test report.....	13
13 Field of direct application of test results	14
13.1 General.....	14
13.2 Extension of width	14
13.3 Extension of height.....	14
13.4 Supporting constructions.....	15
13.4.1 Standard supporting constructions.....	15

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

Annex A (normative) Specific requirements for testing glazed elements of non-loadbearing walls incorporating glazing	36
A.1 General	36
A.2 Test specimen design.....	36
A.3 Test specimen instrumentation.....	37
A.3.1 General.....	37
A.3.2 Average temperature rise.....	37
A.3.2.1 Fully glazed test specimen	37
A.3.2.2 Partly glazed test specimen.....	37
A.3.3 Maximum temperature rise	37
A.3.4 Radiation measurement.....	38
A.3.5 Deflection measurement	38
A.4 Field of direct application of test results	38
A.4.1 General.....	38
A.4.2 Field of direct application rules not requiring overrun time.....	38
A.4.2.1 Glazed element	38
A.4.2.1.1 Installation angle.....	38
A.4.2.1.2 Height of the glazed element	39
A.4.2.1.3 Width of the glazed element.....	39
A.4.2.2 Glazing system (see Figure 16).....	39
A.4.2.2.1 Linear dimensions.....	39
A.4.2.2.2 Aspect ratio.....	39
A.4.2.2.3 Glazing beads.....	40
A.4.2.3 Framing system (see Figure 16).....	40
A.4.2.4 Supporting constructions	40
A.4.2.4.1 General.....	40
A.4.2.4.2 Standard supporting constructions.....	40
A.4.2.4.3 Non-standard supporting construction	41
A.4.3 Field of direct application rules requiring overrun time	41
A.4.3.1 General	41
A.4.3.2 Dimensions of the glazed element.....	41
A.4.3.2.1 Height	41
A.4.3.2.2 Width	41
A.4.3.3 Dimensions and area of individual rectangular glass panes	42
A.4.3.4 Aspect ratio	42
A.4.3.5 Area of individual circular, triangular and four side non-rectangular glass panes	42
Annex B (normative) Specific requirements for testing non-loadbearing external and internal walls designed to span horizontally between two independently proven fire resisting vertical structural elements.....	43

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

B.2	Test specimen	43
B.2.1	Size	43
B.2.2	Number.....	43
B.2.3	Design	43
B.2.4	Boundary and Restraint conditions	43
B.3	Test specimen instrumentation.....	44
B.4	Test procedure	44
B.5	Performance criteria	44
B.6	Field of direct application of test results	44
B.6.1	General.....	44
B.6.2	Supporting constructions.....	45
B.6.3	Extension of width.....	45
B.6.4	Extension of height	45
	Bibliography	46

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

This document (EN 1364-1:2015) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2016, and conflicting national standards shall be withdrawn at the latest by January 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1364-1:1999.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

The main changes with respect to the previous edition are listed below:

- a) locations of thermocouples are modified in line with the definitions in EN 1363-1;
- b) additional deflections measurements for larger constructions;
- c) additional thermocouples on glazed constructions;
- d) additional rules in the field of direct application for glazed constructions (Annex A);
- e) rules for testing non-loadbearing external and internal walls designed to span horizontally (Annex B).

EN 1364 'Fire resistance tests for non-loadbearing elements' consists of the following:

Part 1: Walls;

Part 2: Ceilings;

Part 3: Curtain walling - Full configuration (complete assembly);

Part 4: Curtain walling - Part configuration;

Part 5: Air transfer grilles.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

The purpose of this test is to measure the ability of a representative specimen of a non-loadbearing wall to resist the spread of fire from one side to another.

It is applicable to non-loadbearing walls, with and without glazing, non-loadbearing walls consisting almost wholly of glazing and other non-loadbearing internal and external non-loadbearing walls.

It is not applicable to curtain walls (external non-loadbearing walls suspended in front of the floor slab), unless explicitly permitted under EN 1364-3 or EN 1364-4 which should contain details of the methodology to be used.

For external fire exposure to a non-loadbearing external wall, the external fire exposure curve given in EN 1363-2 is used.

CAUTION — The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

This is a preview of "BS EN 1364-1:2015". [Click here to purchase the full version from the ANSI store.](#)

This European standard specifies a method for determining the fire resistance of non-loadbearing walls.

This European Standard is used in conjunction with EN 1363-1.

It is applicable to internal non-loadbearing walls (partitions), with and without glazing, non-loadbearing walls consisting almost wholly of glazing (glazed non-loadbearing walls) and other non-loadbearing internal and external non-loadbearing walls with and without glazing.

The fire resistance of external non-loadbearing walls can be determined under internal or external exposure conditions. In the latter case the external fire exposure curve given in EN 1363-2 is used.

It is not applicable to:

- a) curtain walls (external non-loadbearing walls suspended in front of the floor slab), unless explicitly permitted under EN 1364-3 or EN 1364-4 which contain details of the methodology to be used.
- b) non-loadbearing walls containing door assemblies that are tested according to EN 1634-1.

Specific requirements for testing glazed elements or non-loadbearing walls incorporating glazing are given in Annex A.

Specific requirements relating to the testing of non-loadbearing external and internal walls designed to span horizontally between two independently proven fire resisting vertical structural elements are given in Annex B.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1 and EN ISO 13943, together with the following, apply:

3.1

non-loadbearing wall (partition)

wall designed not to be subject to any load other than its self-weight

3.2

internal non-loadbearing wall (partition)

wall, with or without glazing, which provides fire separation

Note 1 to entry It may be exposed separately to a fire from either side.

3.3

external non-loadbearing wall

wall forming the external envelope of a building

Note 1 to entry It may be exposed separately to an internal or an external fire.