



## BSI Standards Publication

# Extended application of results from fire resistance tests for service installations

---

## Part 1: Ducts

This is a preview of "BS EN 15882-1:2011+A...". [Click here to purchase the full version from the ANSI store.](#)

## National foreword

This British Standard is the UK implementation of EN 15882-1:2011+A1:2017. It supersedes BS EN 15882-1:2011, which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to CEN text carry the number of the CEN amendment. For example, text altered by CEN amendment A1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee FSH/22/-/9, Fire resistance tests for ducts, including smoke extract ducts.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2018  
Published by BSI Standards Limited 2018

ISBN 978 0 580 90063 1

ICS 91.140.30; 13.220.50

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 January 2012.

### Amendments/corrigenda issued since publication

| Date             | Text affected                           |
|------------------|---|
| 30 November 2018 | Implementation of CEN amendment A1:2017 |

This is a preview of "BS EN 15882-1:2011+A...". Click here to purchase the full version from the ANSI store.

## EUROPÄISCHE NORM

November 2017

ICS 13.220.50; 91.140.30

Supersedes EN 15882-1:2011

English Version

## Extended application of results from fire resistance tests for service installations - Part 1: Ducts

Application étendue des résultats des essais de  
résistance au feu des installations de service - Partie 1:  
Conduits

Erweiterter Anwendungsbereich der Ergebnisse aus  
Feuerwiderstandsprüfungen für Installationen - Teil 1:  
Leitungen

This European Standard was approved by CEN on 22 October 2011 and includes Amendment 1 approved by CEN on 11 September 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

| <b>Contents</b>  | <b>Page</b> |
|--|-------------|
| <b>European foreword.....</b>                                      | <b>3</b>    |
| <b>Introduction .....</b>  | <b>4</b>    |
| <b>1 Scope .....</b>   | <b>5</b>    |
| <b>2 Normative references .....</b>                                | <b>5</b>    |
| <b>3 Terms and definitions .....</b>                               | <b>5</b>    |
| <b>4 Critical parameters and factors .....</b>                     | <b>6</b>    |
| 4.1 General.....   | 6           |
| 4.2 Common thermal and mechanical parameters and factors.....      | 6           |
| 4.3 Common constructional parameters and factors.....              | 7           |
| 4.4 Specific constructional parameters and factors .....           | 8           |
| <b>5 Methodology .....</b>   | <b>9</b>    |
| <b>6 Requirements, performance criteria and influences.....</b>    | <b>15</b>   |
| 6.1 Requirements and performance criteria.....                     | 15          |
| 6.2 Influences.....  | 15          |
| <b>7 Assessment scheme .....</b>                                   | <b>16</b>   |
| 7.1 General.....   | 16          |
| 7.2 Requirement for additional tests .....                         | 16          |
| <b>8 Test arrangements and criteria for additional tests .....</b> | <b>16</b>   |
| 8.1 Maximum dimensions of ducts which can be classified.....       | 16          |
| 8.2 Closed ducts with pressure differential .....                  | 17          |
| 8.3 Open horizontal duct B.....                                    | 17          |
| 8.4 Open vertical duct B .....                                     | 17          |
| 8.5 Additional rules .....   | 17          |
| <b>9 Evaluation of fire resistance.....</b>                        | <b>21</b>   |
| 9.1 Application of the basic and additional test results .....     | 21          |
| 9.2 Suspension devices.....  | 21          |
| 9.3 Inspection openings/access panels.....                         | 22          |
| 9.4 Components within ducts.....                                   | 23          |
| 9.5 Surface finishes.....  | 23          |
| 9.6 Change in wall or floor thickness .....                        | 23          |
| <b>10 Extended application report .....</b>                        | <b>23</b>   |
| <b>Bibliography .....</b>  | <b>29</b>   |

This is a preview of "BS EN 15882-1:2011+A...". [Click here to purchase the full version from the ANSI store.](#)

## European foreword

This document (EN 15882-1:2011+A1:2017) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This document includes Amendment 1 approved by CEN on 1 May 2017.

This document supersedes A1 EN 15882-1:2011 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2018, and conflicting national standards shall be withdrawn at the latest by May 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This European Standard has the general title *Extended application of results from fire resistance tests for service installations* and consists of the following parts:

- *Part 1: Ducts;*
- *Part 2: Dampers;*
- *Part 3: Penetration seals;*
- *Part 4: Linear joint seals.*

The Enquiry phase of this project (00127162) took place under the reference prEN 15080-10.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

There are a number of practical limitations on the size and design of elements that can be tested by the standard methods of fire resistance test. When these elements are larger, or are of a modified design, there is a necessity to be able to confirm their performance, i.e. whether the classification(s) is (are) given in the classification report in relation to the relevant criteria identified in the Interpretative Document are maintained, without the ability of being able to test them. To achieve this, extended application documents for the various elements are under development.

It is not allowed to change any detail of the duct construction. If this is done outside the DiAP<sup>1)</sup> and EXAP<sup>2)</sup>, the duct has another design and cannot be classified in accordance with EN 13501-3 without further appropriate testing.

Before there can be any consideration for extended application the duct shall be tested in accordance with EN 1366-1 to achieve a test result which could generate a classification in accordance with EN 13501-3 at least equal to the classification subsequently required from extended application considerations.

The extended application report should be based on the evaluation of one or more fire resistance test reports on the same proprietary construction of duct.

A review of the duct construction parameters may indicate that one or more criteria (integrity, insulation, leakage) may be improved by a particular parameter variation. In the case of ducts, this should never lead to an increased classification period for any specific parameter beyond that achieved during any one test.

---

<sup>1)</sup> DiAP = Direct field of application.

<sup>2)</sup> EXAP = Extended field of application.

This is a preview of "BS EN 15882-1:2011+A...". [Click here to purchase the full version from the ANSI store.](#)

## 1 Scope

This European Standard identifies parameters that affect the fire resistance of ducts for ventilation purposes. It also identifies the factors that need to be considered when deciding whether, or by how much a parameter can be extended either positively or negatively when contemplating the fire resistance on an untested variation in the construction.



This European Standard, where applicable, gives guidance on additional tests that are needed to extend the field of application.

The European Standard gives the principles behind how a conclusion on the influence of specific parameters/constructional details relating to the relevant criteria (E, I, S) can be achieved.

This European Standard only applies to ducts tested to EN 1366-1. Duct sections for use other than in fire resisting heating, ventilation and air conditioning (HVAC) systems are not covered by this European Standard. It does not cover ducts used for smoke control which are tested in accordance with EN 1366-8 or EN 1366-9.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1 :2012 , *Fire resistance tests — Part 1: General requirements*

EN 1366-1:1999, *Fire resistance tests for service installations — Part 1: Ducts*

EN 13501-3, *Fire classification of construction products and building elements — Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: Fire resisting ducts and fire dampers*

EN ISO 898-1, Mechanical properties of fasteners made of carbon steel and alloy steel — Part 1: Bolts, screws and studs with specific property classes — Coarse thread and fine pitch thread (*ISO 898-1:2009*)

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1 and EN 1366-1 and the following apply.

### 3.1

#### **self-supporting duct**

duct constructed from fire protective boards to provide fire resistance without using a conventional steel duct

### 3.2

#### **fire protected steel duct**

steel duct with or without external insulation or coating to provide integrity or integrity and insulation in case of fire

### 3.3

#### **duct system**

complete system, consisting of the duct sections, duct joints, suspensions and penetration seals