

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

BS EN 50341-2-19:2015



BSI Standards Publication

Overhead electrical lines exceeding AC 1 kV

Part 2-19: National Normative Aspects (NNA)
for CZECH REPUBLIC

bsi.

...making excellence a habit.TM

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

This British Standard is the UK implementation of EN 50341-2-19:2015.

This standard, together with the following list of National Normative Aspect standards, supersedes BS EN 50423-3:2005 and BS EN 50341-3:2001:

Country Code	Origin	Ref
AT	Austrian National Committee	BS EN 50341-2-1
BE	Belgian National Committee	BS EN 50341-2-2
CH	Swiss National Committee	BS EN 50341-2-3
DE	German National Committee	BS EN 50341-2-4
DK	Danish National Committee	BS EN 50341-2-5
ES	Spanish National Committee	BS EN 50341-2-6
FI	Finnish National Committee	BS EN 50341-2-7
FR	French National Committee	BS EN 50341-2-8
GB	British National Committee	BS EN 50341-2-9
GR	Greek National Committee	BS EN 50341-2-10
IE	Irish National Committee	BS EN 50341-2-11
IS	Iceland National Committee	BS EN 50341-2-12
IT	Italian National Committee	BS EN 50341-2-13
LU	Luxemburg National Committee	No NNA available
NL	Nederland's National Committee	BS EN 50341-2-15
NO	Norwegian National Committee	BS EN 50341-2-16
PT	Portuguese National Committee	BS EN 50341-2-17
SE	Swedish National Committee	BS EN 50341-2-18
CZ	Czech National Committee	BS EN 50341-2-19:2015
EE	Estonian National Committee	BS EN 50341-2-20:2015
SI	Slovak National Committee	BS EN 50341-2-21
PL	Polish National Committee	BS EN 50341-2-22

BS EN 50423-3:2005 and BS EN 50341-3:2001 will be withdrawn upon publication of the rest of the series.

The UK participation in its preparation was entrusted to Technical Committee PEL/11, Overhead Lines.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

© The British Standards Institution 2015.

Published by BSI Standards Limited 2015

ISBN 978 0 580 90341 0

ICS 29.240.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2015.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

EUROPÄISCHE NORM

April 2015

ICS 29.240.20

English Version

**Overhead electrical lines exceeding AC 1 kV - Part 2-19:
National Normative Aspects (NNA) for CZECH REPUBLIC
(based on EN 50341-1:2012)**

This European Standard was approved by CENELEC on 2015-04-07.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

Contents

	Page
1 Scope	7
1.1 General	7
1.2 Field of application	7
2 Normative references, definitions and symbols	7
2.1 Normative references	7
2.2 Definitions	10
2.3 Symbols	10
3 Basis of design	12
3.2.2 Reliability requirements	12
3.2.5 Strength coordination	12
3.2.6 Additional considerations	12
4 Actions on lines	13
4.3 Wind loads	13
4.3.1 Field of application and basic wind velocity	13
4.3.2 Mean wind velocity	13
4.3.3 Mean wind pressure	13
4.4 Wind forces on overhead line components	13
4.4.1 Wind forces on conductors	13
4.4.2 Wind forces on insulator sets	14
4.4.3 Wind forces on lattice towers	15
4.4.4 Wind forces on poles	15
4.5 Ice loads	15
4.5.1 General	15
4.6 Combined wind and ice loads	16
4.6.1 Combined probabilities	16
4.6.2 Drag factors and ice densities	17
4.6.5 Wind forces on support for ice covered conductors	17
4.6.6 Combination of wind velocities and ice loads	17
4.7 Temperature effects	18
4.8 Security loads	18
4.8.1 General	18
4.8.2 Torsional loads	18
4.8.3 Longitudinal loads	19
4.9 Safety loads	19
4.9.1 Construction and maintenance loads	19
4.9.2 Loads related to the weight of linesmen	19
4.10 Forces due to short-circuit currents	19
4.11 Other special forces	20
4.11.1 Avalanches, creeping snow	20
4.11.2 Earthquakes	20
4.12 Load cases	20
4.12.1 General	20
4.12.2 Standard load cases	20
4.13 Partial factors for actions	22
5 Electrical requirements	25
5.3 Insulation coordination	25
5.4 Classification of voltages and overvoltages	25
5.4.2 Representative power frequency voltages	25
5.5 Minimum air clearance distances to avoid flashover	26

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

5.5.3	Empirical method based on European experience.....	26
5.6	Load cases for calculation of clearances	27
5.6.2	Maximum conductor temperature.....	27
5.6.3	Wind loads for determination of electric clearances.....	27
5.6.4	Ice loads for determination of electric clearances	28
5.6.5	Combined wind and ice loads.....	29
5.7	Coordination of conductor positions and electrical stresses	30
5.8	Internal clearances within the span and at the top of support.....	30
5.9	External clearances	33
5.9.1	General	33
5.9.2	External clearances to ground in areas remote from buildings, roads, etc.	34
5.9.3	External clearances to residential and other buildings.....	34
5.9.4	External clearances to crossing traffic routes.....	36
5.9.5	External clearances to adjacent traffic routes	38
5.9.6	External clearances to other power lines or overhead telecommunication lines	38
5.10	Corona effect	40
5.10.1	Radio noise.....	40
5.11	Electric and magnetic fields.....	40
5.11.1	Electric and magnetic fields under a line	40
5.11.2	Electric and magnetic field induction	40
5.11.3	Interference with telecommunication circuits.....	40
6	Earthing systems.....	41
6.1	Introduction	41
6.1.2	Requirements for dimensioning of earthing systems	41
6.1.3	Earthing measures against lightning effects.....	41
6.1.4	Transferred potentials.....	42
6.2	Ratings with regard to corrosion and mechanical strength	43
6.2.1	Earth electrodes.....	43
6.2.2	Earthing and bonding conductors.....	43
6.4	Dimensioning with regard to human safety	43
6.4.1	Permissible values for touch voltages	43
6.4.3	Basic design of earthing systems with regard to permissible touch voltage	43
7	Supports	44
7.3	Lattice steel towers	44
7.3.6	Ultimate limit states.....	44
7.3.7	Serviceability limit states	44
7.3.8	Resistance of connections.....	44
7.3.9	Design assisted by testing	44
7.4	Steel poles	45
7.4.6	Ultimate limit states (EN 1993-1-1:2005 – Chapter 6).....	45
7.4.7	Serviceability limit states (EN 1993-1-1:2005 – Chapter 7)	45
7.4.8	Resistance of connections.....	45
7.4.9	Design assisted by testing	45
7.5	Wood poles	45
7.5.5	Ultimate limit states.....	45
7.5.6	Serviceability limit states	45
7.5.7	Resistance of connections.....	45
7.5.8	Design assisted by testing	46
7.6	Concrete poles	46
7.6.4	Ultimate limit states.....	46
7.6.5	Serviceability limit states	46

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

7.7 Guyed structures	40
7.7.4 Ultimate limit states.....	46
7.7.5 Serviceability limit states.....	47
7.9 Corrosion protection and finishes	47
7.9.1 General	47
7.10 Maintenance facilities	47
7.10.1 Climbing	47
7.10.2 Maintainability	47
7.10.3 Safety requirements.....	47
8 Foundations.....	47
8.1 Introduction	47
8.2 Basis of geotechnical design (EN 1997-1:2004 – Section 2)	47
8.2.2 Geotechnical design by calculation	47
8.3 Soil investigation and geotechnical data (EN 1997-1:2004 – Section 3)	47
9 Conductors and earth-wires	48
9.1 Introduction	48
9.2 Aluminium based conductors.....	48
9.2.2 Electrical requirements	48
9.2.3 Conductor service temperatures and grease characteristics	49
9.2.4 Mechanical requirements.....	49
9.2.5 Corrosion protection	49
9.2.6 Test requirements.....	49
9.3 Steel based conductors	50
9.3.1 Characteristics and dimensions.....	50
9.3.3 Conductor service temperatures and grease characteristics	50
9.3.4 Mechanical requirements.....	50
9.3.5 Corrosion protection	51
9.3.6 Test requirements.....	51
9.4 Copper base conductors.....	51
9.5 Conductors and ground wires containing optical fibre telecommunication circuits	51
9.5.1 Characteristics and dimensions.....	51
9.5.2 Electrical requirements	51
9.5.3 Conductor service temperatures.....	51
9.5.4 Mechanical requirements.....	51
9.6 General requirements	52
9.6.2 Partial factor for conductors.....	52
9.6.3 Minimum cross-sections	52
9.6.4 Sag – tension calculations	52
10 Insulators	52
10.1 Introduction	52
10.4 Pollution performance requirements.....	52
10.5 Power arc requirements.....	53
10.7 Mechanical requirements	53
10.10 Characteristics and dimensions of insulators	53
10.11 Type test requirements	54
10.11.1 Standard type tests.....	54
10.11.2 Optional type tests	54
11 Hardware	54
11.1 Introduction	54
11.6 Mechanical requirements.....	54
12 Quality assurance, checks and taking-over	55

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

Installation and measurements of earthing systems	55
H.2 Basis for the verification	55
H.2.2 Resistance to earth.....	55
H.3 Installation of earth electrodes and earthing conductors.....	55
H.3.1 Installation of earth conductors.....	55
H.4 Measurements for and on earthing systems	55
H.4.4 Determination of the earth potential rise	55
H.4.5 Reduction factor related to earth wires of overhead lines	56
Annex M/CZ (informative).....	56
Geotechnical and structural design of foundations	56
M.1 Typical values of the geotechnical parameters of soils and rocks	56
M.1.3 Symbols, definitions and units of some ground parameters	56
M.3 Sample semi-empirical models for resistance estimation	62
M.3.1 Geotechnical design by calculation	62
Annex S/CZ (informative)	63
Map of icing zones in the Czech Republic	63

This is a preview of "BS EN 50341-2-19:201...". Click here to purchase the full version from the ANSI store.

1. The Czech National Committee (NC) is identified by the following address :
CZECH OFFICE FOR STANDARDS, METROLOGY AND TESTING email: unmz@unmz.cz
Gorazdova 24, P.O.Box 49 tel: ++420 224 907 111
128 01 PRAHA 2 fax: ++420 221 802 301
Czech Republic
2. The Czech National Committee has prepared this Part 2-19 (EN 50341-2-19) listing the Czech National Normative Aspects (NNA) under its sole responsibility and duly passed this document through the CENELEC and CLC/TC11 procedures.

NOTE The Czech National Committee also takes sole responsibility for the technically correct co-ordination of this EN 50341-2-19 with EN 50341-1. It has performed the necessary checks in the frame of quality assurance/control. However, it is noted that this quality assurance/control has been made in the framework of the general responsibility of The Czech National Committee under the national laws/regulations.

3. This EN 50341-2-19 is normative in the Czech Republic and informative for other countries.
4. This EN 50341-2-19 has to be read in conjunction with EN 50341-1, hereinafter referred as Part 1. All clause numbers used in Part 2-19 correspond to those of Part 1. Specific subclauses which are prefixed CZ are to be read as amendments to the relevant text in Part 1. Any necessary clarification regarding the application of Part 2-19 in conjunction with Part 1 shall be referred to the Czech Office for Standards, Metrology and Testing that will, in co-operation with CLC/TC11, clarify the requirements. When no reference is made in Part 2-19 to a specific subclause, then Part 1 applies.
5. In the case of "boxed values" defined in Part 1, amended values (if any) which are defined in Part 2-19 shall be taken into account in the Czech Republic.

However, any "boxed values" whether in Part 1 or Part 2-19, shall not be amended in direction of greater risk in the Project Specification.

6. The national Czech standards/regulations, regarding overhead lines exceeding 1 kV AC, are listed in 2.1/CZ.2 and 2.1/CZ.3.

NOTE All national standards referred to in this Part 2-19 will be replaced by the relevant European Standards as soon as they become available and are declared by the Czech Office for Standards, Metrology and Testing to be applicable and thus reported to the secretary of CLC/TC11.

This is a preview of "BS EN 50341-2-19:201...". Click [here](#) to purchase the full version from the ANSI store.

1.1 General

(ncpt) CZ.1 New overhead line

The new overhead line is considered a brand new electric overhead line with nominal voltage exceeding 1 kV AC, between the points A and B.

The new branch line of the existing overhead line shall be considered a new overhead line except for a junction support for which the specific requirements shall be defined in the Project Specification.

The extent of application of this standard in respect of reconstruction, relaying and extension of existing overhead lines shall be determined in the Project Specification. Simultaneously, the Project Specification shall determine, which of the previous national standards shall be used and to what extent they shall be used for the project in question.

1.2 Field of application

(ncpt) CZ.1 Field of application

The requirements of this standard shall be adopted, where applicable (e.g. requirements on loads, external clearances, etc.), for telecommunication cables as well.

In case of overhead line under the design stage, parties concerned shall agree the extent of the application of this standard.

Overhead line under construction may be completed according to standards valid during the design stage of the line. The parties concerned shall agree any possible application of certain clauses of this standard.

(ncpt) CZ.2 Installation of telecommunication equipment on supports

Provisions of this standard also apply to the telecommunication equipment and devices (aerials, dish antennas, etc.) which are installed on individual supports of overhead power lines, especially in terms of wind and ice loads on such installed equipment. Design and installation has to respect requirements of the utility operating the line in question. The design of such telecommunication equipment has to incorporate such technical solutions and such precautions, which shall allow safe access and maintenance of both a power line and telecommunication equipment, and which shall provide protection of persons performing repairs or maintenance of the power line and/or telecommunication equipment against electric shock and protection of telecommunication equipment and attached installations against the influence of the power line (short-circuits, switching and lightning overvoltages etc.).

2 Normative references, definitions and symbols

2.1 Normative references

(ncpt) CZ.1 General

National laws, Government regulations and other binding regulations are included in following 2.1/CZ.2. International and national standards quoted in EN 50341-2-19 and not included in 2.1 EN 50341-1 are included in 2.1/CZ.3.

The set of standards included in 2.1 EN 50341-1 under a common title of Eurocodes is valid in the Czech Republic including the Czech National Application documents related to relevant standards, unless EN 50341-1 and/or these Czech National Normative Aspects (EN 50341-2-19) specify otherwise.

NOTE Some EN, IEC, ISO and CISPR International Standards and publications implemented as Czech National Standards – ČSN EN, ČSN IEC, ČSN ISO and ČSN CISPR – include informative notes and informative annexes useful in the Czech Republic.