

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)



BSI Standards Publication

Energy Performance of Buildings — Controls for heating systems

Part 3: Control equipment for electrical heating systems — Modules M3-5,6,7,8

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

National foreword

This British Standard is the UK implementation of EN 12098-3:2017. It supersedes BS EN 12098-3:2013, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee RHE/16, Performance requirements for control systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017
Published by BSI Standards Limited 2017

ISBN 978 0 580 91970 1

ICS 97.120; 97.100.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 June 2017.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

May 2017

ICS 97.100.10; 97.120

Supersedes EN 12098-3:2013

English Version

Energy Performance of Buildings - Controls for heating systems - Part 3: Control equipment for electrical heating systems - Modules M3-5,6,7,8

Performance énergétique des bâtiments - Régulation pour les systèmes de chauffage - Partie 3 : Équipement de régulation pour les systèmes de chauffage électrique - Modules M3-5, 6, 7, 8

Engergieeffizienz von Gebäuden - Mess-, Steuer- und Regleinrichtungen für Heizungen - Teil 3: Regleinrichtungen für Elektroheizungen - Module M3-5, 6, 7, 8

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

Contents		Page
European foreword.....		4
Introduction		5
1	Scope	6
2	Normative references	8
3	Terms and definitions	8
4	Symbols, subscripts and abbreviations.....	16
4.1	Symbols.....	16
4.2	Subscripts.....	16
5	Functionality.....	16
5.1	Functional objective.....	16
5.2	Control equipment functionality.....	17
6	Requirements	18
6.1	Data protection	18
6.2	Characteristic heating curve	18
6.3	Input signal – Sensors.....	18
6.4	Controller operation modes.....	18
6.4.1	General.....	18
6.4.2	Comfort operation mode	19
6.4.3	Economy operation mode	19
6.4.4	Building protection operation mode	19
6.4.5	Automatic operation mode.....	19
6.5	Frost protection	19
6.6	Additional functions.....	19
6.6.1	General.....	19
6.6.2	Summer/winter switch function	19
6.6.3	Set back function	19
6.6.4	Optimum start function	20
6.6.5	Optimum stop function	20
6.7	Switching times.....	20
6.8	Override mode	20
6.9	Parameter settings	21
6.10	Factory settings / default values	21
6.10.1	Characteristic heating curve	21
6.10.2	Switching times / operating condition	21
6.11	Switching relays.....	21
6.12	Electrical requirements.....	21
6.12.1	Electrical connections	21
6.12.2	Supply voltage	21
6.12.3	Electrical safety.....	21
6.12.4	Electromagnetic compatibility.....	22
6.13	Degree of protection	22
6.14	Environmentally induced stress due to temperature.....	22
6.15	Materials.....	22
6.16	Use of graphical symbols	22

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

7	Test methods	22
7.1	Data Protection	22
7.2	Controller operation modes	22
7.3	Controller characteristic heating curve	22
7.4	Frost protection	25
7.5	Switching times	25
7.6	Manual override mode	25
7.7	Optimum start-stop function	25
7.7.1	General	25
7.7.2	Test conditions	26
7.7.3	Test run	27
7.7.4	Test results start optimization	27
7.7.5	Test results stop optimization	29
7.8	Set back	29
7.9	Parameter settings	29
7.10	Factory settings	29
7.11	Switching relays	30
7.12	Electrical test	30
7.13	Degrees of protection	30
7.14	Environmental individual stress due to temperature	30
8	Marking	30
9	Documentation	30
9.1	Technical documents	30
9.2	Technical Specifications	30
9.2.1	Controller	30
9.2.2	Output signals	31
9.2.3	Input signals (sensors)	31
9.3	Instruction installation	31
9.4	User guideline	31
	Bibliography	32

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

European foreword

This document (EN 12098-3:2017) has been prepared by Technical Committee CEN/TC 247 "Building Automation, Controls and Building Management", the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2017, and conflicting national standards shall be withdrawn at the latest by November 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12098-3:2013.

This document has been prepared under a mandate [12] given to CEN by the European Commission and the European Free Trade Association.

This document is part of the set of standards on the energy performance of buildings (the set of EPB standards).

In case this standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications, in particular for the application within the context of EU Directives transposed into national legal requirements.

Further target groups are users of the voluntary common European Union certification scheme for the energy performance of non-residential buildings (EPBD art.11.9) and any other regional (e.g. Pan European) parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

Introduction

This standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called "EPB set of standards".

As part of the "EPB set of standards" it complies with the requirements for the set of basic EPB documents EN ISO 52000-1 (see Normative references), CEN/TS 16628 and CEN/TS 16629 (see bibliography [2] and [3]) developed under a mandate given to CEN by the European Commission and the European Free Trade Association (Mandate M/480).

The standards issued by TC 247 for M/480 belong to the EPB set of standards and are in line with the over-arching standard (EN ISO 52000-1) and drafted in accordance with the basic principles and detailed technical rules developed in the Phase I of the mandate.

Also these standards are clearly identified in the modular structure developed to ensure a transparent and coherent EPB standard set. BAC (Building Automation and Control) is identified in the modular structure as Technical Building System M10. However, the standards of TC 247 deal with control accuracy, control functions and control strategies using standards communications protocol (these last standards do not belong to the EPB standards set).

To avoid a duplication of calculation due to the BAC (avoid double impact), no calculation are done in BAC EPB standard set, but in each underlying standard of EPB set of standards (from M1 to M9 in the Modular Structure), an IDENTIFIER developed and present in the M10 covered by EN 15232-1 is used where appropriate. These way of interaction is described in detailed in the Technical Report (CEN ISO/TR 52000-2) accompanying the over-arching standard. As consequence, the Annex A and Annex B concept as EXCEL sheet with the calculation formulas used in the EPB standards are not applicable for the standards issued by TC 247 for M/480.

The main target groups of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in the Technical Report accompanying this standard (CEN/TR 12098-7:2015 [5]).

This third edition cancels and replaces the second edition EN 12098-3:2013.

The most important changes are:

- respect the presentation of this project in the frame EPB in accordance with the drafting rules;
- Clause 6.7 Switching times and Table 2 introducing networked clocks improvements in line with EN 12098-5 modifications.

This is a preview of "BS EN 12098-3:2017". [Click here to purchase the full version from the ANSI store.](#)

1 Scope

This European Standard applies to electronic control equipment for heating systems with direct electrical emission, which have an integrated outside compensated function and or optimum start/stop function.

This control equipment controls the distribution and/or the generation of heat in relation to the outside temperature and time and other reference variables.

This European Standard also covers controllers that contain an integrated optimum start or an optimum start-stop control function. The controller modulates heating or control modes of electronic individual zone or emitter control equipment.

Safety requirements on heating systems remain unaffected by this standard. The dynamic behaviour of the local thermostats, sensors, or actuators is not covered in this standard.

A multi-distribution and/or multi-generation system needs a coordinated solution to prevent undesired interaction and is not part of this standard.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In CEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively.