

This is a preview of "BS EN 50336:2021". [Click here to purchase the full version from the ANSI store.](#)



BSI Standards Publication

Bushings for transformers and reactor cable boxes not exceeding 36 kV

This is a preview of "BS EN 50336:2021". [Click here to purchase the full version from the ANSI store.](#)

National foreword

This British Standard is the UK implementation of EN 50336:2021. It supersedes BS EN 50336:2002, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/36, Insulators for power systems.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 04049 4

ICS 29.080.20; 29.180

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 May 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN 50336:2021". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

April 2021

ICS 29.080.20; 29.180

Supersedes EN 50336:2002 and all of its amendments
and corrigenda (if any)

English Version

**Bushings for transformers and reactor cable boxes not
exceeding 36 kV**Traversées pour boîtes à câbles de transformateurs et
bobines d'inductance ne dépassant pas 36 kVDurchführungen für Kabelanschlusskästen von
Transformatoren und Drosselspulen bis 36 kV

This European Standard was approved by CENELEC on 2021-03-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

This is a preview of "BS EN 50336:2021". [Click here to purchase the full version from the ANSI store.](#)

Contents	Page
European foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Requirements	5
4.1 General requirements.....	5
4.2 Ratings.....	5
4.2.1 Standard values of rated voltage for ceramic insulators (U_r).....	5
4.2.2 Standard values of rated voltage for resin-insulated bushings (U_r).....	5
4.2.3 Standard values of rated current (I_r)	5
4.3 Ceramic bushings.....	5
4.3.1 General requirements.....	5
4.3.2 Clamping arrangements.....	6
4.3.3 Terminals	6
4.4 Resin-insulated bushings	7
4.4.1 General requirements.....	7
4.4.2 Type test (temperature cycle).....	7
4.4.3 Routine tests	7
5 Ceramic busing dimensions.....	8
5.1 Ceramic insulator	8
5.2 Clamping arrangement for ceramic insulators.....	10
5.3 Bushing end terminal arrangement	11
6 Resin bushing dimensions	15
Bibliography	17

This is a preview of "BS EN 50336:2021". [Click here to purchase the full version from the ANSI store.](#)

European foreword

This document (EN 50336:2021) has been prepared by CLC/TC 36A "Insulated bushings".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-03-30
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2024-03-30

This document supersedes EN 50336:2002 and all of its amendments and corrigenda (if any).

EN 50336:2021 includes the following significant technical changes with respect to EN 50336:2002:

- 3.1 – Minimum IP rating removed from air filled cable boxes.
- 3.4 and 3.5 – EN 60137 added as a reference specification.
- 4.1 – Clarification that transformer side bushing connection is to be fully immersed in insulating liquid.
- 4.3.1 – EN 62155 referenced as standard rather than HD.
- Table 1 – Material corrected on the 400 and 630A rated items from brass to copper.
- 4.4.2 – Time frame for temperature cycle testing added.
- 4.4.3.3 – Test criteria clarified for applications over 1.1kV.
- Table 2 – Corrected L3 dimension on 36kV bushings from 250 mm - 350 mm.
- Figure 9 / Table 9 – D2 dimension added to show required plain connection size for the range of terminals.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This is a preview of "BS EN 50336:2021". Click here to purchase the full version from the ANSI store.

1 Scope

This document is applicable to insulated bushings, excluding those plug-in bushings specified by EN 50180 series, for use in air insulated, shroud insulated and fully insulated cable boxes for liquid filled transformers and reactors for rated voltages up to 36 kV, and rated currents up to 4 000 A at frequencies from 15 Hz to 60 Hz.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60137, *Insulated bushings for alternating voltages above 1 000 V (IEC 60137)*

EN 62155, *Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1 000 V (IEC 62155)*

IEC 60296, *Fluids for electrotechnical applications - Mineral insulating oils for electrical equipment*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <https://www.iso.org/obp>

— IEC Electropedia: available at <http://www.electropedia.org/>

3.1

air insulated cable box

metallic weatherproof enclosure designed to protect the ends of cables and their associated bushings using air as the primary source of insulation

3.2

cast or moulded resin-insulated bushing

bushing in which the major insulation consists of a cast or moulded organic material with or without an inorganic filler

[SOURCE: EN 60137:2017, 3.13]

3.3

ceramic, glass or analogous inorganic material bushing

bushing in which the major insulation consists of a ceramic, glass or analogous inorganic material

[SOURCE: EN 60137:2017, 3.12]

3.4

fully insulated cable box

metallic weatherproof enclosure as in 3.1 where those parts of the termination and bushing within the enclosure including live metal parts and cable cores are insulated by a liquid or compound suitable for the appropriate system voltage

Note 1 to entry: The box shall be suitably sealed to contain the liquid or compound and allow for their expansion due to temperature changes.