



BSI Standards Publication

Industrial communication networks - Fieldbus specifications

Part 4-12: Data-link layer protocol specification - Type 12 elements

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

National foreword

This British Standard is the UK implementation of EN IEC 61158-4-12:2019. It is identical to IEC 61158-4-12:2019. It supersedes BS EN 61158-4-12:2014, which will be withdrawn on 23 May 2022.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 04851 3

ICS 35.100.20; 25.040.40; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2019.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

EUROPÄISCHE NORM

June 2019

ICS 25.040.40; 35.100.20; 35.110

Supersedes EN 61158-4-12:2014

English Version

Industrial communication networks - Fieldbus specifications -
Part 4-12: Data-link layer protocol specification - Type 12
elements
(IEC 61158-4-12:2019)

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 4-12: Spécification du protocole de la
couche liaison de données - Éléments de type 12
(IEC 61158-4-12:2019)

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-12:
Protokollspezifikation des Data Link Layer
(Sicherheitsschicht) - Typ 12-Elemente
(IEC 61158-4-12:2019)

This European Standard was approved by CENELEC on 2019-05-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

European foreword

The text of document 65C/946/FDIS, future edition 4 of IEC 61158-4-12, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61158-4-12:2019.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-02-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2022-05-23

This document supersedes EN 61158-4-12:2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61158-4-12:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131-2	NOTE Harmonized as EN 61131-2
IEC 61131-3	NOTE Harmonized as EN 61131-3
IEC 61158-1	NOTE Harmonized as EN 61158-1
IEC 61158-2:2014	NOTE Harmonized as EN 61158-2:2014 (not modified)
IEC 61158-5-12:2019	NOTE Harmonized as EN IEC 61158-5-12:2019 (not modified)
IEC 61158-6-12	NOTE Harmonized as EN 61158-6-12
IEC 61784-1	NOTE Harmonized as EN 61784-1
IEC 61784-2	NOTE Harmonized as EN 61784-2

This is a preview of "BS EN IEC 61158-4-12...". Click here to purchase the full version from the ANSI store.

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-3-12	2019	Industrial communication networks Fieldbus specifications - Part 3-12: Data-link layer service definition - Type 12 elements	-EN IEC 61158-3-12	2019
IEC 61588	-	Precision clock synchronization protocol for networked measurement and control systems	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems-Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems-Interconnection - Basic reference model: Naming and addressing	-	-
ISO/IEC 9899	-	Information technology - Programming-languages - C	-	-
ISO/IEC 10731	-	Information technology - Open Systems-Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
ISO/IEC/IEEE 8802-3	-	Standard for Ethernet	-	-
IEEE Std 802.1Q	-	IEEE Standard for Local and Metropolitan-Area Networks – Bridges and bridged networks	-	-
IETF RFC 768	-	User Datagram Protocol	-	-
IETF RFC 791	-	Internet protocol DARPA internet program-protocol specification	-	-

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
1.1 General.....	11
1.2 Specifications	11
1.3 Procedures	11
1.4 Applicability	11
1.5 Conformance	11
2 Normative references	12
3 Terms, definitions, symbols, abbreviations and conventions	12
3.1 Reference model terms and definitions	12
3.2 Service convention terms and definitions	13
3.3 Common terms and definitions.....	14
3.4 Additional Type 12 definitions	14
3.5 Common symbols and abbreviations	17
3.6 Additional Type 12 symbols and abbreviations.....	18
3.7 Conventions.....	19
3.7.1 General concept	19
3.7.2 Abstract syntax conventions	19
3.7.3 Convention for the encoding of reserved bits and octets	21
3.7.4 Conventions for the common coding s of specific field octets.....	21
3.7.5 State machine conventions	22
4 Overview of the DL-protocol	24
4.1 Operating principle.....	24
4.2 Topology.....	24
4.3 Frame processing principles	24
4.4 Data-link layer overview.....	25
4.5 Error detection overview	26
4.6 Node reference model.....	26
4.6.1 Mapping onto OSI basic reference model	26
4.6.2 Data-link Layer features	27
4.7 Operation overview	27
4.7.1 Relation to ISO/IEC/IEEE 8802-3.....	27
4.7.2 Frame structure	27
5 Frame structure	28
5.1 Frame coding principles	28
5.2 Data types and encoding rules	28
5.2.1 General description of data types and encoding rules	28
5.2.2 Transfer syntax for bit sequences	28
5.2.3 Unsigned Integer	29
5.2.4 Signed Integer.....	30
5.2.5 Octet String	30
5.2.6 Visible String.....	30
5.3 Ethernet DLPDU structure.....	31
5.3.1 Type 12 frame inside an Ethernet frame	31
5.3.2 Type 12 frame inside a UDP datagram	31

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

5.3.3	Type 12 frame structure.....	33
5.4	Type 12 DLPDU structure	33
5.4.1	Read	33
5.4.2	Write	38
5.4.3	Read write	43
5.4.4	Attributes access	50
5.5	Network variable structure	50
5.6	Type 12 mailbox structure	51
6	Attributes.....	52
6.1	Management.....	52
6.1.1	DL Information.....	52
6.1.2	Station address	56
6.1.3	DL control.....	57
6.1.4	DL status	59
6.1.5	DLS-user specific registers.....	62
6.1.6	Event parameter	63
6.2	Statistics.....	68
6.2.1	RX error counter.....	68
6.2.2	Lost link counter	69
6.2.3	Additional counter.....	70
6.3	Watchdogs.....	71
6.3.1	Watchdog divider.....	71
6.3.2	DLS-user watchdog	72
6.3.3	Sync manager watchdog.....	72
6.3.4	Sync manager watchdog status	73
6.3.5	Watchdog counter.....	74
6.4	Slave information interface	74
6.4.1	Slave information interface area	74
6.4.2	Slave information interface access	74
6.4.3	Slave information interface control/status	75
6.4.4	Slave information interface address	77
6.4.5	Slave information interface data	78
6.5	Media independent interface (MII).....	78
6.5.1	MII control/status	78
6.5.2	MII address	80
6.5.3	MII data	81
6.5.4	MII access	81
6.6	Fieldbus memory management unit (FMMU)	82
6.6.1	General	82
6.6.2	FMMU attributes	83
6.7	Sync manager.....	85
6.7.1	Sync manager overview.....	85
6.7.2	Sync Manager Attributes.....	88
6.8	Distributed clock	91
6.8.1	General	91
6.8.2	Delay measurement.....	91
6.8.3	Local time parameter	92
6.8.4	DL-user time parameter	92
6.8.5	DC attributes	93

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

7	DL-user memory	95
7.1	Overview	95
7.2	Mailbox access type.....	95
7.2.1	Mailbox transfer.....	95
7.2.2	Write access from master	95
7.2.3	Read access from master	97
7.3	Buffered access type	98
7.3.1	Write access from master	98
7.3.2	Read access from master	98
8	Type 12: FDL protocol state machines.....	99
8.1	Overview of slave DL state machines.....	99
8.2	State machine description.....	100
8.2.1	Port state machine (PSM).....	100
8.2.2	PDU handler state machine (DHSM).....	100
8.2.3	Sync manager state machine (SYSM).....	101
8.2.4	Resilient mailbox state machine (RMSM).....	101
8.2.5	SII state machine (SIISM).....	101
8.2.6	MII state machine (MIISM).....	105
8.2.7	DC state machine (DCSM).....	105
Annex A (informative) Type 12: Additional specifications on DL-Protocol state machines		108
A.1	DHSM.....	108
A.1.1	Primitive definitions	108
A.1.2	State machine description	109
A.1.3	DHSM table	110
A.1.4	Functions.....	125
A.2	SYSM	126
A.2.1	Primitive definition	126
A.2.2	State machine description	127
A.2.3	Local variables	128
A.2.4	State table nomenclature	128
A.2.5	SYSM table	128
A.2.6	Functions.....	138
A.3	RMSM.....	138
A.3.1	Primitive definitions	138
A.3.2	State machine description	139
A.3.3	Local variables	139
A.3.4	RMSM table.....	139
A.3.5	Functions.....	141
Bibliography.....		142
Figure 1 – Type description example		20
Figure 2 – Common structure of specific fields.....		21
Figure 3 – Frame structure.....		25
Figure 4 – Mapping of data in a frame.....		26
Figure 5 – Slave node reference model.....		27
Figure 6 – Type 12 PDUs embedded in Ethernet frame.....		28
Figure 7 – Type 12 PDUs embedded in UDP/IP		28

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

Figure 8 – DL information type description	54
Figure 9 – Address type description	56
Figure 10 – DL control type description	58
Figure 11 – DL status type description	61
Figure 12 – Successful write sequence to DL-user control register	62
Figure 13 – Successful read sequence to the DL-user status register	63
Figure 14 – RX error counter type description	69
Figure 15 – Lost link counter type description	70
Figure 16 – Additional counter type description	71
Figure 17 – Watchdog divider type description	72
Figure 18 – DLS-user Watchdog divider type description	72
Figure 19 – Sync manager watchdog type description	73
Figure 20 – Sync manager watchdog status type description	73
Figure 21 – Watchdog counter type description	74
Figure 22 – Slave information interface access type description	74
Figure 23 – Slave information interface control/status type description	76
Figure 24 – Slave information interface address type description	78
Figure 25 – Slave information interface data type description	78
Figure 26 – MII control/status type description	79
Figure 27 – MII address type description	81
Figure 28 – MII data type description	81
Figure 29 – MII access type description	82
Figure 30 – FMMU mapping example	83
Figure 31 – FMMU entity type description	84
Figure 32 – SyncM mailbox interaction	86
Figure 33 – SyncM buffer allocation	86
Figure 34 – SyncM buffer interaction	87
Figure 35 – Handling of write/read toggle with read mailbox	87
Figure 36 – Sync manager channel type description	89
Figure 37 – Distributed clock local time parameter type description	93
Figure 38 – Successful write sequence to mailbox	96
Figure 39 – Bad write sequence to mailbox	96
Figure 40 – Successful read sequence to mailbox	97
Figure 41 – Bad read sequence to mailbox	97
Figure 42 – Successful write sequence to buffer	98
Figure 43 – Successful read sequence to buffer	99
Figure 44 – Structuring of the protocol machines of an slave	100
Figure 45 – Slave information interface read operation	102
Figure 46 – Slave information interface write operation	103
Figure 47 – Slave information interface reload operation	104
Figure 48 – Distributed clock	106
Figure 49 – Delay measurement sequence	107

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

Table 1 – PDU element description example	20
Table 2 – Example attribute description	21
Table 3 – State machine description elements	23
Table 4 – Description of state machine elements	23
Table 5 – Conventions used in state machines	23
Table 6 – Transfer Syntax for bit sequences	29
Table 7 – Transfer syntax for data type Unsignedn	29
Table 8 – Transfer syntax for data type Integern	30
Table 9 – Type 12 frame inside an Ethernet frame	31
Table 10 – Type 12 frame inside an UDP PDU	32
Table 11 – Type 12 frame structure containing Type 12 PDUs	33
Table 12 – Type 12 frame structure containing network variables	33
Table 13 – Type 12 frame structure containing mailbox	33
Table 14 – Auto increment physical read (APRD).....	34
Table 15 – Configured address physical read (FPRD).....	35
Table 16 – Broadcast read (BRD)	36
Table 17 – Logical read (LRD)	37
Table 18 – Auto Increment physical write (APWR)	38
Table 19 – Configured address physical write (FPWR).....	39
Table 20 – Broadcast write (BWR)	41
Table 21 – Logical write (LWR).....	42
Table 22 – Auto increment physical read write (APRW)	43
Table 23 – Configured address physical read write (FPRW).....	44
Table 24 – Broadcast read write (BRW)	45
Table 25 – Logical read write (LRW)	47
Table 26 – Auto increment physical read multiple write (ARMW).....	48
Table 27 – Configured address physical read multiple write (FRMW).....	49
Table 28 – Network variable	50
Table 29 – Mailbox	51
Table 30 – Error Reply Service Data	52
Table 31 – DL information.....	54
Table 32 – Configured station address.....	57
Table 33 – DL control	58
Table 34 – DL status.....	61
Table 35 – DLS-user specific registers.....	63
Table 36 – DLS-user event	65
Table 37 – DLS-user event mask	66
Table 38 – External event.....	67
Table 39 – External event mask.....	68
Table 40 – RX error counter.....	69
Table 41 – Lost link counter.....	70
Table 42 – Additional counter	71
Table 43 – Watchdog divider.....	72

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

Table 44 – DLS-user watchdog	72
Table 45 – Sync manager channel watchdog	73
Table 46 – Sync manager watchdog Status	73
Table 47 – Watchdog counter	74
Table 48 – Slave information interface access	75
Table 49 – Slave information interface control/status	76
Table 50 – Slave information interface address	78
Table 51 – Slave information interface data	78
Table 52 – MII control/status	80
Table 53 – MII address	81
Table 54 – MII data	81
Table 55 – MII access	82
Table 56 – Fieldbus memory management unit (FMMU) entity	84
Table 57 – Fieldbus memory management unit (FMMU)	85
Table 58 – Sync manager channel	90
Table 59 – Sync manager Structure	91
Table 60 – Distributed clock local time parameter	93
Table 61 – Distributed clock DLS-user parameter	94
Table A.1 – Primitives issued by DHSM to PSM	108
Table A.2 – Primitives issued by PSM to DHSM	108
Table A.3 – Parameters used with primitives exchanged between DHSM and PSM	108
Table A.4 – Identifier for the octets of a Ethernet frame	109
Table A.5 – DHSM state table	111
Table A.6 – DHSM function table	126
Table A.7 – Primitives issued by SYSM to DHSM	126
Table A.8 – Primitives issued by DHSM to SYSM	127
Table A.9 – Primitives issued by DL-User to SYSM	127
Table A.10 – Primitives issued by SYSM to DL-User	127
Table A.11 – Parameters used with primitives exchanged between SYSM and DHSM	127
Table A.12 – SYSM state table	129
Table A.13 – SYSM function table	138
Table A.14 – Primitives issued by RMSM to SYSM	138
Table A.15 – Primitives issued by SYSM to RMSM	139
Table A.16 – Parameters used with primitives exchanged between RMSM and SYSM	139
Table A.17 – RMSM state table	140
Table A.18 – RMSM function table	141

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-12: Data-link layer protocol specification – Type 12 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-4-12 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

This edition includes the following significant technical changes with respect to the previous edition:

- technical corrections and editorial improvements for clarification.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/946/FDIS	65C/955/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

This is a preview of "BS EN IEC 61158-4-12...". [Click here to purchase the full version from the ANSI store.](#)

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the "three-layer" fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the profile parts. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning Type 12 elements and possibly other types given as follows:

EP 1 590 927 B1	[BE] Koppler für ein Netzwerk mit Ringtopologie und ein auf Ethernet basierten Netzwerk
EP 1 789 857 B1	[BE] Datenübertragungsverfahren und automatisierungssystem zum Einsatz eines solchen Datenübertragungsverfahrens
EP 2 137 893 B1	[BE] Paketvermittlungsvorrichtung und lokales Kommunikationsnetz mit einer solchen Paketvermittlungsvorrichtung
EP 1 456 722 B1	[BE] Datenübertragungsverfahren, serielles Bussystem und Anschalteinheit für einen passiven Busteilnehmer

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

[BE]: Beckhoff Automation GmbH
Eiserstraße 5
33415 Verl,
Germany

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line databases of patents relevant to their standards. Users are encouraged to consult the databases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-12: Data-link layer protocol specification – Type 12 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

- a) in a synchronously-starting cyclic manner, and
- b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This document specifies

- a) procedures for the transfer of data and control information from one data-link user entity to one or more user entity;
- b) the structure of the DLPDUs used for the transfer of data and control information by the protocol of this document, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between DL-entities (DLEs) through the exchange of DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and the MAC services of ISO/IEC/IEEE 8802-3.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI reference model, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This document also specifies conformance requirements for systems implementing these procedures. This part of this document does not contain tests to demonstrate compliance with such requirements.