



CSA C22.2 No. 139:19

Electrically operated valves



Legal Notice for Standards

Canadian Standards Association (operating as "CSA Group") develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA C22.2 No. 139:19 December 2019

Title: *Electrically operated valves*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2427450**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

CSA C22.2 No. 139:19

Electrically operated valves



®A trademark of the Canadian Standards Association, operating as "CSA Group"

*Published in December 2019 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-4883-2377-5

*© 2019 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Industrial Products	5
Subcommittee on Electrically Operated Valves	7
Preface	8
1 Scope	10
2 Reference publications	11
3 Definitions	13
4 General requirements	15
5 Construction	15
5.1 General	15
5.1.1 Components	15
5.1.2 Electrical component location	15
5.1.3 Reassembly	15
5.1.4 Modular assembly	16
5.1.5 Semiconductor components	16
5.1.6 Safety functions involving electronics	16
5.1.7 Solid-state devices and unreliable components	16
5.2 Enclosures	17
5.2.1 General	17
5.2.2 Non-metallic materials	17
5.2.3 Thickness of non-metallic enclosures for live parts	18
5.2.4 Thickness of sheet metal enclosures for live parts	18
5.2.5 Thickness of cast enclosures for live parts	18
5.2.6 Doors and covers of enclosures	18
5.2.7 Openings in enclosures	19
5.2.8 Special-purpose enclosures	19
5.3 Mechanical assembly	19
5.4 Strength of fluid-containing parts	20
5.4.1 General	20
5.4.2 Safety shut-off valves for fuel gas	20
5.4.3 Fluid-containing parts intended for Boiler and Pressure Vessel applications	20
5.4.4 Compliance	20
5.4.5 Threaded connection to pipes	21
5.4.6 Valves for flammable, hazardous fluids and safety valves	21
5.4.7 Hydraulic control valves installed in elevator systems	21
5.5 Operation requirements	21
5.5.1 Seat leakage	21
5.5.2 External leakage	22
5.5.3 Opening and closing	22
5.6 Endurance requirements	23
5.7 Supply connections	23

5.7.1	General	23
5.7.2	Leads	24
5.8	Wiring terminal parts	24
5.9	Current-carrying parts	25
5.10	Internal wiring	25
5.11	Electrical insulation	26
5.12	Motors	26
5.12.1	General	26
5.12.2	Protection against overheating	26
5.13	Transformers	26
5.14	Switches and controls	27
5.15	Fuses and fuseholders	27
5.16	Spacings	27
5.16.1	General	27
5.16.2	Low-voltage circuits	28
5.16.3	Extra-low-voltage safety-control circuits	29
5.16.4	Extra-low-voltage Class 2 circuits	29
5.16.5	Spacings on printed circuit boards	29
5.17	Separation of circuits	30
5.17.1	Factory-installed wiring	30
5.17.2	Provision for field installation conductors	30
5.18	Grounding and bonding	31
5.19	Isolation of circuits	31
5.20	Surge suppression components	31
5.21	Components for communication applications	32
5.22	Thermal cut-off	32
5.23	Electro-hydraulic actuators	32
6	Marking	32
6.1	General	32
6.2	Extra-low-voltage valves	34
6.3	Modular assembly	35
7	Tests	35
7.1	General	35
7.2	Test conditions	36
7.3	Rating	36
7.3.1	Input	36
7.3.2	Output	36
7.4	Temperature	36
7.4.1	General	36
7.4.2	Temperature under extreme voltage operating conditions	37
7.4.3	Temperature under normal operating conditions	37
7.4.4	High ambient temperature condition	37
7.4.5	Test fluid requirements	38
7.4.6	Switching devices or auxiliary circuits	38
7.4.7	Modulating action	38
7.4.8	Repeated operation	38
7.4.9	Motor stall condition	38

7.4.10	Measurement methods	38
7.5	Operation	39
7.5.1	General	39
7.5.2	Opening and closing — Safety valves	39
7.5.3	Opening and closing — General-purpose valves	39
7.5.4	Operating times	40
7.6	Dielectric strength	40
7.7	Overload (control devices)	41
7.8	Endurance tests	42
7.8.1	General	42
7.8.2	Control devices	45
7.9	Leakage tests	46
7.9.1	General	46
7.9.2	Seat and external leakage test sequence and conditions	46
7.9.3	Seat leakage test for safety valves intended to handle liquid fluids	46
7.9.4	Seat leakage test for safety valves intended to handle gas fluids	47
7.9.5	Test for external leakage	48
7.10	Strength tests of fluid-containing parts	49
7.11	Impact test	49
7.12	Flame test for enclosures of live parts	50
7.12.1	General	50
7.12.2	Apparatus	50
7.12.3	Test procedure	50
7.12.4	Compliance	51
7.12.5	Alternate flame test	51
7.13	Deformation test	51
7.14	Fatigue test	52
7.14.1	Test method	52
7.14.2	Acceptance criteria	52
7.14.3	Additional requirements	52
7.15	Test for valves with valve bodies of thermoplastic material intended to be connected to a delivery point downstream of the water supply mains	52
7.15.1	Test method	52
7.15.2	Conditions of acceptability	53
7.16	Test for general-purpose pneumatic (air) valves with valve bodies of non-metallic material	53
7.16.1	Applicable valves for pressure envelope test	53
7.16.2	Pressure envelope test	53
7.16.3	Impact	53
7.17	Single fault condition	54
7.18	Burnout test	54
7.18.1	General	54
7.18.2	Test conditions	54
7.18.3	Conditions of acceptability	54
7.19	Abnormal	54
7.19.4	Conditions of acceptability	55
7.20	Printed circuit board with conformal coating	55
7.20.1	Dielectric strength on printed circuit boards	55
7.20.2	Dielectric strength after temperature conditioning	55
7.20.3	Dielectric strength after humidity conditioning	55

7.20.4 Adhesion 56

7.21 Torsion and bending moment 56

Annex A (informative) — Calculation of variability factor, K_v 71

Technical Committee on Industrial Products

R. P. de Lhorbe	Schneider Electric Canada, Inc., North Vancouver, British Columbia, Canada <i>Category: Producer Interest</i>	<i>Chair</i>
M. Smith	Kitchener, Ontario, Canada <i>Category: General Interest</i>	<i>Vice-Chair</i>
A. Z. Tsisserev	AES Engineering Ltd., Vancouver, British Columbia, Canada <i>Category: User Interest</i>	<i>Vice-Chair</i>
B. M. Baldwin	Baldwin Services Inc., Saskatoon, Saskatchewan, Canada <i>Category: General Interest</i>	
R. M. Bartholomew	Electric Power Equipment Ltd., Vancouver, British Columbia, Canada <i>Category: Producer Interest</i>	
R. B. Buckler	ASCO Power Technologies Canada, Brantford, Ontario, Canada <i>Category: Producer Interest</i>	
C. C. Cormier	Alberta Municipal Affairs, Edmonton, Alberta, Canada <i>Category: Regulatory Authority</i>	
T. S. Driscoll	OBIEC Consulting Ltd., Calgary, Alberta, Canada <i>Category: User Interest</i>	
V. V. Gagachev	Eaton, Burlington, Ontario, Canada <i>Category: Producer Interest</i>	
N. Hanna	Electrical Safety Authority, Mississauga, Ontario, Canada <i>Category: Regulatory Authority</i>	

R. J. Kelly	CSA Consumer Program, Ingleside, Ontario, Canada <i>Category: Regulatory Authority</i>	
R. Leduc	Marex Canada Limited, Calgary, Alberta, Canada <i>Category: User Interest</i>	
D. R. MacLeod	Nova Scotia Department of Labour and Advanced Education, Halifax, Nova Scotia, Canada <i>Category: Regulatory Authority</i>	
D. Mascarenhas	Brampton, Ontario, Canada <i>Category: General Interest</i>	
R. Pack	SaskPower, Saskatoon, Saskatchewan, Canada <i>Category: Regulatory Authority</i>	
T. Simmons	British Columbia Institute of Technology, Burnaby, British Columbia, Canada <i>Category: General Interest</i>	
C. Lee	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Subcommittee on Electrically Operated Valves

B. Morrison	Toronto, Ontario, Canada	<i>Chair</i>
G. Aubert-Maguéro	Bernard Controls, Gonesse Cedex, France	
A. Bal	Toronto, Ontario, Canada	
K. Boehme	National Fluid Power Association, Milwaukee, Wisconsin, USA	
J. F. Carlin	Eaton Corporation Hydraulics Operations, Searcy, Arkansas, USA	
E. Fernando	Brampton, Ontario, Canada	
R. Jakhu	CSA Group, Toronto, Ontario, Canada	
D. C. Johnson	Robertshaw Controls Company, dba Robertshaw, Itasca, Illinois, USA	
W. J. Loftus	Asco Valve Canada, Brantford, Ontario, Canada	
K. Stroes	SMC Corporation of America, Noblesville, Indiana, USA	
O. Walch	R. Stahl Schaltgeraete GmbH, Waldenburg, Baden-Württemberg, Germany	
T. White	Rotork Controls Inc., Rochester, New York, USA	
S. Wiedmann	Burkert Werke GmbH & Co. KG, Ingelfingen, Germany	
M. McEwen	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Preface

This is the fifth edition of CSA C22.2 No. 139, *Electrically operated valves*. It supersedes the previous editions, published in 2013, 2010, 1982, and 1973.

This Standard is one of a series of Standards issued by CSA Group under Part II of the *Canadian Electrical Code*.

The following are the major changes to this edition:

- a) Scope expanded to include electro-hydraulic actuators.
- b) Spacing requirements for printed circuit boards rated for use above 300 V to 600 V have been added.
- c) Construction requirements for electro-hydraulic actuators have been added.
- d) Endurance cycle requirements added for damper actuator category.
- e) Repositioning range for modulating valves for hazardous fluids added.
- f) Endurance cycles for hydraulic control valves clarified.
- g) Cycle and reposition requirements for modulating general purpose valve/actuators used in specific end applications clarified.

Permission to use extracts from ISO/TR 10771-2:2008 was provided by Standards Council of Canada (SCC) on behalf of ISO. No further reproduction is permitted without prior written approval from Standards Council of Canada.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Electrically Operated Valves, under the jurisdiction of the Technical Committee on Industrial Products and the Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the Technical Committee.

Interpretations: The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: "The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant CSA committee interpretation has not already been published, CSA Group's procedures for interpretation shall be followed to determine the intended safety principle."

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as "substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity". It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include "Request for interpretation" in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific "yes" or "no" answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include "Proposal for change" in the subject line:*
- a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

CSA C22.2 No. 139:19

Electrically operated valves

1 Scope

1.1

This Standard applies to electrically operated, general-purpose valves* and safety valves* that are intended to be used in ordinary locations in accordance with CSA C22.1, *Canadian Electrical Code, Part I*, for the control of fluids (e.g., air, gases, oils, refrigerants, steam, water, etc.), and rated 600 V and less.

** For convenience, the shorter term "valve" is used where the same requirements apply to both general-purpose and safety valves.*

1.2

This Standard applies to electrically powered mechanisms that are designed to provide the signals needed for monitoring valve operation from a remote location and to electrically powered valve actuators* that are designed to be fitted to valves.

** For convenience, the term valve includes valve actuator unless otherwise stated.*

1.3

This Standard applies to self-contained electro-hydraulic* actuators, both linear and rotary type.

** These types of actuators are electrically operated and use hydraulic fluid as a driving medium. They can be operated in conjunction with a remote signal.*

1.4

This Standard contains requirements for electrical features of valves and requirements for mechanical features of valves that affect their safe operation.

1.5

With respect to construction and tests of electrical features, the requirements of this Standard complement those of ANSI Z21.21/CSA 6.5.

1.6

Electrically operated damper actuators are evaluated to the requirements of CSA C22.2 No. 24.

1.7

This Standard does not contain requirements for mechanical and operational features that do not directly affect the safe operation of a valve.

1.8

This Standard does not apply to water valves of connection size larger than 2-inch pipe size or pressure rating above 1600 kPa (232 psi) for valve bodies of thermoplastic material.