

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

Renrum og tilknyttede kontrollerede områder – Del 12: Specifikation af overvågning af luftrenhed ved hjælp af nanopartikelkoncentration

Cleanrooms and associated controlled environments –
Part 12: Specifications for monitoring air cleanliness
by nanoscale particle concentration

DANSK STANDARD
Danish Standards Association

Göteborg Plads 1
DK-2150 Nordhavn

Tel: +45 39 96 61 01

Tel: +45 39 96 61 01

dansk.standard@ds.dk

www.ds.dk

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

DS projekt: M310547

ICS: 13.040.35

Første del af denne publikations betegnelse er:

DS/ISO, hvilket betyder, at det er en international standard, der har status som dansk standard.

Denne publikations overensstemmelse er:

IDT med: ISO 14644-12:2018

DS-publikationen er på engelsk.

DS-publikationstyper

Dansk Standard udgiver forskellige publikationstyper.

Typen på denne publikation fremgår af forsiden.

Der kan være tale om:

Dansk standard

- standard, der er udarbejdet på nationalt niveau, eller som er baseret på et andet lands nationale standard, eller
- standard, der er udarbejdet på internationalt og/eller europæisk niveau, og som har fået status som dansk standard

DS-information

- publikation, der er udarbejdet på nationalt niveau, og som ikke har opnået status som standard, eller
- publikation, der er udarbejdet på internationalt og/eller europæisk niveau, og som ikke har fået status som standard, fx en teknisk rapport, eller
- europæisk præstandard

DS-håndbog

- samling af standarder, eventuelt suppleret med informativt materiale

DS-hæfte

- publikation med informativt materiale

Til disse publikationstyper kan endvidere udgives

- tillæg og rettelsesblade

DS-publikationsform

Publikationstyperne udgives i forskellig form som henholdsvis

- fuldttekstpublikation (publikationen er trykt i sin helhed)
- godkendelsesblad (publikationen leveres i kopi med et trykt DS-omslag)
- elektronisk (publikationen leveres på et elektronisk medie)

DS-betegnelse

Alle DS-publikationers betegnelse begynder med DS efterfulgt af et eller flere præfikser og et nr., fx **DS 383**, **DS/EN 5414** osv. Hvis der efter nr. er angivet et **A** eller **Cor**, betyder det, enten at det er et **tillæg** eller et **rettelsesblad** til hovedstandard, eller at det er indført i hovedstandard.

DS-betegnelse angives på forsiden.

Overensstemmelse med anden publikation:

Overensstemmelse kan enten være IDT, EQV, NEQ eller MOD

- **IDT:** Når publikationen er identisk med en given publikation.
- **EQV:** Når publikationen teknisk er i overensstemmelse med en given publikation, men præsentationen er ændret.
- **NEQ:** Når publikationen teknisk eller præsentationsmæssigt ikke er i overensstemmelse med en given standard, men udarbejdet på baggrund af denne.
- **MOD:** Når publikationen er modificeret i forhold til en given publikation.

First edition
2018-08-27

Cleanrooms and associated controlled environments —

Part 12: Specifications for monitoring air cleanliness by nanoscale particle concentration

Salles propres et environnements maîtrisés apparentés —

Partie : Spécification de la propreté de l'air en fonction de la concentration des nanoparticules



Reference number
ISO 14644-12:2018(E)

© ISO 2018

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 General.....	1
3.2 Size.....	2
3.3 Airborne particles.....	2
3.4 Occupancy states.....	3
3.5 Measuring apparatus.....	3
4 Monitoring	3
4.1 General.....	3
4.2 Principle.....	3
4.3 Methods.....	3
5 Test report	4
Annex A (informative) Reference method for monitoring by condensation particle counting	5
Annex B (informative) Particle counting efficiency and particle size cutoff	8
Bibliography	11

This is a preview of "DS/ISO 14644-12:2018". Click here to purchase the full version from the ANSI store.

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 209, *Cleanrooms and associated controlled environments*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

A list of all parts in the [ISO 14644 series](#) can be found on the ISO website.

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

Introduction

Cleanrooms and associated controlled environments provide the control of contamination to levels appropriate for accomplishing contamination-sensitive activities. Products and processes that benefit from the control of contamination include those in such industries as aerospace, microelectronics, pharmaceuticals, medical devices, healthcare and food.

The normative requirements in the first editions of [ISO 14644-1](#) and [ISO 14644-3](#) were limited to classification of particles greater than 100 nm. However, informative material was included in both documents for airborne particles smaller than 100 nm. At the time these documents were written; particles smaller than 100 nm were called ultrafine particles rather than the more recent term, nanoparticles.

In the second editions of [ISO 14644-1](#) and [ISO 14644-3](#)¹⁾, sections on ultrafine particles have been removed and these are incorporated, in modified form, in this document. Supporting information has also been drawn from documents developed elsewhere, for example by ISO/TC 229, *Nanotechnologies*.

Nanotechnology typically deals with material in the size range of approximately 1 nm to 100 nm. As part of the long-term trend of manufacturing products with ever smaller feature size to improve performance, many industries utilizing cleanrooms (such as microelectronics and those related to health) now have products in the nanoscale.

Nanoparticles are man-made. Other particles in the nanoscale size range can originate as incidental by-product emissions from industrial process or additionally as naturally occurring particles. A cleanroom with a nanotechnology-based process can contain nanoscale particles from all three sources.

Nanoparticles or ultrafine particles differ from sub-micron and macro-particles in origin, chemical properties and transport behaviour. Most sub-micron and macro particles in cleanrooms can be related to human activity. Nanoparticles are generated by electrostatic discharge, chemical reactions, such as oxidation, and gas phase nucleation. Material properties of nanoparticles are expected to differ from bulk properties with potentially greater reactivity and sometimes enhanced toxicity. Transport of nanoparticles is dominated by air flow, just like sub-micron particles. However, diffusion of nanoparticles and mobility in electrical fields increases rapidly with decreasing size. As a consequence, nanoparticles have higher coagulation rates in the air and deposition rates on surfaces are higher than larger sized particles. Therefore, it is not expected that the classification curves as described in [ISO 14644-1](#) can be simply extrapolated to smaller particles than the stated lower limit.

Ultra Low Particulate Air (ULPA) filters remove nanoparticles with high efficiency, preventing penetration from the atmosphere and recirculated air. Therefore, the majority of the nanoparticles in cleanrooms are process related. For many cleanrooms, the composition of sub-micron and macro particles is comparable. For nanoparticles, each cleanroom has nanoparticles corresponding to the specific process. Therefore, measurement of the nanoparticle concentration is only suitable when the cleanroom is in an "operational" state. In the "as-built" or "at-rest" state, the lack of process related particles leads to data that do not correlate to the realistic conditions.

See Bibliography references [1] to [18] for background information on particle size characteristics/properties.

1) Under preparation. (Stage at the time of publication: ISO/DIS 14644-3.)

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

This is a preview of "DS/ISO 14644-12:2018". [Click here to purchase the full version from the ANSI store.](#)

Cleanrooms and associated controlled environments —

Part 12:

Specifications for monitoring air cleanliness by nanoscale particle concentration

1 Scope

This document covers the monitoring of air cleanliness by particles in terms of concentration of airborne nanoscale particles.

For monitoring purposes, only populations of particles with a lower size limit of 0.1 microns (100 nm) or less – “nanoscale” – are considered.

The monitoring given in this document is for use mainly in “operational” states.

NOTE 1 — For the purposes of this document, reference is made to “nanoscale particles”, which means all nano-objects having one (nanoplate), two (nanofibre) or three (nanoparticle) dimensions in the nanoscale.

NOTE 2 — As a consequence, the specifications for monitoring air cleanliness by nanoscale particle concentration of the cleanroom in operational state also considers process specifics, e.g., used equipment, personnel behaviour, etc.

NOTE 3 — Health and safety considerations are excluded from this document.

2 Normative references

There are no normative references in this document.