

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

# Undersøgelsesresultater for elektromagnetisk interferens i frekvensområdet under 150 kHz

Investigation Results on Electromagnetic Interference in the Frequency Range below 150 kHz



**DANSK STANDARD**  
Danish Standards Association

Göteborg Plads 1  
DK-2150 Nordhavn

Tel: +45 39 96 61 01

Tel: +45 39 96 61 01

[dansk.standard@ds.dk](mailto:dansk.standard@ds.dk)

[www.ds.dk](http://www.ds.dk)

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

DS projekt: M315014  
ICS: 33.100.10

**Første del af denne publikations betegnelse er:**  
DS/CLC/TR, hvilket betyder, at det er en europæisk teknisk rapport, der har status som DS-information.

**Denne publikations overensstemmelse er:**  
IDT med: CLC/TR 50669:2017

DS-publikationen er på engelsk.

---

### **DS-publikationstyper**

Dansk Standard udgiver forskellige publikationstyper.  
Typen på denne publikation fremgår af forsiden.

Der kan være tale om:

#### **Dansk standard**

- standard, der er udarbejdet på nationalt niveau, eller som er baseret på et andet lands nationale standard, eller
- standard, der er udarbejdet på internationalt og/eller europæisk niveau, og som har fået status som dansk standard

#### **DS-information**

- publikation, der er udarbejdet på nationalt niveau, og som ikke har opnået status som standard, eller
- publikation, der er udarbejdet på internationalt og/eller europæisk niveau, og som ikke har fået status som standard, fx en teknisk rapport, eller
- europæisk præstandard

#### **DS-håndbog**

- samling af standarder, eventuelt suppleret med informativt materiale

#### **DS-hæfte**

- publikation med informativt materiale

Til disse publikationstyper kan endvidere udgives

- tillæg og rettelsesblade

### **DS-publikationsform**

Publikationstyperne udgives i forskellig form som henholdsvis

- fuldtekstpublikation (publikationen er trykt i sin helhed)
- godkendelsesblad (publikationen leveres i kopi med et trykt DS-omslag)
- elektronisk (publikationen leveres på et elektronisk medie)

### **DS-betegnelse**

Alle DS-publikationers betegnelse begynder med DS efterfulgt af et eller flere præfikser og et nr., fx **DS 383**, **DS/EN 5414** osv. Hvis der efter nr. er angivet et **A** eller **Cor**, betyder det, enten at det er et **tillæg** eller et **rettelsesblad** til hovedstandard, eller at det er indført i hovedstandard.

DS-betegnelse angives på forsiden.

### **Overensstemmelse med anden publikation:**

Overensstemmelse kan enten være IDT, EQV, NEQ eller MOD

- **IDT:** Når publikationen er identisk med en given publikation.
- **EQV:** Når publikationen teknisk er i overensstemmelse med en given publikation, men præsentationen er ændret.
- **NEQ:** Når publikationen teknisk eller præsentationsmæssigt ikke er i overensstemmelse med en given standard, men udarbejdet på baggrund af denne.
- **MOD:** Når publikationen er modificeret i forhold til en given publikation.

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

## TECHNISCHER BERICHT

December 2017

ICS 33.100.10

English Version

## Investigation Results on Electromagnetic Interference in the Frequency Range below 150 kHz

Résultats des études réalisées sur le brouillage  
électromagnétique dans la plage des fréquences inférieures  
à 150 kHz

Untersuchungsergebnisse zu elektromagnetischen  
Interferenzen im Frequenzbereich unter 150 kHz

This Technical Report was approved by CENELEC on 2017-09-11.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

## Contents

	Page
European foreword .....	10
Introduction .....	11
1 Scope .....	12
2 General.....	12
3 Specific situation in the frequency range 2 kHz – 150 kHz .....	12
4 Dimension of the EMC problem & Environment.....	15
5 Situation of emission levels and EMI.....	20
6 Specific EMC issues .....	25
6.1 General.....	25
6.2 MCS robustness.....	25
6.3 The impedance behaviour .....	27
6.3.1 General.....	27
6.3.2 Variable impedance characteristic and its possible effects .....	27
6.3.3 Impedance values, measurement and calculation .....	28
6.3.4 Summary.....	34
6.4 Long-term effects of EMI.....	35
6.4.1 General.....	35
6.4.2 Thermal impact on electronic components .....	36
6.4.3 Increase of emissions due to ageing.....	38
6.4.4 Summary.....	38
7 Measurement issues .....	38
7.1 General.....	38
7.2 Status of standardisation.....	39
7.3 Characteristics of measurement quantities and requirements .....	41
7.3.1 Classification of higher frequency phenomena .....	41
7.3.2 Types of application .....	42
7.3.3 General requirements.....	42
7.4 Summary.....	43
8 Emissions - Measurement and test results.....	44
8.1 General.....	44
8.2 Measurement and test results .....	44
8.2.1 Large photovoltaic inverter installations .....	44
8.2.2 Small PV inverter installations .....	48
8.2.3 Lamps with electronic ballast.....	51
8.2.4 Electric vehicle charging .....	57
8.2.5 Frequency-controlled heat pump.....	62
8.2.6 Cola spender .....	63
8.2.7 DVD player.....	64
8.2.8 TV box .....	65
8.2.9 Beer cooler .....	66
8.2.10 Travelling circuses .....	66
8.2.11 Power supply to fibre switches.....	67
8.2.12 Power supply to a network router.....	68
8.2.13 Plugin charger.....	68
8.2.14 Single-phase PSU pretending a 3-phase problem .....	69
8.2.15 Power supply to a PLC modem.....	70
8.2.16 Microwave oven .....	70

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

8.2.17	Desktop power supply with aPFC .....	71
8.3	Summary .....	71
9	EMI cases - Measurement and test results .....	72
9.1	Introduction.....	72
9.2	General .....	72
9.3	EMI due to conducted emissions .....	73
9.3.1	EMI to NCE .....	73
9.3.2	EMI with MCS .....	80
9.4	EMI due to radiated field strength from conducted NIE / signals .....	98
9.4.1	General .....	98
9.4.2	Radiated EMI to telecom equipment.....	98
9.4.3	Radiated EMI in higher frequency ranges .....	100
9.4.4	Descriptions of EMI cases .....	102
9.5	Summary .....	106
10	Standardisation, Legislation & Regulation .....	109
10.1	General .....	109
10.2	Present legislative & regulation situation.....	111
10.3	Present standardisation situation .....	114
10.4	Summary - Needs for the future.....	116
11	Conclusions .....	118
12	Recommendations .....	120
Annex A	MCS robustness A set of basic principles for field proven effective PLC systems operating in the CENELEC A-Band .....	122
Annex B	Measurement issues: Frequency-domain vs. Time-domain analysis .....	123
B.1	Frequency-domain methods .....	123
B.1.1	General .....	123
B.1.2	Frequency analyser based on DFT principle.....	123
B.1.3	Analyser based on heterodyne principle .....	130
B.2	Time-domain analysis .....	137
Annex C	Comparison of measurement methods for the frequency range 2 kHz – 150 kHz .....	141
C.1	General .....	141
C.2	Measurement Methods under Test .....	141
C.3	Signals for comparison purposes .....	141
C.3.1	Synthetic waveform.....	141
C.3.2	Battery Electric Vehicle Charger.....	142
C.3.3	Photovoltaic inverter and PLC-signal .....	142
C.4	Measurement setup.....	143
C.5	Summary of results .....	143
Annex D	Acronyms and abbreviations .....	147
Bibliography	.....	151

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

List of Figures

Figure 1 — Combinations of groups of equipment / systems to be considered related to EMI in the frequency range 2 kHz - 150 kHz ..... 13

Figure 2 — Typical smart metering architecture..... 16

Figure 3 — Multi-utility application of PLC technology ..... 17

Figure 4 — Smart Meter rollout status in Europe [6, 10] (Source: European Commission, DG ENER, 2014) 18

Figure 5 — MCS signal levels vs. NIE levels: Margin requirements for proper MCS function..... 21

Figure 6 — Network impedance behaviour in 2 kHz – 150 kHz across one cycle of the 50 Hz-supply voltage ..... 27

Figure 7 — Example of artificial network 9 kHz - 95 kHz and 95 kHz – 148,5 kHz (EN 50065-1, EN 55016-2-1) ..... 29

Figure 8 — Impedance values measured in the LV network of TUD ..... 30

Figure 9 — Impedance values in ERDF LV networks Preliminary measurement results ..... 31

Figure 10 — Measurement of effects of a PV inverter ..... 33

Figure 11 — Long-term EMI effects of EMI in 2 kHz - 150 kHz..... 36

Figure 12 — Simplified schematic diagram of a CFL (11W) without PFC..... 37

Figure 13 — Voltage and current measurement at 230 V (50 Hz) ..... 37

Figure 14 — Voltage and current measurement at 230 V (50 Hz) + 2,3V (5 kHz)..... 37

Figure 15 — Different types of graphical presentation in time- and frequency domain (Example: EV charger)39

Figure 16 — Time variation of emissions and signal attenuation in a Solar Campus, measured at the busbar45

Figure 17 — Spectrogram of emissions from a set of inverters switched off step by step..... 46

Figure 18 — Time variation of emissions and signal attenuation in the external LV grid, measured at the busbar ..... 47

Figure 19 — Time variation of emissions and signal attenuation in the external LV grid..... 47

Figure 20 — Spectra of three PV inverters for home use..... 48

Figure 21 — Impedance characteristic of inverters ..... 49

Figure 22 — Voltage and current values at switching frequency, if reactance of the network impedance is changed ..... 49

Figure 23 — Comparison between measured and predicted emission from inverter D for two network impedances ..... 49

Figure 24 — Emissions from a solar panel..... 50

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

Figure 25 — Example of CFL without PFC circuit Current emission in time and frequency domain. High-pass filtered waveform .....	52
Figure 26 — Example of CFL with aPFC circuit Current emission in time and frequency domain High-pass filtered waveform .....	52
Figure 27 — Example of an LED lamp Current emission in time and frequency domain High-pass filtered waveform .....	53
Figure 28 — Switching frequencies and emission levels for different lamps with electronic ballast (emission levels calculated as 200 Hz-bands, RMS).....	54
Figure 29 — Current drawn by the lamp, measured in time domain .....	55
Figure 30 — Current drawn by the lamp, measured in frequency domain .....	55
Figure 31 — Time / Frequency domain.....	56
Figure 32 — Current spectra of 4 BEV chargers (200-Hz-bands, RMS) .....	57
Figure 33 — Switching frequencies and emission levels for different EVs (800-Hz-bands, RMS).....	58
Figure 34 — EV1 charging pattern (Yellow) / Not charging pattern (Green) .....	59
Figure 35 — EV2 charging pattern (Yellow) / Not charging pattern (Green) .....	60
Figure 36 — High-pass filtered current and voltage waveforms of the BEV charging station .....	61
Figure 37 — High-pass filtered current and voltage spectra of the BEV charging station (200-Hz-bands, RMS) .....	61
Figure 38 — Measurement results of EV charging in time domain vs. frequency domain .....	62
Figure 39 — Emissions from an inverter-controlled heat pump .....	63
Figure 40 — Emissions from a Cola spender.....	64
Figure 41 — Emissions from a DVD player before (a)) and after (b)) installing a single-phase filter (35 kHz - 95 kHz).....	65
Figure 42 — Emissions from a TV box.....	65
Figure 43 — Emissions from a beer cooler in operation (a)) and after switch-off (b)) .....	66
Figure 44 — Emissions from a travelling circus'equipment .....	67
Figure 45 — Emissions from a fibre switch with built-in power supply .....	67
Figure 46 — Emissions from a power supply to a network router before (a)) and after (b) replacement .....	68
Figure 47 — Emissions from a plugin charger Higher emission levels can be recognised on from ~3 kHz, with .....	68
Figure 48 — Emissions from a PSU, pretending a three-phase EMC problem .....	69
Figure 49 — Emissions from a PLC modem .....	70

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

Figure 50 — Emissions from a microwave oven .....	70
Figure 51 — High-pass filtered current waveform for one cycle of the fundamental .....	71
Figure 52 — Current emission spectrum (200-Hz-bands, RMS).....	71
Figure 53 — Types of EMI effects in the frequency range 2 kHz - 150 kHz .....	73
Figure 54 — Network scheme with locations of customers, complaints and measurement .....	74
Figure 55 — Spectrum of voltage at site c (200Hz-bands).....	74
Figure 56 — Inverter emissions measured at the end of the CNC mill feeder (site c).....	75
Figure 57 — Emissions from a dimmable ceiling lighting equipment.....	75
Figure 58 — Noise level at an induction cooker .....	76
Figure 59 — Spectrum FFT-voltage DC to 20 kHz, measured at the connection point of the automatic lathe	77
Figure 60 — Emissions from a power adapter to a TV box.....	78
Figure 61 — Emissions from an LED construction light .....	78
Figure 62 — Signal current waveforms on phase L3 connected to a single phase photovoltaic inverter, showing significant high frequency current emissions at about 20 kHz .....	79
Figure 63 — Current and voltage waveform at minimum and maximum levels of the disturbing emission.....	80
Figure 64 — Network situation at measurements in Caluire et Cuire .....	81
Figure 65 — Max holds measurement of supply voltage spectrum .....	82
Figure 66 — TV amplifier (up to ~ 110 dB $\mu$ V noise floor).....	83
Figure 67 — Variable speed drive of an elevator (80 dB $\mu$ V noise floor with peaks 92,1 dB $\mu$ V (48,3 kHz), 85,96 dB $\mu$ V (65 kHz), 101,81 dB $\mu$ V (72,6 kHz)) .....	83
Figure 68 — PC screen (100 dB $\mu$ V noise floor with peak 129,1 dB $\mu$ V at 65,7 kHz).....	83
Figure 69 — Power supply voltage (Phase L1) before any action .....	84
Figure 70 — Power supply voltage (Phase L1) after disconnection of the EMI source .....	85
Figure 71 — Peak levels of emissions from a PLC homeplug modem, measured at different points .....	86
Figure 72 — Peak levels of emissions from a voltage converter .....	87
Figure 73 — Emission peak levels from a voltage converter before taking action.....	87
Figure 74 — Emission peak levels from a voltage converter after replacement with a new one .....	88
Figure 75 — Emissions from a voltage converter to a broadband switch .....	89
Figure 76 — Emissions from a central TV amplifier measured on phase L2 at the incoming cable .....	90
Figure 77 — Emissions from a voltage converter at the substation .....	90



This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

Figure 78 — Emissions from a voltage converter at the incoming cable of two different apartment buildings..	91
Figure 79 — Emissions from a frequency-controlled ventilation .....	92
Figure 80 — Emissions from a frequency-controlled ventilation in an apartment building .....	92
Figure 81 — Emissions from rectifiers inside a mobile site before taking action .....	93
Figure 82 — Emissions from rectifiers inside a mobile site after installation of a filter .....	94
Figure 83 — Emissions from undercounter display fridges.....	94
Figure 84 — Power supplies of TV antenna amplifiers .....	95
Figure 85 — Power supplies of Base Transceiver Stations (BTS).....	95
Figure 86 — Inverter emissions .....	96
Figure 87 — LED lighting emissions .....	96
Figure 88 — Frequency-controlled heat pumps .....	97
Figure 89 — Emissions from a frequency control to a pellet boiler.....	98
Figure 90 — Radiated EMI to telecom equipment - Sources and effects .....	99
Figure 91 — Assignment of disturbance frequencies to the ranges DC to 150 kHz and above 150 kHz .....	101
Figure 92 — Conducted EMI from an EV battery charger to different devices in customer premises.....	102
Figure 93 — Disturbance shapes at ADSL modem before taking measures .....	103
Figure 94 — Emission spectra measured at point B (telecom line, L1 - E) of the ADSL modem with and without EV charging.....	103
Figure 95 — EMI situation after taking mitigation measures.....	104
Figure 96 — EMI due to fault currents from an electric fence.....	105
Figure 97 — Conducted disturbance levels in a telecom line due to fault currents from an electric fence .....	106
Figure 98 — Emission peak levels from measurements on emission levels and investigations on EMI cases .....	108
Figure 99 — Utilisation of frequencies in the range 2 kHz – 500 kHz.....	110
Figure 100 — Background to EMC problems in the frequency range 2 kHz – 150 kHz.....	112
Figure B.1 — General processing chain for DFT methods .....	123
Figure B.2 — Damping behaviour and measurement accuracy for the 4 <sup>th</sup> order Butterworth filter .....	125
Figure B.3 — Spectra of voltage at point of connection of photovoltaic infeed converter in laboratory at different fundamental frequencies, without high-pass filter [50].....	125
Figure B.4 — Amplitude frequency response and relative error of the proposed filter .....	126

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

Figure B.5 — Comparison of spectra of the same signal with different bandwidths .....	127
Figure B.6 — Location of the measurement intervals according to EN 61000-4-30:2015 Ed.3 [45], Annex C .....	127
Figure B.7 — Variation of the measurement results for the current of a LED lamp at 54 kHz for the methods according to EN 61000-4-7:2002 Ed.2, Annex B and EN 61000-4-30:2015 Ed.3, Annex C depending on the starting time of the measurement .....	128
Figure B.8 — Spectra of voltage in 5-Hz-resolution at the POC of a photovoltaic infeed converter with slightly shifted switching frequency (16 kHz and 16,07 kHz) and the resulting 200-Hz-bands .....	129
Figure B.9 — Filtered voltage waveform, at the point of connection of the PV inverter .....	130
Figure B.10 — Block diagram of a spectrum analyser (Super-Heterodyne Method) .....	131
Figure B.11 — Illustration of a 10-kHz-RBW for two signals of equal amplitude .....	133
Figure B.12 — RBW type and selectivity .....	134
Figure B.13 — RBW determines measurement time .....	135
Figure B.14 — Noise sidebands .....	136
Figure B.15 — Different waveforms in time domain and frequency domain .....	138
Figure B.16 — Time domain (a) vs. Frequency domain (b, calculated): Measurement results in a distribution network, at one and the same point of common coupling (PCC) and with a time difference of measurement < 0,5 s .....	139
Figure B.17 — Measurement at supply terminal in residential area .....	140
Figure C.1 — Waveform of the filtered synthetic signal .....	141
Figure C.2 — Spectrum of the filtered synthetic signal, in 200-Hz-bands according to EN 61000-4-7 .....	141
Figure C.3 — Waveform of the filtered charger signal .....	142
Figure C.4 — Spectrum of the filtered charger signal, in 200 Hz-bands according to EN 61000-4-7 .....	142
Figure C.5 — Waveform of the filtered PV inverter emission and PLC signal .....	142
Figure C.6 — Spectrum of the filtered PV inverter emission and PLC signal, in 200 Hz-bands according to EN 61000-4-7 .....	142
Figure C.7 — Comparison of the results for the different methods and different emissions/signals .....	144
Figure C.8 — Comparison of differences of the results between the individual methods and emissions / signals in relation to the method 2 (CISPR 16-2-1 QPk) in dB .....	144
Figure C.9 — Detailed results for the PV inverter emission using the method according to EN 61000-4-7 ..	145

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

List of Tables

Table 1 — EMC factors and its relevance for EMI in the frequency range 2 kHz - 150 kHz .....	14
Table 2 — Mass-roll-outs of smart metering in Europe (November 2014) .....	19
Table 3 — Main groups of EMI effects .....	22
Table 4 — Equipment figuring as a source of EMI, Examples .....	22
Table 5 — Equipment figuring as an EMI victim, Examples .....	23
Table 6 — Effects of EMI to equipment in the frequency range 2 kHz - 150 kHz, Examples .....	24
Table 7 — Max. voltage of the 16-kHz-sidebands of a PV inverter in percent of the inverter terminal voltage — Results of measurement and of calculation .....	34
Table 8 — Comparison of today's standards regarding the frequency range from 2 kHz to 150 kHz.....	40
Table 9 — Switch-off sequence of inverters.....	46
Table 10 — EMI due to radiated disturbances to equipment in the telecom field. Examples (Japan, 1996-98) .....	99
Table 11 — Overview of EMI cases caused by GCPCs (Japan, 1998).....	100
Table 12 — Examples of EMI cases due to emissions below 150 kHz, causing radiated disturbances in higher frequency ranges (Japan, 2012) .....	101
Table 13 — Protected frequency bands for standard frequency and time signal services [116].....	113
Table B.1 — Comparison of maximum, quadratic average and minimum values for the waveform from Figure B.9, 1 s duration .....	130

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

## **European foreword**

This document (CLC/TR 50669:2017) has been prepared by CLC/SC 205A "Mains communicating systems" of CLC/TC 205, "Home and Building Electronic Systems (HBES)".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

## **Introduction**

In April 2010, SC 205A<sup>1)</sup> published its first Study Report on “Electromagnetic Interference between Electrical Equipment in the Frequency Range 2 to 150 kHz” [1], providing first results of investigations on electromagnetic interference (EMI) in this frequency range, due to Touch-dimmer lamps (TDLs) as an EMI victim, an inverter as an EMI source, and automated meter reading systems using powerline communication (AMR-PLC) figuring as EMI victims as well as sources.

With a second edition of this Study Report, in 2013 [2], the specific situation in the frequency range 2 kHz - 150 kHz and the broad relevance of recognised EMI for safeguarding electromagnetic compatibility (EMC) also in this frequency range was highlighted; that also with provision of results of measurements on the existing situation of emissions in the grid as well as with an overview of results of investigations on proven EMI cases. This 2<sup>nd</sup> edition of the Study Report has been published as CLC/TR 50627:2015 [3].

Based on a third edition of this Study Report [4], CLC/TR 50669 covers the same scope as CLC/TR 50627 but provides a comprehensive set of additional measurement results on electromagnetic interference in this frequency range.

It documents the existing disturbances on the electricity supply network, including customer premises. It covers both products acting as emission sources and those which are susceptible to such, including cumulative effects and the effect of ageing of components that are intended to suppress emissions. It also provides information on interference mechanisms and on the current situation with regard to standardisation. The TR is based on investigation results (measurement results, reported EMI cases) from twelve countries involving network operators, manufacturers, universities, accredited test houses and consultants.

---

<sup>1)</sup> CENELEC SC 205A "Mains communicating system"

This is a preview of "DS/CLC/TR 50669:2017". [Click here to purchase the full version from the ANSI store.](#)

## **1 Scope**

Following to [1, 2, 3] having proceeded with the collection of related information, with this Technical Report, further extended information is provided including:

- the given EMC problems in the frequency range 2 kHz - 150 kHz, concerning EMC between electrical equipment in general as well as EMC between non-mains communicating equipment / systems (NCE) and mains communicating systems (MCS) as a particular issue
- the given situation of related emissions in the grid, with other measurement results
- EMI cases and related investigation results
- new findings on parameters to be considered when dealing with EMC in this frequency range, in particular related to
  - the impact of the network impedance and its variation over time on the more or less disturbing effect of emissions in this frequency range
  - the behaviour of emissions in this frequency range over time and the increasing need for performing also time domain measurements for comprehensively evaluating emissions and their disturbance potential
- the actual standardisation situation
- needs for the future, concerning
  - measurement of related emissions
  - investigation on the impedance of the grid / in installations over time
  - closing gaps in standardisation
  - installation guidelines and possibly regulatory measures related to the ageing effect.

In light of different positions on and in evaluating related EMC problems, with additional measurement results concerning emission levels in the supply network and results from investigations of additional proven EMI cases, the given problems are highlighted in more detail and recommendations for what to do in the future are provided.

## **2 General**

As the results of investigations having been made for the Study Reports [1, 2, 3] show, utilisation of the frequency range 2 kHz – 150 kHz by electrical equipment shows several effects, which, compared with other frequency ranges, needs to be considered as a somehow specific situation; that resulting in the need for consideration of these effects when considering related EMC issues.

In the following, extended information about this specific situation and measurement and investigation results on related emissions and EMI cases are provided.