

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

Mobile og faste offshoreenheder – Elektriske installationer – Del 4: Kabler

Mobile and fixed offshore units – Electrical
installations – Part 4: Cables

DANSK STANDARD
Danish Standards Association

Göteborg Plads 1
DK-2150 Nordhavn

Tel: +45 39 96 61 01

Tel: +45 39 96 61 01

dansk.standard@ds.dk

www.ds.dk

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

DS projekt: M320754

ICS: 47.020.60

Første del af denne publikations betegnelse er:

DS/IEC, hvilket betyder, at det er en international standard, der har status som dansk standard.

Denne publikations overensstemmelse er:

IDT med: IEC 61892-4:2007

DS-publikationen er på engelsk.

DS-publikationstyper

Dansk Standard udgiver forskellige publikationstyper.

Typen på denne publikation fremgår af forsiden.

Der kan være tale om:

Dansk standard

- standard, der er udarbejdet på nationalt niveau, eller som er baseret på et andet lands nationale standard, eller
- standard, der er udarbejdet på internationalt og/eller europæisk niveau, og som har fået status som dansk standard

DS-information

- publikation, der er udarbejdet på nationalt niveau, og som ikke har opnået status som standard, eller
- publikation, der er udarbejdet på internationalt og/eller europæisk niveau, og som ikke har fået status som standard, fx en teknisk rapport, eller
- europæisk præstandard

DS-håndbog

- samling af standarder, eventuelt suppleret med informativt materiale

DS-hæfte

- publikation med informativt materiale

Til disse publikationstyper kan endvidere udgives

- tillæg og rettelsesblade

DS-publikationsform

Publikationstyperne udgives i forskellig form som henholdsvis

- fuldtekstpublikation (publikationen er trykt i sin helhed)
- godkendelsesblad (publikationen leveres i kopi med et trykt DS-omslag)
- elektronisk (publikationen leveres på et elektronisk medie)

DS-betegnelse

Alle DS-publikationers betegnelse begynder med DS efterfulgt af et eller flere præfikser og et nr., fx **DS 383**, **DS/EN 5414** osv. Hvis der efter nr. er angivet et **A** eller **Cor**, betyder det, enten at det er et **tillæg** eller et **rettelsesblad** til hovedstandard, eller at det er indført i hovedstandard.

DS-betegnelse angives på forsiden.

Overensstemmelse med anden publikation:

Overensstemmelse kan enten være IDT, EQV, NEQ eller MOD

- **IDT:** Når publikationen er identisk med en given publikation.
- **EQV:** Når publikationen teknisk er i overensstemmelse med en given publikation, men præsentationen er ændret.
- **NEQ:** Når publikationen teknisk eller præsentationsmæssigt ikke er i overensstemmelse med en given standard, men udarbejdet på baggrund af denne.
- **MOD:** Når publikationen er modificeret i forhold til en given publikation.

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

INTERNATIONAL STANDARD

IEC 61892-4

First edition
2007-06

**Mobile and fixed offshore units –
Electrical installations –**

**Part 4:
Cables**



Reference number
IEC 61892-4:2007(E)

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Types, installation and operating conditions of cables	10
4.1 Types of cables.....	10
4.2 Voltage rating.....	10
4.2.1 Power frequency cables	10
4.2.2 Control and instrumentation cables.....	11
4.3 Cross-sectional areas of conductors and current-carrying capacities	11
4.3.1 Cross-sectional areas of conductors	11
4.3.2 Current-carrying capacities.....	13
4.3.3 Current-carrying capacities for continuous service.....	13
4.3.4 Correction factors for different ambient air temperatures	17
4.3.5 Correction factors for short time duty.....	18
4.3.6 Correction factors for cable grouping.....	21
4.4 Voltage drop.....	22
4.5 Estimation of lighting loads.....	22
4.6 Parallel connection of cables.....	22
4.7 Separation of circuits.....	22
4.8 Short circuit capacity (withstand capability).....	22
4.9 Conductor	22
4.10 Insulation material.....	23
4.11 Screen, core screen or shield.....	23
4.12 Sheathing material	23
4.13 Metallic braid armour.....	23
4.14 Fire performance.....	23
4.15 Bending radius	24
Annex A (informative) Tabulated current-carrying capacities – Defined installations	26
Annex B (Informative) Fire stops.....	40
Annex C (Informative) Jet fire test for hydrocarbon (HCF) fire resistant cables	41
Annex D (Informative) Drilling fluid test procedure and requirements	42
Bibliography.....	44
Table 1 – Choice of cables for a.c. systems.....	11
Table 2 – Sizes of earth continuity conductors* and equipment earthing connections.....	13
Table 3 – Coefficient related to maximum permissible temperature of the conductor.....	14
Table 4 – Current-carrying capacities in continuous service at maximum rated conductor temperature of 70 °C (ambient air temperature 45 °C).....	15

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

Table 5 – Current-carrying capacities in continuous service at maximum rated conductor temperature of 90 °C (ambient air temperature 45 °C)	16
Table 6 – Current-carrying capacities in continuous service at maximum rated conductor temperature of 95 °C (ambient air temperature 45 °C)	17
Table 7 – Correction factor for various ambient air temperatures (reference ambient temperature of 45 °C)	18
Table 8 – Correction factor for various ambient air temperatures (reference ambient temperature of 30 °C)	18
Table 9 – Bending radii for cables rated up to 1,8/3 kV	25
Table 10 – Bending radii for cables rated at 3,6/6,0(7,2) kV and above	25
Table A.1 – Current-carrying capacities in amperes – Copper conductor temperature 60 °C and reference ambient air temperature 45 °C	29
Table A.2 – Current-carrying capacities in amperes – Copper conductor temperature 70 °C and reference ambient air temperature 45 °C	30
Table A.3 – Current-carrying capacities in amperes – Copper conductor temperature 85 °C and reference ambient air temperature 45 °C	31
Table A.4 – Current-carrying capacities in amperes – Copper conductor temperature 60 °C and reference ambient air temperature 30 °C	32
Table A.5 – Current-carrying capacities in amperes – Copper conductors temperature 70 °C and reference ambient temperature 30 °C	33
Table A.6 – Current-carrying capacities in amperes – Copper conductors temperature 85 °C and reference ambient temperature 30 °C	34
Table A.7 – Current-carrying capacities in amperes – Copper conductors temperature 90 °C and reference ambient temperature 45 °C	35
Table A.8 – Current-carrying capacities in amperes – Copper conductors temperature 95 °C and reference ambient temperature 45 °C	36
Table A.9 – Correction factors for groups of more than one circuit or of more than one multi-core cable to be used with current-carrying capacities of Tables A.1 to A.8	37
Table A.10 – Correction factors for group of more than one multi-core cable to be applied to reference ratings for multi-core cables in free air – Method of installation E in Tables A.1 to A.8	38
Table A.11 – Correction factors for groups of more than one circuit of single-core cables to be applied to reference rating for one circuit of single-core cables in free air – Method of installation F in Tables A.1 to A.8	39
Figure 1 – Time constant of cables	19
Figure 2 – Correction factors for half-hour and one-hour service	20
Figure 3 – Correction factor for intermittent service	21
Figure C.1 – International recognized HC fire curve	41

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –
ELECTRICAL INSTALLATIONS –**

Part 4: Cables

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-4 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units, in cooperation with SC 18A: Cables and cable installations.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/1052/FDIS	18/1058/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

A list of all parts of the IEC 61892 series, published under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

INTRODUCTION

IEC 61892 forms a series of International Standards intended to enable safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilisation of electrical energy for all purposes in offshore units which are being used for the purpose of exploration or production of petroleum resources.

This part of IEC 61892 also incorporates and coordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements of the International Maritime Organisation. It also constitutes a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organisations.

This standard is based on equipment and practices which are in current use but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International standards exclusively for the offshore petroleum industry.

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 4: Cables

1 Scope

This part of IEC 61892 specifies requirements for the choice and installation of electrical cables intended for fixed electrical systems in mobile and fixed offshore units, including pumping or “pigging” stations, compressor stations and exposed location single buoy moorings, used in the offshore petroleum industry for drilling, production, processing and for storage purposes.

The reference to fixed electrical systems includes those that are subjected to vibration due to the movement of the unit, e.g. cables installed on a drag chain, and not those that are intended for repeated flexing. Cables suitable for repeated flexing use are detailed in other IEC specifications, e.g. IEC 60227 and IEC 60245, and their uses on board offshore units are restricted to those situations which do not directly involve exposure to a marine environment, e.g. portable tools, domestic appliances, etc.

The following types and applications of cables are not included:

- optical fibre cables;
- sub-sea and umbilical cables;
- cables supplying downhole pumps;
- data, telecommunication and radio frequency cables.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:1983, *IEC standard voltages*¹⁾
Amendment 1 (1994)
Amendment 2 (1997)

IEC 60092-350:2001, *Electrical installations in ships – Part 350: Shipboard power cables - General construction and test requirements*

IEC 60092-351, *Electrical installations in ships – Part 351: Insulating materials for shipboard and offshore units, power, control, instrumentation, telecommunication and data cables*

IEC 60092-353, *Electrical installations in ships – Part 353: Single and multicore non-radial field power cables with extruded solid insulation for rated voltages 1 kV and 3 kV*

IEC 60092-354, *Electrical installations in ships – Part 354: Single and three-core power cables with extruded solid insulation for rated voltages 6 kV ($U_m=7,2$ kV); up to 30 kV ($U_m=36$ kV)*

¹⁾ There exists a consolidated edition 6.2 (2002) including IEC 60038:1983 and its Amendments 1 and 2.

This is a preview of "DS/IEC 61892-4:2007". [Click here to purchase the full version from the ANSI store.](#)

IEC 60092-359, *Electrical installations in ships – Part 359: Sheathing materials for shipboard power and telecommunication cables*

IEC 60092-376, *Electrical installations in ships – Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)*

IEC 60228:2004, *Conductors of insulated cables*

IEC 60331-21:1999, *Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to and including 0,6/1,0 kV*

IEC 60331-31:2002, *Tests for electric cables under fire conditions – Circuit integrity – Part 31: Procedures and requirements for fire with shock – Cables of rated voltage up to and including 0,6/1 kV*

IEC 60332-1-2:2004, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60332-3-22:2000, *Tests on electric cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A*

IEC 60754-1:1994, *Test on gases evolved during combustion of materials from cables – Part 1: Determination of the amount of halogen acid gas*

IEC 60754-2:1991, *Test on gases evolved during combustion of electric cables – Part 2: Determination of degree of acidity of gases evolved during the combustion of materials taken from electric cables by measuring pH and conductivity*
Amendment 1 (1997)

IEC 61034-2:2005, *Measurement of smoke density of cables burning under defined conditions – Part 2: Test procedure and requirements*

IEC 61892-1:2001, *Mobile and fixed offshore units – Electrical installations – Part 1: General requirements and conditions*

IEC 61892-2, *Mobile and fixed offshore units – Electrical installations – Part 2: System design*

IEC 61892-6, *Mobile and fixed offshore units – Electrical installations – Part 6: Installation*

3 Terms and definitions

3.1

appropriate authority

governmental body and/or classification society with whose rules an offshore unit is required to comply

3.2

braid armour

covering formed from braided metal wires used to protect the cable from external mechanical effects

3.3

braid

covering made of plaited metallic or non-metallic material