

Renrum og tilknyttede kontrollerede områder – Del 16: Energieffektivitet i renrum og udstyr til adskillelse

Cleanrooms and associated controlled environments – Part 16: Energy efficiency in cleanrooms and separative devices (ISO 14644-16:2019)

DANSK STANDARD
Danish Standards Association

Göteborg Plads 1
DK-2150 Nordhavn

Tel: +45 39 96 61 01

Tel: +45 39 96 61 01

dansk.standard@ds.dk

www.ds.dk

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

DS projekt: M323149

ICS: 13.040.35

Første del af denne publikations betegnelse er:

DS/EN ISO, hvilket betyder, at det er en international standard, der har status både som europæisk og dansk standard.

Denne publikations overensstemmelse er:

IDT med: ISO 14644-16:2019

IDT med: EN ISO 14644-16:2019

DS-publikationen er på engelsk.

DS-publikationstyper

Dansk Standard udgiver forskellige publikationstyper.

Typen på denne publikation fremgår af forsiden.

Der kan være tale om:

Dansk standard

- standard, der er udarbejdet på nationalt niveau, eller som er baseret på et andet lands nationale standard, eller
- standard, der er udarbejdet på internationalt og/eller europæisk niveau, og som har fået status som dansk standard

DS-information

- publikation, der er udarbejdet på nationalt niveau, og som ikke har opnået status som standard, eller
- publikation, der er udarbejdet på internationalt og/eller europæisk niveau, og som ikke har fået status som standard, fx en teknisk rapport, eller
- europæisk præstandard

DS-håndbog

- samling af standarder, eventuelt suppleret med informativt materiale

DS-hæfte

- publikation med informativt materiale

Til disse publikationstyper kan endvidere udgives

- tillæg og rettelsesblade

DS-publikationsform

Publikationstyperne udgives i forskellig form som henholdsvis

- fuldttekstpublikation (publikationen er trykt i sin helhed)
- godkendelsesblad (publikationen leveres i kopi med et trykt DS-omslag)
- elektronisk (publikationen leveres på et elektronisk medie)

DS-betegnelse

Alle DS-publikationers betegnelse begynder med DS efterfulgt af et eller flere præfikser og et nr., fx **DS 383**, **DS/EN 5414** osv. Hvis der efter nr. er angivet et **A** eller **Cor**, betyder det, enten at det er et **tillæg** eller et **rettelsesblad** til hovedstandard, eller at det er indført i hovedstandard.

DS-betegnelse angives på forsiden.

Overensstemmelse med anden publikation:

Overensstemmelse kan enten være IDT, EQV, NEQ eller MOD

- **IDT:** Når publikationen er identisk med en given publikation.
- **EQV:** Når publikationen teknisk er i overensstemmelse med en given publikation, men præsentationen er ændret.
- **NEQ:** Når publikationen teknisk eller præsentationsmæssigt ikke er i overensstemmelse med en given standard, men udarbejdet på baggrund af denne.
- **MOD:** Når publikationen er modificeret i forhold til en given publikation.

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

EUROPÄISCHE NORM

June 2019

ICS 13.040.35

English Version

Cleanrooms and associated controlled environments - Part 16: Energy efficiency in cleanrooms and separative devices (ISO 14644-16:2019)

Salles propres et environnements maîtrisés
apparentés - Partie 16: Efficacité énergétique
dans les salles propres et les dispositifs
séparatifs (ISO 14644-16:2019)

Reinräume und zugehörige Reinraumbereiche
- Teil 16: Energieeffizienz von Reinräumen
und Reinluftgeräten (ISO 14644-16:2019)

This European Standard was approved by CEN on 30 May 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

Contents

Page

European foreword	3
-------------------------	---

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

European foreword

This document ([EN ISO 14644-16:2019](#)) has been prepared by Technical Committee ISO/TC 209 "Cleanrooms and associated controlled environments" in collaboration with Technical Committee CEN/TC 243 "Cleanroom technology" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2019, and conflicting national standards shall be withdrawn at the latest by December 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of [ISO 14644-16:2019](#) has been approved by CEN as [EN ISO 14644-16:2019](#) without any modification.

This is a preview of "DS/EN ISO 14644-16:2...". [Click here to purchase the full version from the ANSI store.](#)

First edition
2019-05-30

Cleanrooms and associated controlled environments —

Part 16: Energy efficiency in cleanrooms and separative devices

Salles propres et environnements maîtrisés apparentés —

Partie : Efficacité énergétique dans les salles propres et les dispositifs séparatifs



Reference number
ISO 14644-16:2019(E)

© ISO 2019

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

Contents

	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 General terms.....	1
3.2 Terms related to installation.....	3
3.3 Terms related to energy efficiency.....	4
3.5 Abbreviated terms.....	4
4 Energy reduction evaluation and implementation process	5
4.1 General.....	5
4.2 New or existing cleanrooms.....	6
4.3 Energy performance comparison.....	7
4.3.1 General.....	7
4.3.2 Compare energy performance.....	7
4.3.3 Determine the business case.....	7
4.3.4 Monitor and review.....	7
4.4 Existing cleanroom retrofit or renovation.....	7
4.5 Process for existing cleanrooms.....	8
4.5.1 Select project team.....	8
4.5.2 Review user requirements and project scope.....	8
4.5.3 Collate information on cleanroom performance criteria.....	9
4.6 Process for design/construction of new build or updating cleanrooms.....	9
4.6.1 Review user requirements and project scope.....	9
4.6.2 Undertake energy performance design review.....	9
4.7 Comparative review of cleanroom environmental performance.....	9
4.8 Identify energy reduction opportunities.....	10
4.9 Assess the impact of energy reduction opportunities.....	10
4.10 Select energy reduction opportunities for implementation.....	10
4.11 Implementation.....	10
4.12 Monitor, review and feedback.....	11
4.13 Decommissioning.....	11
5 Impact of user requirement specification (URS) on energy consumption	11
5.1 Principle.....	11
5.2 Garment levels.....	11
6 Airflow volume and compensating factors	12
6.1 Fresh air supply.....	12
6.2 Airflow volume rate.....	12
6.3 Source strength and airflow rate calculation for non-unidirectional rooms.....	12
6.3.1 Determining air volume flow rate.....	12
6.3.2 Ventilation effectiveness index.....	13
6.3.3 Compensation factors (C_f).....	13
6.4 Flexible procedure for airflow rate estimation in non-UDAF rooms.....	14
6.4.1 General.....	14
6.4.2 Design stage.....	14
6.4.3 Testing stage.....	15
6.4.4 Operational stage.....	15
6.5 Air velocity reduction for unidirectional air flow systems.....	15
7 Power management: turn-down, turn-off and recovery	15
7.1 Turn-down.....	15
7.2 Turn-off.....	16

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

8	Adaptive control	16
9	Heating and cooling loads	17
10	Fan and filter selection	17
	10.1 Air movement fans.....	17
	10.2 Selection of air filters.....	17
11	Lighting levels	18
12	Training	18
13	Operation	18
14	Maintenance	19
15	Decommissioning	20
	Annex A (informative) Source strength: Air volume and worked example	21
	Annex B (informative) Energy saving opportunities	26
	Annex C (informative) Impact assessment	32
	Annex D (informative) Benchmarking: Energy performance indicators for cleanrooms	33
	Annex E (informative) Useful measures to minimize excess heating and cooling losses or gains	38
	Annex F (informative) Critical area reduction example	40
	Bibliography	42

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 209, *Cleanrooms and associated controlled environments*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

A list of all parts in the [ISO 14644 series](#) can be found on the ISO website.

Introduction

Cleanrooms and associated controlled environments are widely used in many industries, such as life-sciences (including pharmaceutical, medical device), micro-electronics, aerospace, food processing, nuclear and hospitals. Operational size ranges from tens to thousands of square metres, most with unique design and operational characteristics based on their function. Their development has involved rapid expansion and progress for several decades, mirrored by an increasing energy demand. This document embraces the accumulated experiences and practices in cleanroom design, operation and maintenance, formulated to reduce their energy consumption and the global impact of this dramatic growth.

Users are also referred to [ISO 50001](#) for energy management.

Although varying greatly in function and size, the energy consumption of cleanrooms can be over 10 times higher than that for offices of similar size. A considerable amount of energy is required to provide large amounts of filtered and conditioned air to achieve specific levels of air cleanliness. Air movement fans can account for 35 % to 50 % of the HVAC consumption of cleanrooms due to the power required to overcome the high pressure differentials needed to operate high-efficiency filters and other circulation components in the cleanroom system. Production of this type of high-quality air can consume up to 80 % of the total energy used in a typical manufacturing facility.

Additional energy is also used to achieve temperature and relative humidity control for processes in the cleanroom, for personnel comfort and to achieve the requisite pressurization of the cleanroom space. There is therefore significant potential for energy saving by diligent design in the installation of new cleanrooms, and by retrofit improvements and upgrades to existing facilities. This document sets out the measures that can be taken to introduce these techniques and applies to the full spectrum of "cleanroom technology", from cleanrooms to clean air devices, including isolators, glove boxes and mini-environments as described in ISO 14644-7[1]. This document is based on actual experience, practice and tests supported by theoretical calculations for the purpose of clear and scientific description of the effects of energy saving.

The energy saving methods and techniques used in this document are all general ones applicable to varied environments and situations. They are not process-specific and exclude related production processes such as water treatment, and oven, autoclave and stress cycling operations. Their specific application depends on the actual conditions of cleanroom operation as agreed between the customer, the supplier and the installation engineers.

At each stage in the cleanroom life cycle, opportunities exist to optimize system performance and reduce energy consumption. Energy saving measures implemented at the design stage achieve the most effective results for new cleanrooms, but similar energy savings can also be achieved for those currently in operation. Cleanrooms can be used singly or as a group, based on practical conditions on site.

During design, when information about the finished building and process is at its minimum, conservatism can dictate the oversizing of systems and the mandating of overly tight specifications. At this stage, challenging these specifications and design considerations is valuable for energy efficiency.

When setting the system to work and executing performance testing, there is an opportunity to adjust the system to accommodate the actual conditions as built to optimize the system performance and minimize energy usage.

During the operating life of the facility, analysis of monitoring data can and should be used to further optimize system performance and minimize energy usage.

This is a preview of "DS/EN ISO 14644-16:2...". Click here to purchase the full version from the ANSI store.

Cleanrooms and associated controlled environments —

Part 16:

Energy efficiency in cleanrooms and separative devices

1 Scope

This document gives guidance and recommendations for optimizing energy usage and maintaining energy efficiency in new and existing cleanrooms, clean zones and separative devices. It provides guidance for the design, construction, commissioning and operation of cleanrooms.

This document covers all cleanroom-specific features and can be used in different areas to optimize energy use in electronic, aerospace, nuclear, pharmaceutical, hospital, medical device, food industries and other clean air applications.

It also introduces the concept of benchmarking for the performance assessment and comparison of cleanroom energy efficiencies, while maintaining performance levels to ISO 14644 requirements^[2]^[3].

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

[ISO 50001](#), *Energy management systems — Requirements with guidance for use*